

QUESTIONS AND ANSWERS REPORT

To: Bidders
From: UNDP Syria
Subject: [supply of water pumps and irrigation equipment](#)
Reference: UNDP-SYR-RFQ-106-19
Date : 26-09-2019

UNDP Syria Procurement Unit has received questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Questions and Answers		
1	Q. Would you advise the average water levels in the wells? A. 80 meters	
2	Q. Kindly advise the required pressure at the wellhead A. 10 bars minimum	
3	Q. It was mentioned that the offer shall include all the equipment and materials required for the installation, trying out and all that is required to pump groundwater in the sites ,Would you clarify who is the responsible of the installation, and the responsibility of the power source that required for the trying the pumps. A. Party responsible for installation: beneficiaries Testing of pumps: technical committees by the ministry of agriculture who will provide a note "محضر استلام ومطابقة للمواصفات" indicating that the pumps are well functioning. This note is a requirement for releasing the payment	

All other terms and conditions remain unchanged