

Amendment No. 1 and Q&A Report

<u>To:</u>	Interested Bidders
<u>From:</u>	UNDP Syria
<u>Subject:</u>	Supply electrical materials for the Lighting Network in Homs City
<u>Reference:</u>	UNDP-SYR-RFQ-100-19
<u>Date:</u>	4 October 2019

Please note that we only require **the supply of the items mentioned in the RFQ without installation,**

يرجى الانتباه أن المطلوب هو فقط تقديم البنود المذكورة في المناقصة بدون تركيبها.

Important note:

As per technical specs, any led light whether device or bulb should have at least 130l/w.

**** UNDP Syria is answering on the received questions as in the following:***

	Question	Answer
1	For the price should be provided in Annex 1 " Technical Specifications for Lighting Network Maintenance Materials in Homs " does it Include the price of (Installation and purchase) together	we only require the supply of the items mentioned in the RFQ without installation.
2	You ask for LED bulbs. Do you mean just the bulbs (light) or the complete set that includes the structure and cover?	the LED bulb that mentioned in provision no 4 is only LED bulb 50w (no need to complete set).
3	Can you be more precise about who is responsible of signing for the final acceptance of the delivered goods?	The lightning directory in Homs City Council is the responsible for signing the final acceptance of the delivered goods.

4	Where is the exact delivery location of the required items?	Homs City مستودعات دائرة الإنارة قرب دوار تدمر
5	can you clarify with more details and specifications of item24 (Light holder+ Bulb holder) Also, can you explain item 20(Varied adjustments for lighting device)	We announced the attached specs, which includes the required clarifications,
6	I noticed that in the RFQ document there is no mention for item 29 and 30. However, the RFQ includes installation. Kindly clarify whether the RFQ is for supply or supply and installation In case installation is included: <ul style="list-style-type: none"> Item 29: How many points are there? Item 30: for how many days you will need the winch? In RFQ there is no mention for battery cells. Do I have to add them in the offer? The specifications for item 25-26-27 are different in the Technical attachments. Which specifications I have to comply with? 	we only require the supply of the items mentioned in the RFQ without installation, <ul style="list-style-type: none"> Item 25, 29 and 30 are mentioned in the general technical specs provided by the beneficiaries which are not required in the RFQ, The items mentioned in the general technical specs n.26,27,29 are related to the items 25,26,27 mentioned in the RFQ (lighting devices)

