

RFQ-299/19 - Rehabilitation of Medical Labs and Studying Halls of Pharmacy Department in Technical
Institute in Northern Technical University in East Mosul-Ninawa Governorate

Q and A from site visit

Item No:	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Height of the exterior wall	It is about 3.0 m
2	Shall all the floor be covered with tiles.	Yes, all the floors shall be covered with the porcelain tiles.
3	Where do you use the ceramic tiles?	It is to be used inside the laboratory rooms, for 1.2m height.
4	Which size is required for wall mounted fan?	18 inch is required