



### **BIDDER'S CONFERENCE – MINUTES OF MEETING**

**Assignment Name:**

ITB/UNDP/EU/001/2015 - Provision of Recovery, Recycle, Recharging Machine For HFC-32 Refrigerant - Hydrochlorofluorocarbons (HCFCs) Phase-out Management Plan (HPMP) Project

**Date and Time:**

6 April 2015, at 1000 hours in Aceh Meeting Room, UNDP, Menara Thamrin Kav. 3, Jakarta

**Closing Date and Time:**

Wednesday, 22<sup>nd</sup> April 2015, at 23.59 Jakarta Local Time

---

### **TO ALL INTERESTED BIDDERS**

Here below are Answers to Questions raised regarding the above assignment:

NO	Introduction & Guidance	
<b>Info</b>	Bid conference was opened with following agenda : <ol style="list-style-type: none"><li>1. Brief explanation on ITB document – administrative issue (closing date, submission form &amp; method, delivery place for submitting offer, etc).</li><li>2. Brief explanation on the back ground of project scope for each lot.</li><li>3. Last day for ITB clarification</li><li>4. Q &amp; A</li></ol> <p>The above explanation had been stated on ITB document. Bidders were encouraged to <u>carefully</u> read the ITB document before preparing the offer.</p>	
<b>1</b>	Q	<b>Please provide detail requirement on the 2-stage rotary vane high vacuum pump</b>
	A	Mist filter is an oil filter – prevents oil emission to atmosphere. 1.2 meter long, with metal handle at end of hose fits tight, areas and traps all the gas, a part of hose pipe. This will reduce leakage of gas. Both are common parts

2	Q	<b>What do exactly needed in the 4 way manifold gauge</b>
	A	This gauge manifold is not a part of recovery machine but extra “4 Way Gauge Manifold”. The technicians can use the same to recover the refrigerant of unserviceable machine as well as from MAC also. The part is a four way gauge manifold
3	Q	<b>Please explain the requirement of Spares for one year on the following items:</b> <b>* 2 Spare pressure guages</b> <b>*1 pressure (and other compound)</b>
	A	This is one set only one pressure and other compound or it is written as 2 Spare pressure gauges – one pressure and one compound
4	Q	<b>Please explain in detail on 1 set of service hoses with manual shut off valves 60” long. Standard 1½” refrigerant service hose, 60” long with manual shut off – Those two are one sentence? Does 1 set means 1pc of hose with manual shut off valves 60” long and 1pce of standard 1/4” refrigerant service hose 60” with manual shut off? Please confirm.</b>
	A	This sentence is 1 set of service hoses 60” {inch} length with manual shut of valves. This will consist of three hose pipes as standard color - yellow, blue and red or it is rewritten as 1 set of Standard 1½” refrigerant service hose, 60” long with manual shut off
5	Q	<b>Please confirm the required quantity for the following items:</b> <b>1. Refrigerant Recycling Unit - Moisture and oil removal from recovered refrigerant</b> <b>2. Refrigerant Charging Station–Evacuation and Charging(E&amp;C) with weighing scale</b> <b>3. Automatic stop controler for vacuum</b> <b>4. Automatic stop controler for charging</b> <b>5. Electronic Refrigerant Leak detector</b> <b>6. Charging Hose with valve</b>
	A	The requirement is for 8 (eight) units of equipment that will be delivered to 8 companies in 8 different locations. Therefore, the items mentioned below should support the need of EACH required unit.