

Date: 14 July 2015

Bulletin 2

Invitation to Bid for Supply and Delivery of Prefabricated Office Blocks

Reference No.: UNDP/ITB/05/2015

Question and Answers

1. Please clarify what is the thickness of UPVC roofing sheet in the BOQ sheet S.I. No. 12 as it is not clear.

Answer: The thickness of UPVC roofing sheet is 17 – 18 mm.