



QUESTIONS AND ANSWERS REPORT

<u>To:</u>	Consultants / Bidders / Offerors
<u>From:</u>	UNDP Lebanon
<u>Subject:</u>	Provision of Shelter rehabilitation Works in Palestinian Gatherings in Beqaa Area
<u>Reference:</u>	LEB/CO ITB/128/15
<u>Date:</u>	26 August 2015

UNDP Lebanon Procurement Unit has received several questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Questions and Answers		
1	Q.	What is the type of ceramic tiles specified?
	A.	Type of ceramic tiles to be local medium range quality
2	Q.	What is the type of electrical devices specified (outlets, switches, etc.)?
	A.	Type of electrical devices to be Vimar, ABB or equivalent (cable routing to be embedded in “cache cables”)
3	Q.	What does “unforeseen works” stand for?
	A.	“Unforeseen works” to be priced only when a description is provided within this item
4	Q.	What is the type of PPR and PVC pipes specified?
	A.	Type of PPR and PVC pipes to be API or equivalent
5	Q.	What is the type of mixers specified?
	A.	Type of mixers to be medium range quality with copper core (samples should be submitted for approval)

A site visit was held on Tuesday 25 August 2015 at 10:30 AM, please find below some clarifications made to the attended contractors:

- All accordion doors to be priced as regular aluminum doors.



- SBS membrane works to include preparation of surface, angle fillet, rough surface membrane CMC material or equivalent with 10cm overlap and 25cm high perimeter lap in addition to remaining BOQ item description
- PU waterproofing to include preparation of surface, angle fillet, 4 layers CMC material or equivalent with 25cm high perimeter lap in addition to remaining BOQ item description