

**PROJECT N° 91597 "STRENGTHENING OF MINEA TO ENHANCE PARTICIPATION AND INTERNATIONAL TECHNICAL CO-OPERATION"**

**ITB/080/MINEA/2016  
PROCUREMENT OF FOREST FIRE-FIGHTING EQUIPMENT**

**AMENDMENT 03**

This Amendment modifies the referred Invitation to Bid Document in the following terms:

1. The new deadline for the receipt of tenders is **18 October 2016 until 03:00 P.M. Official time of the Bolivarian Republic of Venezuela.**
2. Section 3a: List of requirements and technical specifications are completed and correct the technical specifications of item 3.2 as follows:

LOT	ITEMS	QUANT.	TECHNICAL SPECIFICATIONS	DELIVERY TIME
3	3.2	40	<b>Portable forest fire-fighting Pump - High pressure centrifugal:</b> Pump body 3 stage, with inlet port 2 "NPSH thread diameter and outlet or discharge of 1 ½" threaded NPSH. 4-stroke engine of 13 HP power. Pressures up to 345 psi (23.8 bar). Flow rates: up to 102 GPM (386 L / min). Weight of complete unit: 129 lbs. (59 kg.). manual pump priming discharge port: ½ "hose construction. Cylinder bronze seals and caps neoprene Max Operating Temperature: 140 ° F (about 60 ° C) Approximate dimensions: (Length x Width): 1-1 / 4 "diameter x 12 inches long. Weight: 2 pounds (0.91 kg). Unit Base Specifications: flat base with four tubular handles integrated to the base. Controls: Engine choke, throttle, and fuel valve control levers; keyed start switch; low oil pressure alert lamp and shutdown. Liquid Discharge Gauge: 0 to 600 PSI Dual unit (PSI/kilopascals).	60 days from the issuance of the Purchase Order (PO)

The remaining Terms and Conditions of the Invitation to Bid Document are kept unaltered. For more information, please enter the following link:

[http://procurement-notice.undp.org/view\\_notice.cfm?notice\\_id=32690](http://procurement-notice.undp.org/view_notice.cfm?notice_id=32690)

Yours sincerely,

**SERVICE CENTRE  
UNDP VENEZUELA**