

ADDENDUM I:

To: All potential bidders

Date: 25th October 2016

SUBJECT: RESPONSE TO REQUEST FOR CLARIFICATIONS

ITB185-16 Upgrade the Electricity Networks in five villages and the Feeder line of Al-Udhaim Subdistrict, Diyala Governorate

We are pleased to respond to all your request for clarifications as below

No	Request for clarification	Response by UNDP to the request for clarification
1	BOQs item 1: Transformer panel board consist of two MCCB 250A while the required specifications mentioned 250A and 400A please clarify?	We confirm 250 Amps per the item description <i>(in Transformer distribution item in BOQ and Attaching Drawing, each transformer)</i> have 2distribution boards each board includes 250A MCCB)
2	BOQs item 4 of HAMEED ALNADA, for lattice pole the English details mentioned 11m while Arabic mentioned 9 m please clarify?	This to clarify that the requirement is 9 m
3	Please clarify BOQs item 5 of Khaiet Al-Habbas, for lattice pole the English details mentioned 9m while Arabic mentioned 9m please clarify?	This to clarify that the requirement is 9 m
4	Please clarify UNDP -Required specifications for cables and conductors, please clarify the exact type and size also for twisted cable and ACC wires?	We clarify the exact type and size is as Per Annex (3) and the Technical Compliance Sheet (Section 9, item #4) of ITB

All other terms and conditions under this ITB remain unchanged.

UNDP looks forward to receiving your Bid and thanks you in advance for your interest in UNDP procurement opportunities.