

Communication 1

Request for Clarification

For ITB-4-012-2016

AND ITB-01-12-2016

Rehabilitation of Abuatni and Leihi Substations

Q 1- We require single line diagram. Kindly provide it.

Answer 1:

Single Line Diagram is only required for Abuatni station and it can be found in the last page of the GECOL Standard attached in the ITB.

Q 2- You required SF6 system but when we checked with the Electric company in Benghazi, the usual is based in air system. Can you reconfirm this.

Answer 2:

The two system are acceptable by GECOL.

Q 3- Is this electrical equipment will be open to any brand.

Answer:

Any brand of electrical equipment will be acceptable, provided that the proposed brand must comply with specification of the General Electric Company of Libya GECO, annexed in the ITB.