



QUESTIONS AND ANSWERS REPORT

<u>To:</u>	Bidders
<u>From:</u>	UNDP Lebanon
<u>Subject:</u>	Construction of Concrete Irrigation Canals and Networks in Machha- Akkar, North Lebanon
<u>Reference:</u>	LEB/CO ITB/245/16
<u>Date:</u>	27 December 2016

UNDP Lebanon Procurement Unit has received several questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Questions and Answers		
1	Q.	Can you send to me more details or clarifications about "construction of the bridge across the winter brook ".
	A.	The winter brook is where the concrete canal must be converted to an HDPE Pipe DN 300 for a length of 60 m and then it will be back to a concrete canal. For more details, refer to the longitudinal profile and to the preamble.