

Communication 3

Request for Clarification

For ITB-6-012-2016

Construction of four units of five classrooms prefabricated building in OBARI

Q 1- .In section 7 "Price Schedule Form including Bill of Quantity (BOQ)" points E1,E2,E the supplying of containers should include porcelain tile floor, but in Bill of Quantity in preamble, point 13.2 we read "The floors should be constructed of minimum 22 mm thick water resistant plywood fixed on to a metal joist framework and finished with "wall to wall" minimum 2.5 mm thick linoleum/vinyl carpet or tiles, solidly and evenly pressed and glued on to the under surface with all joints rendered water tight".

Do you confirm that we must supply porcelain tiles floor and not linoleum/vinyl carpet or tiles?

Answer 1:

In case of contradiction between BOQ and preamble/drawing, BOQ specification prevail. So, please follow BOQ specification