

Bid Bulletin No. (1)



Empowered lives.
Resilient nations.

Supply, lay & compacting of asphaltic concrete wearing course at Al Jabalain byway road, Al Jabalain Locality of White Nile State, Sudan ITB/KRT/19/043

#	Questions	Answers
1.	As per the specification it is chip Seal techniques. we have a question or clarifications. Can it be made normal/used asphalt pavement technique since the material is available?	No, Chip-seal machinery should be provided
2.	Base on above question quantity to be revised in a ton& can we offer an alternative method. all other side ditches, culverts, other finishing will not be part of this job? it is only 7.2m asphalt road	All culverts, ditches, bituminous and other finishing will be managed separately
3	in the Document of Scope of work AGGREGATES FOR BITUMINOUS PAVING MIXES: it stated 1. Aggregate for use in bituminous, binder and wearing courses, shall consist of crushed stone. it is stated 50 mm layer ONLY & as if its Binder & Wearing course it will be 120 mm	As per specifications it should be 50mm layer.
4	Is it possible receive advance payment against bank guarantee?	Not Applicable, please refer to Date Sheet Point 8.
5	Is performance bond required? If yes, are insurance companies accepted?	Not Applicable, please refer to Date Sheet Point 14.
6	is bid security required? If yes, are insurance companies accepted?	Not Applicable, please refer to Date Sheet Point 7.
7	Is it possible to receive payment outside Sudan?	Please refer to Date Sheet Point 15.
8	Will there be an organized site visit? If not, who is our contract to organize a trip?	<p>We encourage bidders to conduct a site visit at any time during (8th – 16th October 2019) in coordination with ministry of infrastructure & urban development/ White Nile. please they should contact:</p> <p>Mr. Sadam Kamal/ director road and Bridges/ Kosti Tel. 0912333872 Eng. Yahia SALIM / team leader - UN-Habitat Tel. 0915984187 & 0122326230</p>

9	Will there be a tender meeting in Khartoum?	No, bidders are advised to send their clarifications and answers will be posted in the e-Tendering system.
10	How are the evaluation percentages for technical and financial proposal?	Please refer to Data Sheet Point 28. No percentage will be used the method is "Non-discretionary "Pass" or "Fail" rating on the detailed contents of the Schedule of Requirements and Technical Specifications "