

**Site visit inquiries**  
**The project of rehabilitation of**  
**Daraa National Hospital – Maternity and Operations Departments**  
**Ref.UNDP-SYR-ITB-114-19**

**Second site visit: Thursday 10.10.2019**

- 1. The contractors asked to provide them with all plans of the hospital.**  
We will resend all available plans including:
  - Attachment No. P01: Operations department plans (Fire alarm system, Telephone network, Radio network, lighting switches plans and electrical panels details);
  - Attachment No. P02: Operations department architectural plans;
  - Attachment No. P03: Maternity department plans (basement and roof plans & conceptual elevations);
  - Attachment No. P03: Maternity department electricity plans (Lighting and switches, telephone network, radio network and cable holders' details).
- 2. The contractors asked to extend the deadline of submission until 01.11.19**  
The deadline will not be extended, and the deadline stays 20.10.19.
- 3. Is it possible to replace elevators' doors in the maternity hospital with stainless steel doors according to the elevators' international norm EN81 hence the old doors are made of painted steel?**  
The contractor should commit to the specs book – offers with improved specifications will be discussed with the engineering committee.
- 4. In the operations department – is the quantity of “the painting of wooden rafters” measured in square meter or length meter?**  
The quantity of this item is measured in length meter.
- 5. Regarding the bid bond determined in USD 12,000, when are they should be submitted, before the offers submission or after the bid opening?**  
Original bid security should be received **WITHIN 5 WORKING DAYS** from the deadline of the bid submission. Late submission of bid security beyond 5 working days will result in disqualification of the received bid.
- 6. Is it possible to conduct another site visit to inspect the mechanical equipment for each contractor separately?**  
Contractors who attended the two previous site visits can (during the third week of October) conduct additional non-mandatory site visit to inspect mechanical equipment but this site visit must be coordinated with Mr. Mosaab Abazeid one day before.

- 7. If a Syrian company own a bank account outside Syrian, can this company submit the bank security from the outside Syria bank? Can this company receive the payments to this bank in USD?**

You can submit the bid security from any bank, but the payment cannot be transferred in dollars as it is a Syrian company

- 8. How many boilers need to be maintained, knowing that they are currently working with capacity (%50)?**

The BoQ didn't mention the maintenance of the boilers.

- 9. How many air condensing units are required (item No.2 in the BoQ)?**

As per the BoQ – one unit.