



Empowered lives.
Resilient nations.

Q&A (Clarification) 2
ITB/UNDP/PETRA/87241/005/2019

Assignment Name:

Procurement of Power Transformer for Anutapura Hospital in Palu

Closing Date:

20 December 2019 at 19:00 (Western Indonesian Time, GMT+7)

TO ALL INTERESTED BIDDERS

Q&A - Clarifications to Questions		
1	Q	Panel ACB 630 A is not available in market. Can we replace it to ACB 800 A?
	A	The bidder may replace the panel to ACB 800A with long time protection 0.4 In to 1 In.
2	Q	What type of document format can be uploaded at UNDP e-tendering? MS. Word or pdf.
	A	All document shall be in PDF files only as stated in RFP.

Jakarta, 18 December 2019