

# Pre Site Visit Report



<b>ITB-002/20 Rehabilitation of Hamadan- Balad Compact Water Treatment Unit 400M3/hr, in Abi Al Khasseb District, Basrah Governorate</b>	Date of Site Visit	16/01/2020	Escorted by Military forces?		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
<b>Time of Site Visit</b>		Name(s) and job title of Gov. Rep.			
Start	End				
10: 00am	12:00 am	1-Mohammad Jabar 2-Mohamad Moneer Hassan 3-Hasananin	Station Engineer Sector Engineer Planning Engineer	End user Directorate of Basra Water Basra Governorate	
Names of companies attended		Rep. name	Mobile/Email	Signature	
1. Al-daiygm Company		Monther kamash	07828281474		
2. Handasat Al-Tareeq company		Hussian Junaet	07810147114		
3. Aber Shimal company		Saifadin Rash	07701696663		
4. Al –Hassan company		Ayad Mohammad Firhawon	07710828715		
5. Difaf Alrafedain company		Ala Abdulgafor Hossain	07705650050		
6. Shamis Company		Mohammad Asad	07901913016		
7. Almahara Alhandasiya company		Diya Kareem Ibrahim	07811224899		
8. Al Fitiyan company		Alla Fawzy	07703193953		
9. Bilady company		Ali Diyab	07801400434		
10. EITE Electric L.T .D company		Cen Ataser	<a href="mailto:Cen.ataser@elteelektrik.com">Cen.ataser@elteelektrik.com</a>		
11. Asama al Faiha		Ali kadim	07726654014		
12- Babylon International Company		Ahmad Majed	+97466654016		
13-Marfa Al-Khairat company		Hissam Jabeer	077010841111		
14- Matco		Dr Hameed	+97455674948		
15-Tareek AL Teber company		Ayat Sajad	07816905531		
16- Furat Gate company		Sarmat Faxit	07816164343		
17-Iraqi Basra Company		Ali Shakir Abdulla	07809201831		
18-Alkhawther Engineering		Bahaa hussein	07800402000		

19- AFAQ Altahawin company	Abdulkareem Abass	07712342126	
20- Nabid Alrafidain	Hameed Zedan Khalaf	07814301432	
21-Serhat Group	Mostfa Hosain Gazee	077026966512	
22-Experts international group	Mia Sliman	07702696512	
23- Eyon Al- fardat	Mahmmod Ahmad	07801411998	
24- Jabal Al-Fahid	Akram Jaber	07801968299	
25-Dorat Almoheet	Jasim Mohammad Jwad	07732714244	
26- Al Abyar Company	Abass Yazee	07714904136	
27- Alsamee Company	Hossain Abdul Razaq	07801010119	

## QUESTIONS AND ANSWERS During the site visit

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	<p>End user requested to increase the current quantities of following items:  Items 4-c –1set  Item 5-a -1Ea</p>	<p>The quantities in the BOQs changed to:  Item 4-c Qty changed to 2 set  Item 5-a Qty changed to 2 Ea</p>
	<p>End-user requested to Change the specs of Item 5-a capacity 2kg/h to increase to 6 Kg/h</p>	<p>The Item 5-a in BOQs increased to 6kg/hs capacity</p>
2	<p>End user requested to Change item # 8-a change from H=50m to H=60m</p>	<p>Item 8-a Head change from H=50m to H=60m</p>
3	<p>End user requested to Change item# 2-b change from H=65m to H=25m</p>	<p>Item 2-b Head change from H=65m to H=25m</p>
4	<p>End User Engineers requested protection by constructing retaining wall with reinforced concrete to support Bank of River</p>	<p>Additional item with detailed description for the Retaining Wall has been added to the BOQs as item #(1-d) to be part of the scope of works to perform by contractor.</p>
5	<p>All Contractors asked about the dimension of site Area</p>	<p>Existing Dimensions of site about (12* 50)m2 area</p>









Prepared by:  
Ibrahim Abdulla Aziz, Consultant Engineer of ICRRP  
21 January 2020