

Date: 26th Jan 2020

ADDENDUM 02

To:All Potential BiddersFrom:UNDP IRAQ

Subject:ITB-002-20 - Rehabilitation of Hamadan- Balad Compact Water Treatment Unit
400M3/hr, in Abi Al Khasseb District, Basrah Governorate, Iraq

Reference is made to the UNDP published procurement notice ref: **ITB-002-20 - Rehabilitation of Hamadan- Balad Compact Water Treatment Unit 400M3/hr, in Abi Al Khasseb District, Basrah Governorate, Iraq** on UNDP and UNGM websites respectively.

Based on UNDP Programme decision, all interested potential bidders are hereby notified that:

 As a result of the Site Visit conducted on 16th of January 2020, the BoQ item (8-a) for Filter Feed Pumps also changed from 30Kw to 55 Kw in line with the revised H 60=m. The Technical Compliance Sheet relevant item has also been revised accordingly and uploaded in UNDP E-tendering system.

The interested bidders are kindly requested to adhere to the changes made to the BoQ and Technical Compliance Sheet in order to submit their bids as per UNDP requirement.

All other Terms and Conditions in this ITB will remain in full force and unchanged.

Thank you in advance for your interest in UNDP procurement opportunities.

Sincerely

treve franceseketti

Piero Emanuele Franceschetti Head of Service Center