



*Empowered lives.
Resilient nations.*

INVITATION TO BID

Turnkey Supply, Installation and Commissioning of on-grid Roof Top PV Systems

ITB No.: UNDP-TUR-ITB(ORKOY)-2020/04

Project: PIMS 5323: Sustainable Energy Financing Mechanism for Solar Photovoltaic Systems in Forest Villages in Turkey

Country: Turkey

Issued on: 12 February 2020



Contents

Section 1. Letter of Invitation.....	4
Section 2. Instruction to Bidders.....	I
A. GENERAL PROVISIONS.....	1
1. Introduction.....	1
2. Fraud & Corruption, Gifts and Hospitality.....	1
3. Eligibility.....	1
4. Conflict of Interests.....	2
B. PREPARATION OF BIDS.....	2
5. General Considerations.....	2
6. Cost of Preparation of Bid.....	3
7. Language.....	3
8. Documents Comprising the Bid.....	3
9. Documents Establishing the Eligibility and Qualifications of the Bidder.....	3
10. Technical Bid Format and Content.....	3
11. Price Schedule.....	3
12. Bid Security.....	3
13. Currencies.....	4
14. Joint Venture, Consortium or Association.....	4
15. Only One Bid.....	5
16. Bid Validity Period.....	5
17. Extension of Bid Validity Period.....	5
18. Clarification of Bid (from the Bidders)	6
19. Amendment of Bids.....	6
20. Alternative Bids.....	6
21. Pre-Bid Conference.....	6
C. SUBMISSION AND OPENING OF BIDS.....	7
22. Submission.....	7
Hard copy (manual) submission.....	7
Email and eTendering submissions.....	7
23. Deadline for Submission of Bids and Late Bids.....	7
24. Withdrawal, Substitution, and Modification of Bids.....	8
25. Bid Opening.....	8
D. EVALUATION OF BIDS	8
26. Confidentiality.....	8
27. Evaluation of Bids.....	8
28. Preliminary Examination.....	9
29. Evaluation of Eligibility and Qualification.....	9
30. Evaluation of Technical Bid and prices.....	9
31. Due diligence.....	9
32. Clarification of Bids.....	10
33. Responsiveness of Bid.....	10
34. Nonconformities, Reparable Errors and Omissions.....	10
E. AWARD OF CONTRACT.....	11
35. Right to Accept, Reject, Any or All Bids.....	11
36. Award Criteria.....	11
37. Debriefing.....	11
38. Right to Vary Requirements at the Time of Award.....	11
39. Contract Signature.....	11
40. Contract Type and General Terms and Conditions.....	11
41. Performance Security.....	11
42. Bank Guarantee for Advanced Payment.....	11
43. Liquidated Damages.....	12

44. Payment Provisions.....	12
45. Vendor Protest.....	12
46. Other Provisions.....	12
Section 3. Bid Data Sheet.....	13
Section 4. Evaluation Criteria.....	21
Section 5a: Schedule of Requirements and Technical Specifications/Bill of Quantities.....	23
Section 5b: Other Related Requirements.....	44
Section 6: Returnable Bidding Forms / Checklist.....	47
Form A: Bid Submission Form.....	48
Form B: Bidder Information Form	49
Form C: Joint Venture/Consortium/Association Information Form.....	51
Form D: Eligibility and Qualification Form.....	52
Form E: Technical Bid FORMAT	55

Section 1. Letter of Invitation

The United Nations Development Programme (UNDP) hereby invites you to submit a Bid to this Invitation to Bid (ITB) for the above-referenced subject.

This ITB includes the following documents and the General Terms and Conditions of Contract which is inserted in the Bid Data Sheet:

- Section 1: This Letter of Invitation
- Section 2: Instruction to Bidders
- Section 3: Bid Data Sheet (BDS)
- Section 4: Evaluation Criteria
- Section 5: Schedule of Requirements and Technical Specifications
- Section 6: Returnable Bidding Forms
 - o Form A: Bid Submission Form
 - o Form B: Bidder Information Form
 - o Form C: Joint Venture/Consortium/Association Information Form
 - o Form D: Qualification Form
 - o Form E: Format of Technical Bid
 - o Form F: Price Schedule
 - o Form G: Form of Bid Security

If you are interested in submitting a Bid in response to this ITB, please prepare your Bid in accordance with the requirements and procedure as set out in this ITB and submit it by the Deadline for Submission of Bids set out in Bid Data Sheet.

Please be informed that this procurement process is being conducted through the online tendering system of UNDP. Bidders who wish to submit an offer must be registered in the system.

- Visit this page for system user guides and videos in different languages:

<http://www.undp.org/content/undp/en/home/operations/procurement/business/procurement-notice/resources/>

- If already registered, go to <https://etendering.partneragencies.org> and sign in using your username and password.

- Use "Forgotten password" link if you do not remember your password. Do not create a new profile.

- If you have never registered in the system before, you can register by visiting the link below and follow the instructions in the user guide (attached): <https://etendering.partneragencies.org>

o Username: event.guest

o Password: why2change

- It is strongly recommended to create a username with two parts: your first name and last name separated by a ".", (similar to the one shown above). Once registered you will receive a valid password to the registered email address which you can use for signing in and changing your password.

- Please note that your new password should meet the following criteria:

o Minimum 8 characters

o At least one UPPERCASE LETTER

- o At least one lowercase letter
- o At least one number

You can view and download tender documents with the guest account as per the above username and password, However, if you are interested to participate, you must register in the system and subscribe to this tender to be notified when amendments are made.

E-Mail and Hard Copy Submissions are not accepted. Bids shall be submitted through e-tendering only.

However, **Original Bid Security** shall be delivered to the below address on or before the submission deadline indicated in e-tendering system, with a PDF copy submitted as part of the electronic submission.

Focal Point: Çağlar SELÇUK, Procurement Officer

Yıldız Kule, 21st Floor, Dikmen Mahallesi, Turan Güneş Bulvarı, No:106, 06550, Çankaya, Ankara, Turkey

If you are interested in submitting a Bid in response to this ITB, please prepare your Bid in accordance with the requirements and procedure as set out in this ITB and submit it by the Deadline for Submission of Bids set out in the e-Tendering System. Note that e-tendering system time zone is in **EST/EDT (New York)** time zone.

Please acknowledge receipt of this ITB by utilizing the “Accept Invitation” function in e-Tendering system. This will enable you to receive amendments or updates to the ITB. Should you require further clarifications, kindly communicate with the contact person/s identified in the attached Data Sheet as the focal point for queries on this ITB.

UNDP looks forward to receiving your Bid and thank you in advance for your interest in UNDP procurement opportunities.

Sincerely;

UNDP TURKEY Country Office

Section 2. Instruction to Bidders

GENERAL PROVISIONS

1. Introduction	<p>1.1 Bidders shall adhere to all the requirements of this ITB, including any amendments made in writing by UNDP. This ITB is conducted in accordance with the UNDP Programme and Operations Policies and Procedures (POPP) on Contracts and Procurement which can be accessed at https://popp.undp.org/SitePages/POPPBSUnit.aspx?TermID=254a9f96-b883-476a-8ef8-e81f93a2b38d</p> <p>1.2 Any Bid submitted will be regarded as an offer by the Bidder and does not constitute or imply the acceptance of the Bid by UNDP. UNDP is under no obligation to award a contract to any Bidder as a result of this ITB.</p> <p>1.3 UNDP reserves the right to cancel the procurement process at any stage without any liability of any kind for UNDP, upon notice to the bidders or publication of cancellation notice on UNDP website.</p> <p>1.4 As part of the bid, it is desired that the Bidder registers at the United Nations Global Marketplace (UNGM) website (www.ungm.org). The Bidder may still submit a bid even if not registered with the UNGM. However, if the Bidder is selected for contract award, the Bidder must register on the UNGM prior to contract signature.</p>
2. Fraud & Corruption, Gifts and Hospitality	<p>2.1 UNDP strictly enforces a policy of zero tolerance on proscribed practices, including fraud, corruption, collusion, unethical or unprofessional practices, and obstruction of UNDP vendors and requires all bidders/vendors observe the highest standard of ethics during the procurement process and contract implementation. UNDP's Anti-Fraud Policy can be found at http://www.undp.org/content/undp/en/home/operations/accountability/audit/office_of_audit_andinvestigation.html#anti</p> <p>2.2 Bidders/vendors shall not offer gifts or hospitality of any kind to UNDP staff members including recreational trips to sporting or cultural events, theme parks or offers of holidays, transportation, or invitations to extravagant lunches or dinners.</p> <p>2.3 In pursuance of this policy, UNDP:</p> <p>(a) Shall reject a bid if it determines that the selected bidder has engaged in any corrupt or fraudulent practices in competing for the contract in question;</p> <p>(b) Shall declare a vendor ineligible, either indefinitely or for a stated period, to be awarded a contract if at any time it determines that the vendor has engaged in any corrupt or fraudulent practices in competing for, or in executing a UNDP contract.</p> <p>2.4 All Bidders must adhere to the UN Supplier Code of Conduct, which may be found at http://www.un.org/depts/ptd/pdf/conduct_english.pdf</p>
3. Eligibility	<p>3.1 A vendor should not be suspended, debarred, or otherwise identified as ineligible by any UN Organization or the World Bank Group or any other international Organization. Vendors are therefore required to disclose to UNDP</p>

	<p>whether they are subject to any sanction or temporary suspension imposed by these organizations.</p> <p>3.2 It is the Bidder's responsibility to ensure that its employees, joint venture members, sub-contractors, service providers, suppliers and/or their employees meet the eligibility requirements as established by UNDP.</p>
4. Conflict of Interests	<p>4.1 Bidders must strictly avoid conflicts with other assignments or their own interests, and act without consideration for future work. Bidders found to have a conflict of interest shall be disqualified. Without limitation on the generality of the above, Bidders, and any of their affiliates, shall be considered to have a conflict of interest with one or more parties in this solicitation process, if they:</p> <ul style="list-style-type: none"> a) Are or have been associated in the past, with a firm or any of its affiliates which have been engaged by UNDP to provide services for the preparation of the design, specifications, Terms of Reference, cost analysis/estimation, and other documents to be used for the procurement of the goods and services in this selection process; b) Were involved in the preparation and/or design of the programme/project related to the goods and/or services requested under this ITB; or c) Are found to be in conflict for any other reason, as may be established by, or at the discretion of UNDP. <p>4.2 In the event of any uncertainty in the interpretation of a potential conflict of interest, Bidders must disclose to UNDP, and seek UNDP's confirmation on whether or not such conflict exists.</p> <p>4.3 Similarly, the Bidders must disclose in their Bid their knowledge of the following:</p> <ul style="list-style-type: none"> a) If the owners, part-owners, officers, directors, controlling shareholders, of the bidding entity or key personnel who are family members of UNDP staff involved in the procurement functions and/or the Government of the country or any Implementing Partner receiving goods and/or services under this ITB; and b) All other circumstances that could potentially lead to actual or perceived conflict of interest, collusion or unfair competition practices. <p>Failure to disclose such an information may result in the rejection of the Bid or Bids affected by the non-disclosure.</p> <p>4.4 The eligibility of Bidders that are wholly or partly owned by the Government shall be subject to UNDP's further evaluation and review of various factors such as being registered, operated and managed as an independent business entity, the extent of Government ownership/share, receipt of subsidies, mandate and access to information in relation to this ITB, among others. Conditions that may lead to undue advantage against other Bidders may result in the eventual rejection of the Bid.</p>
B. PREPARATION OF BIDS	
5. General Considerations	<p>5.1 In preparing the Bid, the Bidder is expected to examine the ITB in detail. Material deficiencies in providing the information requested in the ITB may result in rejection of the Bid.</p> <p>5.2 The Bidder will not be permitted to take advantage of any errors or omissions in the ITB. Should such errors or omissions be discovered, the Bidder must notify</p>

	the UNDP accordingly.
6. Cost of Preparation of Bid	6.1 The Bidder shall bear all costs related to the preparation and/or submission of the Bid, regardless of whether its Bid is selected or not. UNDP shall not be responsible or liable for those costs, regardless of the conduct or outcome of the procurement process.
7. Language	7.1 The Bid, as well as any and all related correspondence exchanged by the Bidder and UNDP, shall be written in the language (s) specified in the BDS.
8. Documents Comprising the Bid	8.1 The Bid shall comprise of the following documents and related forms which details are provided in the BDS: <ul style="list-style-type: none"> a) Documents Establishing the Eligibility and Qualifications of the Bidder; b) Technical Bid; c) Price Schedule; d) Bid Security, if required by BDS; e) Any attachments and/or appendices to the Bid.
9. Documents Establishing the Eligibility and Qualifications of the Bidder	9.1 The Bidder shall furnish documentary evidence of its status as an eligible and qualified vendor, using the Forms provided under Section 6 and providing documents required in those forms. In order to award a contract to a Bidder, its qualifications must be documented to UNDP's satisfaction.
10. Technical Bid Format and Content	10.1 The Bidder is required to submit a Technical Bid using the Standard Forms and templates provided in Section 6 of the ITB. 10.2 Samples of items, when required as per Section 5, shall be provided within the time specified and unless otherwise specified by the Purchaser, at no expense to the UNDP. If not destroyed by testing, samples will be returned at Bidder's request and expense, unless otherwise specified. 10.3 When applicable and required as per Section 5, the Bidder shall describe the necessary training programme available for the maintenance and operation of the equipment offered as well as the cost to the UNDP. Unless otherwise specified, such training as well as training materials shall be provided in the language of the Bid as specified in the BDS. 10.4 When applicable and required as per Section 5, the Bidder shall certify the availability of spare parts for a period of at least five (5) years from date of delivery, or as otherwise specified in this ITB.
11. Price Schedule	11.1 The Price Schedule shall be prepared using the Form provided in Section 6 of the ITB and taking into consideration the requirements in the ITB. 11.2 Any requirement described in the Technical Bid but not priced in the Price Schedule, shall be assumed to be included in the prices of other activities or items, as well as in the final total price.
12. Bid Security	12.1 A Bid Security, if required by BDS, shall be provided in the amount and form indicated in the BDS. The Bid Security shall be valid for a minimum of thirty (30) days after the final date of validity of the Bid. 12.2 The Bid Security shall be included along with the Bid. If Bid Security is required

	<p>by the ITB but is not found in the Bid, the offer shall be rejected.</p> <p>12.3 If the Bid Security amount or its validity period is found to be less than what is required by UNDP, UNDP shall reject the Bid.</p> <p>12.4 In the event an electronic submission is allowed in the BDS, Bidders shall include a copy of the Bid Security in their bid and the original of the Bid Security must be sent via courier or hand delivery as per the instructions in BDS.</p> <p>12.5 The Bid Security may be forfeited by UNDP, and the Bid rejected, in the event of any, or combination, of the following conditions:</p> <ul style="list-style-type: none"> a) If the Bidder withdraws its offer during the period of the Bid Validity specified in the BDS, or; b) In the event the successful Bidder fails: <ul style="list-style-type: none"> i. to sign the Contract after UNDP has issued an award; or ii. to furnish the Performance Security, insurances, or other documents that UNDP may require as a condition precedent to the effectivity of the contract that may be awarded to the Bidder.
13. Currencies	<p>13.1 All prices shall be quoted in the currency or currencies indicated in the BDS. Where Bids are quoted in different currencies, for the purposes of comparison of all Bids:</p> <ul style="list-style-type: none"> a) UNDP will convert the currency quoted in the Bid into the UNDP preferred currency, in accordance with the prevailing UN operational rate of exchange on the last day of submission of Bids; and b) In the event that UNDP selects a Bid for award that is quoted in a currency different from the preferred currency in the BDS, UNDP shall reserve the right to award the contract in the currency of UNDP's preference, using the conversion method specified above.
14. Joint Venture, Consortium or Association	<p>14.1 If the Bidder is a group of legal entities that will form or have formed a Joint Venture (JV), Consortium or Association for the Bid, they shall confirm in their Bid that : (i) they have designated one party to act as a lead entity, duly vested with authority to legally bind the members of the JV, Consortium or Association jointly and severally, which shall be evidenced by a duly notarized Agreement among the legal entities, and submitted with the Bid; and (ii) if they are awarded the contract, the contract shall be entered into, by and between UNDP and the designated lead entity, who shall be acting for and on behalf of all the member entities comprising the joint venture.</p> <p>14.2 After the Deadline for Submission of Bid, the lead entity identified to represent the JV, Consortium or Association shall not be altered without the prior written consent of UNDP.</p> <p>14.3 The lead entity and the member entities of the JV, Consortium or Association shall abide by the provisions of Clause 9 herein in respect of submitting only one Bid.</p> <p>14.4 The description of the organization of the JV, Consortium or Association must clearly define the expected role of each of the entities in the joint venture in delivering the requirements of the ITB, both in the Bid and the JV, Consortium or Association Agreement. All entities that comprise the JV, Consortium or Association shall be subject to the eligibility and qualification assessment by</p>

	<p>UNDP.</p> <p>14.5 A JV, Consortium or Association in presenting its track record and experience should clearly differentiate between:</p> <ul style="list-style-type: none"> a) Those that were undertaken together by the JV, Consortium or Association; and b) Those that were undertaken by the individual entities of the JV, Consortium or Association. <p>14.6 Previous contracts completed by individual experts working privately but who are permanently or were temporarily associated with any of the member firms cannot be claimed as the experience of the JV, Consortium or Association or those of its members, but should only be claimed by the individual experts themselves in their presentation of their individual credentials</p> <p>14.7 JV, Consortium or Associations are encouraged for high value, multi-sectoral requirements when the spectrum of expertise and resources required may not be available within one firm.</p>
15. Only One Bid	<p>15.1 The Bidder (including the individual members of any Joint Venture) shall submit only one Bid, either in its own name or as part of a Joint Venture.</p> <p>15.2 Bids submitted by two (2) or more Bidders shall all be rejected if they are found to have any of the following:</p> <ul style="list-style-type: none"> a) they have at least one controlling partner, director or shareholder in common; or b) any one of them receive or have received any direct or indirect subsidy from the other/s; or c) they have the same legal representative for purposes of this ITB; or d) they have a relationship with each other, directly or through common third parties, that puts them in a position to have access to information about, or influence on the Bid of another Bidder regarding this ITB process; e) they are subcontractors to each other's Bid, or a subcontractor to one Bid also submits another Bid under its name as lead Bidder; or some key personnel proposed to be in the team of one Bidder participates in more than one Bid received for this ITB process. This condition relating to the personnel, does not apply to subcontractors being included in more than one Bid.
16. Bid Validity Period	<p>16.1 Bids shall remain valid for the period specified in the BDS, commencing on the Deadline for Submission of Bids. A Bid valid for a shorter period may be rejected by UNDP and rendered non-responsive.</p> <p>16.2 During the Bid validity period, the Bidder shall maintain its original Bid without any change, including the availability of the Key Personnel, the proposed rates and the total price.</p>
17. Extension of Bid Validity Period	<p>17.1 In exceptional circumstances, prior to the expiration of the Bid validity period, UNDP may request Bidders to extend the period of validity of their Bids. The request and the responses shall be made in writing, and shall be considered integral to the Bid.</p> <p>17.2 If the Bidder agrees to extend the validity of its Bid, it shall be done without any change to the original Bid.</p>

	17.3 The Bidder has the right to refuse to extend the validity of its Bid, in which case, the Bid shall not be further evaluated.
18. Clarification of Bid (from the Bidders)	<p>18.1 Bidders may request clarifications on any of the ITB documents no later than the date indicated in the BDS. Any request for clarification must be sent in writing in the manner indicated in the BDS. If inquiries are sent other than specified channel, even if they are sent to a UNDP staff member, UNDP shall have no obligation to respond or confirm that the query was officially received.</p> <p>18.2 UNDP will provide the responses to clarifications through the method specified in the BDS.</p> <p>18.3 UNDP shall endeavour to provide responses to clarifications in an expeditious manner, but any delay in such response shall not cause an obligation on the part of UNDP to extend the submission date of the Bids, unless UNDP deems that such an extension is justified and necessary.</p>
19. Amendment of Bids	<p>19.1 At any time prior to the deadline of Bid submission, UNDP may for any reason, such as in response to a clarification requested by a Bidder, modify the ITB in the form of an amendment to the ITB. Amendments will be made available to all prospective bidders.</p> <p>19.2 If the amendment is substantial, UNDP may extend the Deadline for submission of Bid to give the Bidders reasonable time to incorporate the amendment into their Bids.</p>
20. Alternative Bids	<p>20.1 Unless otherwise specified in the BDS, alternative Bids shall not be considered. If submission of alternative Bid is allowed by BDS, a Bidder may submit an alternative Bid, but only if it also submits a Bid conforming to the ITB requirements. Where the conditions for its acceptance are met, or justifications are clearly established, UNDP reserves the right to award a contract based on an alternative Bid.</p> <p>20.2 If multiple/alternative bids are being submitted, they must be clearly marked as "Main Bid" and "Alternative Bid"</p>
21. Pre-Bid Conference	21.1 When appropriate, a pre-bid conference will be conducted at the date, time and location specified in the BDS. All Bidders are encouraged to attend. Non-attendance, however, shall not result in disqualification of an interested Bidder. Minutes of the Bidder's conference will be disseminated on the procurement website and shared by email or on the e-Tendering platform as specified in the BDS. No verbal statement made during the conference shall modify the terms and conditions of the ITB, unless specifically incorporated in the Minutes of the Bidder's Conference or issued/posted as an amendment to ITB.

c. SUBMISSION AND OPENING OF BIDS

22. Submission	<p>22.1 The Bidder shall submit a duly signed and complete Bid comprising the documents and forms in accordance with requirements in the BDS. The Price Schedule shall be submitted together with the Technical Bid. Bid can be delivered either personally, by courier, or by electronic method of transmission as specified in the BDS.</p> <p>22.2 The Bid shall be signed by the Bidder or person(s) duly authorized to commit the Bidder. The authorization shall be communicated through a document evidencing such authorization issued by the legal representative of the bidding entity, or a Power of Attorney, accompanying the Bid.</p> <p>22.3 Bidders must be aware that the mere act of submission of a Bid, in and of itself, implies that the Bidder fully accepts the UNDP General Contract Terms and Conditions.</p>
Hard copy (manual) submission	<p>22.4 Hard copy (manual) submission by courier or hand delivery allowed or specified in the BDS shall be governed as follows:</p> <p>a) The signed Bid shall be marked "Original", and its copies marked "Copy" as appropriate. The number of copies is indicated in the BDS. All copies shall be made from the signed original only. If there are discrepancies between the original and the copies, the original shall prevail.</p> <p>(b) The Technical Bid and Price Schedule must be sealed and submitted together in an envelope, which shall:</p> <ol style="list-style-type: none"> Bear the name of the Bidder; Be addressed to UNDP as specified in the BDS; and Bear a warning not to open before the time and date for Bid opening as specified in the BDS. <p>If the envelope with the Bid is not sealed and marked as required, UNDP shall assume no responsibility for the misplacement, loss, or premature opening of the Bid.</p>
Email and eTendering submissions	<p>22.5 Electronic submission through email or eTendering, if allowed as specified in the BDS, shall be governed as follows:</p> <ol style="list-style-type: none"> Electronic files that form part of the Bid must be in accordance with the format and requirements indicated in BDS; Documents which are required to be in original form (e.g. Bid Security, etc.) must be sent via courier or hand delivered as per the instructions in BDS. <p>22.6 Detailed instructions on how to submit, modify or cancel a bid in the eTendering system are provided in the eTendering system Bidder User Guide and Instructional videos available on this link: http://www.undp.org/content/undp/en/home/operations/procurement/business/procurement-notices/resources/</p>
23. Deadline for Submission of Bids and Late Bids	<p>23.1 Complete Bids must be received by UNDP in the manner, and no later than the date and time, specified in the BDS. UNDP shall only recognise the actual date and time that the bid was received by UNDP</p> <p>23.2 UNDP shall not consider any Bid that is received after the deadline for the</p>

	submission of Bids.
24. Withdrawal, Substitution, and Modification of Bids	<p>24.1 A Bidder may withdraw, substitute or modify its Bid after it has been submitted at any time prior to the deadline for submission.</p> <p>24.2 Manual and Email submissions: A bidder may withdraw, substitute or modify its Bid by sending a written notice to UNDP, duly signed by an authorized representative, and shall include a copy of the authorization (or a Power of Attorney). The corresponding substitution or modification of the Bid, if any, must accompany the respective written notice. All notices must be submitted in the same manner as specified for submission of Bids, by clearly marking them as "WITHDRAWAL" "SUBSTITUTION," or "MODIFICATION"</p> <p>24.3 eTendering: A Bidder may withdraw, substitute or modify its Bid by Cancelling, Editing, and re-submitting the Bid directly in the system. It is the responsibility of the Bidder to properly follow the system instructions, duly edit and submit a substitution or modification of the Bid as needed. Detailed instructions on how to cancel or modify a Bid directly in the system are provided in the Bidder User Guide and Instructional videos.</p> <p>24.4 Bids requested to be withdrawn shall be returned unopened to the Bidders (only for manual submissions), except if the bid is withdrawn after the bid has been opened.</p>
25. Bid Opening	<p>25.1 UNDP will open the Bid in the presence of an ad-hoc committee formed by UNDP of at least two (2) members.</p> <p>25.2 The Bidders' names, modifications, withdrawals, the condition of the envelope labels/seals, the number of folders/files and all other such other details as UNDP may consider appropriate, will be announced at the opening. No Bid shall be rejected at the opening stage, except for late submissions, in which case, the Bid shall be returned unopened to the Bidders.</p> <p>25.3 In the case of e-Tendering submission, bidders will receive an automatic notification once the Bid is opened.</p>
D. EVALUATION OF BIDS	
26. Confidentiality	<p>26.1 Information relating to the examination, evaluation, and comparison of Bids, and the recommendation of contract award, shall not be disclosed to Bidders or any other persons not officially concerned with such process, even after publication of the contract award.</p> <p>26.2 Any effort by a Bidder or anyone on behalf of the Bidder to influence UNDP in the examination, evaluation and comparison of the Bids or contract award decisions may, at UNDP's decision, result in the rejection of its Bid and may subsequently be subject to the application of prevailing UNDP's vendor sanctions procedures.</p>
27. Evaluation of Bids	<p>27.1 UNDP will conduct the evaluation solely on the basis of the Bids received.</p> <p>27.2 Evaluation of Bids shall be undertaken in the following steps:</p> <ol style="list-style-type: none"> Preliminary Examination including Eligibility Arithmetical check and ranking of bidders who passed preliminary examination by price. Qualification assessment (if pre-qualification was not done)

	<ul style="list-style-type: none"> a) Evaluation of Technical Bids b) Evaluation of prices <p>Detailed evaluation will be focussed on the 3 - 5 lowest priced bids. Further higher priced bids shall be added for evaluation if necessary</p>
28. Preliminary Examination	<p>28.1 UNDP shall examine the Bids to determine whether they are complete with respect to minimum documentary requirements, whether the documents have been properly signed, and whether the Bids are generally in order, among other indicators that may be used at this stage. UNDP reserves the right to reject any Bid at this stage.</p>
29. Evaluation of Eligibility and Qualification	<p>29.1 Eligibility and Qualification of the Bidder will be evaluated against the Minimum Eligibility/Qualification requirements specified in the Section 4 (Evaluation Criteria).</p> <p>29.2 In general terms, vendors that meet the following criteria may be considered qualified:</p> <ul style="list-style-type: none"> a) They are not included in the UN Security Council 1267/1989 Committee's list of terrorists and terrorist financiers, and in UNDP's ineligible vendors' list; b) They have a good financial standing and have access to adequate financial resources to perform the contract and all existing commercial commitments, c) They have the necessary similar experience, technical expertise, production capacity, quality certifications, quality assurance procedures and other resources applicable to the supply of goods and/or services required; d) They are able to comply fully with the UNDP General Terms and Conditions of Contract; e) They do not have a consistent history of court/arbitral award decisions against the Bidder; and f) They have a record of timely and satisfactory performance with their clients.
30. Evaluation of Technical Bid and prices	<p>30.1 The evaluation team shall review and evaluate the Technical Bids on the basis of their responsiveness to the Schedule of Requirements and Technical Specifications and other documentation provided, applying the procedure indicated in the BDS and other ITB documents. When necessary, and if stated in the BDS, UNDP may invite technically responsive bidders for a presentation related to their technical Bids. The conditions for the presentation shall be provided in the bid document where required.</p>
31. Due diligence	<p>31.1 UNDP reserves the right to undertake a due diligence exercise, aimed at determining to its satisfaction, the validity of the information provided by the Bidder. Such exercise shall be fully documented and may include, but need not be limited to, all or any combination of the following:</p> <ul style="list-style-type: none"> a) Verification of accuracy, correctness and authenticity of information provided by the Bidder; b) Validation of extent of compliance to the ITB requirements and evaluation criteria based on what has so far been found by the evaluation team; c) Inquiry and reference checking with Government entities with jurisdiction on the Bidder, or with previous clients, or any other entity that may have done business with the Bidder; d) Inquiry and reference checking with previous clients on the performance on on-going or completed contracts, including physical inspections of previous

	<p>works, as deemed necessary;</p> <p>e) Physical inspection of the Bidder's offices, branches or other places where business transpires, with or without notice to the Bidder;</p> <p>f) Other means that UNDP may deem appropriate, at any stage within the selection process, prior to awarding the contract.</p>
32. Clarification of Bids	<p>32.1 To assist in the examination, evaluation and comparison of Bids, UNDP may, at its discretion, request any Bidder for a clarification of its Bid.</p> <p>32.2 UNDP's request for clarification and the response shall be in writing and no change in the prices or substance of the Bid shall be sought, offered, or permitted, except to provide clarification, and confirm the correction of any arithmetic errors discovered by UNDP in the evaluation of the Bids, in accordance with the ITB.</p> <p>32.3 Any unsolicited clarification submitted by a Bidder in respect to its Bid, which is not a response to a request by UNDP, shall not be considered during the review and evaluation of the Bids.</p>
33. Responsiveness of Bid	<p>33.1 UNDP's determination of a Bid's responsiveness will be based on the contents of the bid itself. A substantially responsive Bid is one that conforms to all the terms, conditions, specifications and other requirements of the ITB without material deviation, reservation, or omission.</p> <p>33.2 If a bid is not substantially responsive, it shall be rejected by UNDP and may not subsequently be made responsive by the Bidder by correction of the material deviation, reservation, or omission.</p>
34. Nonconformities, Reparable Errors and Omissions	<p>34.1 Provided that a Bid is substantially responsive, UNDP may waive any non-conformities or omissions in the Bid that, in the opinion of UNDP, do not constitute a material deviation.</p> <p>34.2 UNDP may request the Bidder to submit the necessary information or documentation, within a reasonable period, to rectify nonmaterial nonconformities or omissions in the Bid related to documentation requirements. Such omission shall not be related to any aspect of the price of the Bid. Failure of the Bidder to comply with the request may result in the rejection of its Bid.</p> <p>34.3 For the bids that have passed the preliminary examination, UNDP shall check and correct arithmetical errors as follows:</p> <p>a) if there is a discrepancy between the unit price and the line item total that is obtained by multiplying the unit price by the quantity, the unit price shall prevail and the line item total shall be corrected, unless in the opinion of UNDP there is an obvious misplacement of the decimal point in the unit price; in which case, the line item total as quoted shall govern and the unit price shall be corrected;</p> <p>b) if there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected; and</p> <p>c) if there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail.</p> <p>34.4 If the Bidder does not accept the correction of errors made by UNDP, its Bid shall</p>

be rejected.

E. AWARD OF CONTRACT

35. Right to Accept, Reject, Any or All Bids	35.1 UNDP reserves the right to accept or reject any bid, to render any or all of the bids as non-responsive, and to reject all Bids at any time prior to award of contract, without incurring any liability, or obligation to inform the affected Bidder(s) of the grounds for UNDP's action. UNDP shall not be obliged to award the contract to the lowest priced offer.
36. Award Criteria	36.1 Prior to expiration of the period of Bid validity, UNDP shall award the contract to the qualified and eligible Bidder that is found to be responsive to the requirements of the Schedule of Requirements and Technical Specification, and has offered the lowest price.
37. Debriefing	37.1 In the event that a Bidder is unsuccessful, the Bidder may request for a debriefing from UNDP. The purpose of the debriefing is to discuss the strengths and weaknesses of the Bidder's submission, in order to assist the Bidder in improving its future Bids for UNDP procurement opportunities. The content of other Bids and how they compare to the Bidder's submission shall not be discussed.
38. Right to Vary Requirements at the Time of Award	38.1 At the time of award of Contract, UNDP reserves the right to vary the quantity of goods and/or services, by up to a maximum twenty-five per cent (25%) of the total offer, without any change in the unit price or other terms and conditions.
39. Contract Signature	39.1 Within fifteen (15) days from the date of receipt of the Contract, the successful Bidder shall sign and date the Contract and return it to UNDP. Failure to do so may constitute sufficient grounds for the annulment of the award, and forfeiture of the Bid Security, if any, and on which event, UNDP may award the Contract to the Second highest rated or call for new Bids.
40. Contract Type and General Terms and Conditions	40.1 The types of Contract to be signed and the applicable UNDP Contract General Terms and Conditions, as specified in BDS, can be accessed at http://www.undp.org/content/undp/en/home/procurement/business/how-we-buy.html
41. Performance Security	41.1 A performance security, if required in the BDS, shall be provided in the amount specified in BDS and form available at https://popp.undp.org/layouts/15/WopiFrame.aspx?sourcedoc=/UNDP_POPP_DOCUMENT_LIBRARY/Public/PSU_Solicitation_Performance%20Guarantee%20Form.docx&action=default within a maximum of fifteen (15) days of the contract signature by both parties. Where a performance security is required, the receipt of the performance security by UNDP shall be a condition for rendering the contract effective.
42. Bank Guarantee for Advanced Payment	42.1 Except when the interests of UNDP so require, it is UNDP's standard practice to not make advance payment(s) (i.e., payments without having received any outputs). If an advance payment is allowed as per the BDS, and exceeds 20% of the total contract price, or USD 30,000, whichever is less, the Bidder shall submit a Bank Guarantee in the full amount of the advance payment in the form available at

	https://popp.undp.org/_layouts/15/WopiFrame.aspx?sourcedoc=/UNDP_POPP_DOCUMENT_LIBRARY/Public/PSU_Contract%20Management%20Payment%20and%20Taxes_Advanced%20Payment%20Guarantee%20Form.docx&action=default
43. Liquidated Damages	<p>43.1 If specified in the BDS, UNDP shall apply Liquidated Damages for the damages and/or risks caused to UNDP resulting from the Contractor's delays or breach of its obligations as per Contract.</p>
44. Payment Provisions	<p>44.1 Payment will be made only upon UNDP's acceptance of the goods and/or services performed. The terms of payment shall be within thirty (30) days, after receipt of invoice and certification of acceptance of goods and/or services issued by the proper authority in UNDP with direct supervision of the Contractor. Payment will be effected by bank transfer in the currency of the contract.</p>
45. Vendor Protest	<p>45.1 UNDP's vendor protest procedure provides an opportunity for appeal to those persons or firms not awarded a contract through a competitive procurement process. In the event that a Bidder believes that it was not treated fairly, the following link provides further details regarding UNDP vendor protest procedures: http://www.undp.org/content/undp/en/home/procurement/business/protest-and-sanctions.html</p>
46. Other Provisions	<p>46.1 In the event that the Bidder offers a lower price to the host Government (e.g. General Services Administration (GSA) of the federal government of the United States of America) for similar goods and/or services, UNDP shall be entitled to the same lower price. The UNDP General Terms and Conditions shall have precedence.</p> <p>46.2 UNDP is entitled to receive the same pricing offered by the same Contractor in contracts with the United Nations and/or its Agencies. The UNDP General Terms and Conditions shall have precedence.</p> <p>46.3 The United Nations has established restrictions on employment of (former) UN staff who have been involved in the procurement process as per bulletin ST/SGB/2006/15 http://www.un.org/en/ga/search/view_doc.asp?symbol=ST/SGB/2006/15&referer</p>

Section 3. Bid Data Sheet

The following data for the goods and/or services to be procured shall complement, supplement, or amend the provisions in the Invitation to Bid In the case of a conflict between the Instructions to Bidders, the Bid Data Sheet, and other annexes or references attached to the Bid Data Sheet, the provisions in the Bid Data Sheet shall prevail.

BDS No.	Ref. to Section.2	Data	Specific Instructions / Requirements
1	7	Language of the Bid	English
2		Submitting Bids for Parts or sub-parts of the Schedule of Requirements (partial bids)	Not Allowed
3	14	Joint Venture, Consortium or Association	Not Allowed
4	20	Alternative Bids	Shall not be considered
5	21	Pre-Bid conference and e-tendering guiding session	<p>Will be Conducted Time: 11:00 hrs (GMT +3, Local Time-Turkey) Date: February 19, 2020 Venue: United Nations Development Programme (UNDP) Yıldız Kule , Yukarı Dikmen Mahallesi, Turan Güneş Bulvarı, No:106, Kat:16, 06550, Çankaya, Ankara/Turkey</p> <p>Following the pre-bid conference, e-tendering guiding session will also be conducted with the participants of the pre-bid conference bidders. The costs of participation to pre-bid conference are at the bidder's own expense.</p> <p>Please be informed that E-tendering guidance session will be conducted on how to prepare their bids through e-tendering. E-tendering session will be provided in Turkish.</p> <p>Prospective bidders are highly encouraged to visit following page for system user guides and videos in different languages before attending to the Guidance Session:</p> <p>http://www.undp.org/content/undp/en/home/operations/procurement/business/procurement-notice/resources/</p>

			<p>Prospective Bidders who wish to participate in the Pre-Bid Conference and e-tendering guiding session shall contact following focal point for arrangement no later than 17.02.2020.</p> <p>The UNDP focal point for the arrangement is: Çağlar Selçuk, Procurement Officer Telephone: 0312 454 1181 E-mail: caglar.selcuk@undp.org</p> <p>Failure of a Bidder to participate in the Pre-bid Conference shall not lead to any additional payment to the Bidder in case awarded by the Contract.</p>
6	16	Bid Validity Period	120 days starting from the submission deadline
7	13	Bid Security	<p>Required in the amount of USD 12,000.00</p> <p>Acceptable Forms of Bid Security</p> <ul style="list-style-type: none"> ▪ Bank Guarantee (See Section 6, Form G for template) <p>Bid Security shall be in English as per the template. Currency of the Bid Security shall be in USD as per the amount indicated above. No change shall be made to the template except for fields indicated in the template.</p> <p>Bid Securities will be returned to all bidders upon signature of contract with the successful Bidder.</p> <p>Bid Security shall be valid up to 30 days after the final date of validity of bids.</p> <p>PDF copy of the Bid Security shall be submitted as part of e-tendering submission. Additionally, original Bid Security shall be delivered to the below address on or before the submission deadline indicated in e-tendering system.</p> <p>Focal Point: Çağlar Selçuk, Procurement Officer Yıldız Kule, 21st Floor, Dikmen Mahallesi, Turan Güneş Bulvarı, No:106, 06550, Çankaya, Ankara, Turkey</p>
8	41	Advanced Payment upon signing of contract	Not Allowed
9	42	Liquidated Damages	<p>Will be imposed as follows:</p> <ul style="list-style-type: none"> • In case of the Contractor's failure to prepare the whole PV plant for commissioning within the framework described in Item 25 of Bid Data Sheet, 1% (one percent) of the total contract amount per week of delay shall be paid by the Contractor to UNDP, as liquidated damages. The maximum number of weeks of delays would be 3, after which UNDP may terminate the contract.

			<ul style="list-style-type: none"> The Contractor will also ensure presence of its Engineers (Electrical and Electronics Engineer/Electrical Engineer/Electronics Engineer/ Mechanical Engineer or equivalent having a work experience of at least 2 years in the field of PV installations) on site at all times until the Substantial Acceptance is made, in line with conditions of the contract. UNDP shall deduct US\$200 per day for any absence of the Contractor's key personnel on the site. In case of the Contractor's failure to perform services as per Technical Specifications in Section 5.a and Section 5.b or non-performance or delay in completing the submission of deliverables listed in payment table in Section 5.b, UNDP shall notify the Contractor in writing within at most one week following the detection of such failure. The contractor shall provide its reasons/justifications for the situation within at most one week following receipt of UNDP's above notification. If the Contractor's reasons/justifications are not deemed acceptable in the context of the Contract and in view of the nature of the Services, UNDP shall impose "liquidated damages" as per this article of the ITB. Once a deduction of 10% (ten percent) of the total contract amount has been reached, as a result of the issues listed above, UNDP may consider termination of the contract.
10	40	Performance Security	<p>Required in the amount of 10% of the total contract amount.</p> <p>Note: Performance Security will be a condition for signing the contract. Contract will be signed after receipt of performance security from the successful bidder.</p> <p>Performance security must be provided no later than 15 days after the bidder receives the award letter from UNDP. If the selected bidder fails to provide the security within this period, UNDP reserves the right to sign the contract with "Second lowest priced technically compliant bidder".</p> <p>The Performance Security must be issued by an accredited bank, in the format included in Appendix I to UNDP General Conditions of Contract for Civil Works and must be valid up to twenty-eight days after issuance of the Certificate of Final Completion. The Performance Security will only be released upon the issuance of Certificate of Final Completion in accordance with the Clause 10 of the UNDP General Conditions of Contract for Civil Works.</p>
11	12	Currency of Bid	United States Dollar (USD)
12	31	Deadline for submitting requests for clarifications/ questions	7 days before the submission deadline

13	31	Contact Details for submitting clarifications/questions	<p>Focal Person in UNDP: Çağlar Selçuk</p> <p>Address: Yıldız Kule, 21th Floor, Yukarı Dikmen Mahallesi, Turan Güneş Bulvarı, No:106, 06550, Çankaya, Ankara/Turkey</p> <p>E-mail address: tr.procurement@undp.org</p>
14	18, 19 and 21	Manner of Disseminating Supplemental Information to the ITB and responses/clarifications to queries	Posted directly to e-Tendering
15	23	Deadline for Submission	<p>March 10, 2020 23:59 hrs. (New York local time Zone)</p> <p>Note that system time zone is in EST/EDT (New York) time zone.</p>
16	22	Allowable Manner of Submitting Bids	<p>e-Tendering</p> <p>This procurement process is being conducted through the online tendering system of UNDP. Bidders who wish to submit an offer must be registered in the system.</p> <p>Visit this page for system user guides and videos in different languages: http://www.undp.org/content/undp/en/home/operations/procurement/business/procurement-notice/resources/</p> <p>If already registered, go to https://etendering.partneragencies.org and sign in using your username and password.</p> <p>Use "Forgotten password" link if you do not remember your password. Do not create a new profile.</p> <p>If you have never registered in the system before, you can register by visiting the link below and follow the instructions in the user guide (attached): https://etendering.partneragencies.org</p> <p>•Username: event.guest •Password: why2change</p> <p>It is strongly recommended to create a username with two parts: your first name and last name separated by a ".", (similar to the one shown above). Once registered you will receive a valid password to the registered email address which you can use for signing in and changing your password. Please note that your new password should meet the following criteria:</p> <ul style="list-style-type: none"> • Minimum 8 characters • At least one UPPERCASE LETTER

			<ul style="list-style-type: none"> • At least one lowercase letter • At least one number <p>You can view and download tender documents with the guest account as per the above username and password, However, if you are interested to participate, you must register in the system and subscribe to this tender to be notified when amendments are made.</p>
17	22	Bid Submission Address	<p>https://etendering.partneragencies.org</p> <p>Bids shall be submitted through e-tendering. However, original bid security shall be delivered to the below address with a PDF copy submitted as part of the electronic submission on or before the submission deadline indicated in e-tendering system:</p> <p>Focal Point: Çağlar Selçuk, Procurement Officer Yıldız Kule, 21st Floor, Dikmen Mahallesi, Turan Güneş Bulvarı, No:106, 06550, Çankaya, Ankara, Turkey</p> <p>Although bids shall be submitted through e-tendering, UNDP reserves the right to request original copies of the documents submitted as part of the bids during evaluation period, if required.</p>
18	22	Electronic submission (email or e-Tendering) requirements	<ul style="list-style-type: none"> ▪ Format: PDF files only ▪ File names must be maximum 60 characters long and must not contain any letter or special character other than from Latin alphabet/keyboard. ▪ All files must be free of viruses and not corrupted. ▪ Max. File Size per transmission: 45 MB
19	25	Date, time and venue for the opening of bid	No Public Opening will be conducted. Bidders will receive an automatic notification through e-tendering once their Bids are opened.
20	27, 36	Evaluation Method for the Award of Contract	Lowest priced technically responsive, eligible and qualified bid.
21		Expected date for commencement of Contract	<i>June 2020</i>
22		Maximum expected duration of contract	150 calendar days, starting from the date on which the Contractor is given Access to the Site and receive a notice from the UNDP Engineer to commence the Works and ending on the date of substantial completion of Works stated in the Certificate of Substantial Completion (Acceptances by relevant electricity distribution companies) .

			As stated in the General Conditions of Contract for Civil Works, clause 47.1; "Defects Liability Period" is 12 months calculated from the date of completion of the Works stated in the Certificate of Substantial Completion issued by the UNDP Engineer.
23	35	UNDP will award the contract to:	One Bidder Only
24	39	Type of Contract	Contract for Civil Works http://www.undp.org/content/undp/en/home/procurement/business/how-we-buy.html
25	39	UNDP Contract Terms and Conditions that will apply	UNDP General Terms and Conditions for Works http://www.undp.org/content/undp/en/home/procurement/business/how-we-buy.html
26		Tax Exemption	<p>UN and its subsidiary organs are exempt from all taxes. Therefore, Bidders shall prepare their Financial Proposals, excluding VAT. It is the Bidder's responsibility to learn from relevant authorities (Ministry of Finance) and/or to review/confirm published procedures and to consult with a certified financial consultant as needed, to confirm the scope and procedures of VAT exemption application as per VAT Law and Ministry of Finance's Communiqués.</p> <p>The Contractor to be selected cannot be entitled to receive any amount over its Bid price in relation to VAT. Overall contract amount to be paid to the Contractor shall not exceed the offered total price.</p> <p>Companies that were involved in the preparation of the feasibility plan/design/design drawings of this work cannot submit Bids to this Tender. In case such a company submits Bid for this ITB, the technical and financial Bids will be rejected and be returned to the Bidder through Bidder.</p>
27	44	Payment condition	<p>Payments are formulated as follows:</p> <p>Payment Terms; Payments will be realized on the items listed in Price Schedule under "Form F: Price Schedule Form". The Contractor shall submit monthly invoices and progress reports.</p> <p>The monthly payments will be realized for 90% of the amounts for the turnkey delivery of the On-grid Rooftop PV Systems which are approved by the Engineer in the corresponding month for the invoice.</p> <p>The final payment will be realized for 10% of the amounts for the all turnkey delivery of the On-grid Rooftop PV Systems after the</p>

			<p>completion/submission of the trainings, 2-year comprehensive machinery insurance (CMI) and substantial completion.</p> <p>The Contractor shall complete all trainings to the households and submit 2-year comprehensive machinery insurance (CMI) before substantial completion.</p> <p>The contractor shall also perform and complete acceptance of all On-grid Rooftop PV Systems by Local Electricity Distribution Companies (Positive Report on Successful Connection of the Solar PV System to national grid covers the commissioning of the PV System and the substantial acceptances of the local electric distribution company and/or TEDAS.) before the substantial completion.</p> <p>UNDP shall effect payment of the invoices after receipt of the certificate of payment issued by the Engineer, approving the amount contained in the invoice.</p> <p>The Engineer may make corrections to that amount, in which case UNDP may effect payment for the corrected amount. Engineer shall test electricity production of each system before the submission of the invoice.</p> <p>The Engineer may also withhold invoices if the work is not performed at any time in accordance with the terms of the Contract or if the necessary insurance policies or performance security are not valid and/or in order. The Engineer shall process the invoices submitted by the Contractor within 15 days of their receipt. Invoices will be paid within thirty (30) days of the date of their receipt and acceptance by UNDP.</p> <p>Currency of Payment; If the Contractor is registered and operating in Turkey, the payment shall be realized in Turkish Liras (TRY) through conversion of United States Dollar (USD) amount into Turkish Liras (TRY) by the UN operational rate of exchange valid on the date of money transfer. If the contractor is registered and operating in a country other than Turkey, payments shall be effected in United States Dollar.</p>
28		Eligibility	<p>The following parties ARE NOT ELIGIBLE to participate in this tender:</p> <ol style="list-style-type: none"> 1. The companies/persons who have been involved/participated in the feasibility plan/design/design drawings and/or development of Technical Requirements for this ITB, 2. JVs/Consortiums/Associations.
29		Site Visit	<p>Prospective bidders may visit sites, at their own cost, at any time before submitting their bids in case they deem site visit useful for the purpose of preparing their bids.</p>

			UNDP shall not be responsible for the Bidders' inability to perform a site visit in any case and hence the successful bidders shall not be eligible to any payment due to their failure to perform a site visit during contract performance.
30		Other Information	<p>Ownership:</p> <p>General Directorate of Forestry (GDF) will be responsible for determination of each household that the roof-top PV systems shall be installed, in each village.</p> <p>Successful bidders shall start implementation of the defined works after receiving "notification of commence" from UNDP. UNDP shall release "notification of commence" after receipt of relevant correspondence by GDF. UNDP is not responsible any sort of delays that may arise due to this correspondence.</p> <p>After transfer of ownership of the roof-top PV systems from UNDP to GDF, contractor shall be directly in contact with the GDF. UNDP will transfer the assets to GDF after substantial acceptance. GDF may decide to transfer the ownership to villagers afterwards. After the transfer of asset is realized, UNDP shall not be responsible for communication with regards to the transferred assets.</p>

Section 4. Evaluation Criteria

Preliminary Examination Criteria

Bids will be examined to determine whether they are complete and submitted in accordance with ITB requirements as per below criteria on a Yes/No basis:

- Appropriate signatures
- Power of Attorney
- Minimum Bid documents provided
- Bid Validity
- Bid Security (if required) submitted as per ITB requirements with compliant validity period

Minimum Eligibility and Qualification Criteria

Eligibility and Qualification will be evaluated on a Pass/Fail basis.

Subject	Criteria	Document Submission requirement
ELIGIBILITY		
Legal Status	Vendor is established as a single legally registered entity.	Form B: Bidder Information Form
Eligibility	Vendor is not suspended, nor debarred, nor otherwise identified as ineligible by any UN Organization or the World Bank Group or any other international Organization or Turkish Government in accordance with ITB clause 3.	Form A: Bid Submission Form
Conflict of Interest	No conflicts of interest in accordance with ITB clause 4.	Form A: Bid Submission Form
Bankruptcy	Has not declared bankruptcy, is not involved in bankruptcy or receivership proceedings, and there is no judgment or pending legal action against the vendor that could impair its operations in the foreseeable future.	Form A: Bid Submission Form
Certificates and Licenses	<ul style="list-style-type: none">▪ Duly authorized to act as Agent on behalf of the Manufacturer, or Power of Attorney, if bidder is not a manufacturer▪ Official appointment as local representative, if Bidder is submitting a Bid on behalf of an entity located outside the country▪ Patent Registration Certificates, if any of technologies submitted in the Bid is patented by the Bidder▪ Export/Import Licenses, if applicable	Form B: Bidder Information Form
QUALIFICATION		
History of Non-Performing	Non-performance of a contract did not occur as a result of contractor default for the last 3 years (reference period to be taken into account: from 10 March 2017 to 10 March 2020).	Form D: Qualification Form

Contracts¹		
Litigation History	No consistent history of court/arbitral award decisions against the Bidder for the last 3 years(reference period to be taken into account: from 10 March 2017 to 10 March 2020).	Form D: Qualification Form
Previous Experience	Minimum 3 years of relevant experience (reference period to be taken into account: from 10 March 2017 to 10 March 2020).	Form D: Qualification Form
	<p>The Bidder must have successfully completed, as the prime contractor, contract(s) for provision and installation of on-grid PV system (roof-top or land-based) which shall not be less than 200 kW AC on a cumulative basis regardless of number of contracts over the last five years (reference period to be taken into account: from 10 March 2015 to 10 March 2020).</p> <p><u>As proof document, the bidders shall submit original letters or their notarized versions, indicating 'Satisfactory Performance/Substantial or Final Acceptance issued by Electricity Utility Company' (the Letters shall indicate the initiation and end date for the previous experience, its budget information, installed power, location of the system explicitly).</u></p>	Form D: Qualification Form
Financial Standing	<p>Minimum average annual turnover of USD 500,000 for the last 3 years (2017, 2018, 2019).</p> <p><u>if audited financial statements are not available for year 2019 then financial statements of 2016, 2017 and 2018 may be provided.</u></p>	Form D: Qualification Form
Technical Evaluation	The technical bids shall be evaluated on a pass/fail basis for compliance or non-compliance with the technical specifications identified in the bid document.	Form E: Technical Bid Form
Financial Evaluation	<p>Detailed analysis of the price schedule based on requirements listed in Section 5 and quoted for by the bidders in Form F.</p> <p>Bidder's proposed delivery schedule is not later than the required delivery date.</p> <p>Price comparison shall be based on Total Fixed Price including all requirements indicated in Section 5.</p>	Form F: Price Schedule Form

¹ Non-performance, as decided by UNDP, shall include all contracts where (a) non-performance was not challenged by the contractor, including through referral to the dispute resolution mechanism under the respective contract, and (b) contracts that were so challenged but fully settled against the contractor. Non-performance shall not include contracts where Employers decision was overruled by the dispute resolution mechanism. Non-performance must be based on all information on fully settled disputes or litigation, i.e. dispute or litigation that has been resolved in accordance with the dispute resolution mechanism under the respective contract and where all appeal instances available to the Bidder have been exhausted.

Section 5a: Schedule of Requirements and Technical Specifications/Bill of Quantities

Bill of Quantities for the Supply, Installation and Commissioning of Solar Photovoltaic System and the required trainings are provided below. The details for the items to be supplied are elaborated in this section.

#	Items to be supplied Description/Specifications (Same requirement for all provinces)				
	Province	Sub-Province	Village	Capacity	Quantity
1	ADANA	Feke	Paşalı	1,2 kW AC	8 Units
2	ÇORUM	Osmancık	Gecek	1,2 kW AC	41 units
3	ANKARA	Kızılcahamam	Uğurlu	1,2 kW AC	8 Units
4	ARTVİN	Yusufeli	Çevreli	1,2 kW AC	8 Units
5	BİLECİK	Gölpazarı	Kavak	1,2 kW AC	8 Units
6	ÇANAKKALE	Yenice	Sazak	1,2 kW AC	8 Units
7	DENİZLİ	Pamukkale	Güzelpınar	1,2 kW AC	8 Units
8	ELAZIĞ	Merkez	Bağlarca Sarıgül	1,2 kW AC	25 units
9	ERZURUM	Tortum	Şenyurt	1,2 kW AC	8 Units
10	BURDUR	Merkez	Büğdüz	1,2 kW AC	8 Units
11	İZMİR	Kiraz	Çayağzı	1,2 kW AC	8 Units
12	MANISA	Sarıgöl	Alemşahlı Kızılçukur Karacaali	1,2 kW AC	5 units
				2,0 kW AC	12 units
				2,8 kW AC	11 units
				3,2 kW AC	2 units
16	KASTAMONU	Tosya	Çaykapı	1,2 kW AC	8 Units
17	YOZGAT	Akdağmadeni	Yukarıçulhalı	1,2 kW AC	18 Units
		Çekerek	Bayındırhüyük		
18	KARAMAN	Merkez	Gökçe	1,2 kW AC	7 Units
19	KAHRAMAN MARAŞ	Onikişubat	Sarıçukur	1,2 kW AC	8 Units
20	ŞANLIURFA	Bozova	Arıkök	1,2 kW AC	8 Units
21	TRABZON	Maçka	Ardıçyayla	1,2 kW AC	8 Units
Overall Amount					225 units

1. INTRODUCTION

These technical specifications apply to supply, installation and commissioning of on-grid Roof Top photovoltaic (PV) Systems to be installed in four forest villages to be specified by the Contracting Authority in Adana, Çorum, Ankara, Artvin, Bilecik, Çanakkale, Denizli, Elazığ, Erzurum, Burdur, İzmir, Manisa, Kastamonu, Yozgat, Karaman, Kahramanmaraş, Şanlıurfa and Trabzon after conclusion of the Contract with the successful bidder. PVs will be installed on roof tops of the selected village houses as per the technical specifications.

These technical specifications cover the connection authorization in accordance with the Electricity Market Law and applicable legislation to be issued by the relevant power distribution company (EDAS) for various capacity PV plants such as, 1,20 kWe AC (1,3 kWp DC), 2,00 kWe AC (2,40 kWp DC), 2,80 kWe AC (3,40 kWp DC) and 3,20 kWe AC (3,60 kWp DC) PV Plant to be installed for an on behalf of the Households that

are residing in above mentioned Forest Villages under the UNDP/GEF Project “Sustainable Energy Financing Mechanism for PV Systems in Forest Villages in Turkey” jointly implemented by the General Directorate of Forestry (GDF) and United Nations Development Programme (UNDP) in line with the Regulation on Unlicensed Electricity Generation in the Electricity Market published in the Official Gazette no. 28783 of 12.05.2019; technical specifications for rooftop PV systems in line with the applicable regulations and standards as well as conditions for supply, installation, grid synchronization, commissioning, operation, of these equipment, technical support services after installation and other relevant requirements. These technical specifications cover not only installation of PV panels and associated systems but also all additional accessories and equipment required for these systems.

Roles and Responsibilities:

The Contract(s) that will be awarded as a result of this ITB will be made between the successful Bidder (as the Contractor) and UNDP Turkey Office (as the Contracting Authority). Ministry of Forestry and Water Affairs, Directorate General of Forestry is the Implementing Partner of this project.

The pilot Solar PVs will be established in forest for selected Households. Hence, the ultimate Beneficiary is the Household that is planned to hold the ownership after the substantial acceptance of the Solar PVs takes place. Totally, there will be 225 Households that would be owning the roof-top PV Systems.

Work Flow:

The area where the PV System is to be installed, is the rooftop of the Forest Village Household which is structurally available for PV System installation. Implementing Partner had notified UNDP about the selected households in the forest villages. Contractor is expected to apply to the local electricity distribution company for the issuance of the letter of invitation to grid connection agreement on behalf of the selected household based on the templates (type design, forms, etc) issued by TEDAS. Contractor is responsible for the preparation of all documentation that is necessary for the application. Upon approval of the project documentation by local electricity distribution company and/or TEDAS, Contractor is expected to start mobilization and execution of the works, thereafter.

After the evaluation of bids, the successful bidder shall submit the Performance Security (Item 41 of Bid Data Sheet), the contract(s) are to be awarded by UNDP.

The Contractor will initiate and complete the stated works stipulated in this ITB. If necessary, UNDP may appoint firm(s)/organization(s)/person(s) to monitor the compliance of health and safety measures, installation, testing and commissioning of the PV systems during the execution of works. After all deliverables listed in Bid Data Sheet Item 25 are completed including the training of persons to be designated by UNDP in cooperation with DG for Forestry and the households, substantial acceptance of Solar PVs will be made by UNDP. At this stage, the payment will be made to the Contractor as per Payment Conditions Item 9 of Bid Data Sheet and UNDP will transfer assets and ownership to the Implementing Partner. The Implementing Partner may transfer the assets and ownership to the villagers (households). This will be decided later during the implementation of the contract.

Contractor is expected to complete stated works within as per Bid Data Sheet Item 25. The performance security will only be released as per Bid Data Sheet Item 9.

1.1. DEFINITIONS

Contracting Authority	: United Nations Development Programme (UNDP)
Plant	: PV Plants in the Forest Vilages described under 1.1 above
Contractor	: The real or legal person who signed the contract and undertook performance of the work hereunder for the contract.

1.2. SYMBOLS AND ABBREVIATIONS

Symbol**Description**

m ²	: square meter
kW _p	: Kilowatt peak
kVA	: Kilovolt amper
W	: Watt
W _p	: Watt peak (maximum peak power)
°C	: Degrees Celcius
%	: Percent
V	: Volt
A	: Amper
N	: Newton
mm ²	: squared millimeter
km	: Kilometer
m	: Meter
cm	: Centimeter
Hz	: Hertz
KWe	: kilo Watt equivalent
Pa	: Pascal
AM	: Amplitude Modulation
kV	: kilo Volt
kA	: kilo Ampere

Abbreviation **Description**

CCTV	: Closed Circuit Television
PV	: Photovoltaic
LV	: Low Voltage
MV	: Medium Voltage
HV	: High Voltage
TMS	: Thermal Magnetic Switch
IEEE	: Institute of Electrical and Electronic Engineers
TTGV	: Technology Developmen Foundation of Turkey
PJIO	: AC Panel for Joining Inverter Outputs
CCB	: Compact Circuit Breaker
MoENR	: Ministry of Energy and Natural Resources

TEDAŞ	: Turkish Electricity Distribution Company
EPDK	: Energy market Regulatory Authority
TMMOB	: Union of Chambers of Turkish Engineers and Architects
DC	: Direct Current
AC	: Alternative Current
TSE	: Turkish Standards Institute
MPPT	: Maximum Power Point Tracker
GCPVS	: Grid Connected PV System
THD	: Total Harmonic Distortion
Contractor	: Company which shall execute the work in accordance with the technical specifications and TEDAS rules and regulations

2. APPLICABLE LEGISLATION

The contents of the bid and associated designs will be produced in accordance with the following legislation.

2.1 Electricity Market Law no. 6446,

2.2. Regulation on Unlicensed Electricity Generation in Electricity Market,

2.3 Applicable standards: TS/ISO/CENELEC/IEC and other national and international standards as well as national standards corresponding transposing international standards relating to equipment, connection systems to be used in and performance criteria for the power generation plants,

2.4 Other applicable technical legislation: The latest versions of all applicable regulations and communiqués adopted by the MoENR and other line ministries and governmental authorities laying down all requirements and standards for safe and stable operation of electricity generation, transmission and distribution plants including the Consumer Protection Law - No: 6502, Regulation on Indoors Electrical Installations OG no. 25494 of 16.06.2004; Regulation on Grounding of Electrical Installations OG no. 24500 of 21.08.2001; Regulation on High Voltage Electrical Installations OG no. 24246 of 30.11.2000; Regulation on Design of Electrical Installations OG no. 27434 of 16.12.2009 and Communiqué implementing the Regulation on Unlicensed Electricity Generation in Electricity Market OG no. 28783 of 02.10.2013 and other legislation directly or indirectly applicable to this type of installations.

2.5 The contents of the bid and design will comply with all regulations as well as with any future amendments thereto and new regulations to be adopted in the future not mentioned herein but applicable to the work hereunder. All additional costs that may arise out of amendments to applicable legislation will be borne by the Contractor.

3. GENERAL REQUIEREMENTS

3.1 The Contractor shall install an on-grid PV System at the specified location and using PV panels meeting the specified requirements, and the DC power generated by the PV panels shall be converted into AC by the inverters and connected to the main distribution bar without storage.

3.2 The duration of work is indicated in Item 20 of the Bid Data Sheet.

3.3. The Contractor shall have service qualification certificates for the systems to be installed (sales, service or installation authorization certificates issued by the manufacturers or wholesalers of PV panels and inverters offered).

3.4 The Contractor shall submit a detailed workplan within 10 (ten) days following approval of the work plan by the Contracting Authority after contract signature. The workplan shall include the brands and models as well as data sheets of all equipment and materials to be used within the system, in alignment with its Bid and submit

the Contracting Authority's approval. No materials or equipment which are not approved by the Contracting Authority shall be used in the system.

3.5 The Contractor shall install grid connection of the PV plant in accordance with the "Regulation on Unlicensed Electricity Generation in Electricity Market", "Principles and Procedures for Grid Connection" adopted under that Regulation as well as all other applicable regulations, decrees and practical guidelines. The Contractor shall fully comply with the decisions, connection agreements and working procedures of governmental authorities (TEDAŞ, etc.) in all works and actions. The Contractor shall install and complete the PV plant fully in accordance with the project approved by TEDAŞ.

3.6 All the criteria to be required by TEDAŞ (e.g. compliance with distribution company's needs, protection, control, grounding, etc.) shall be met by the Contractor at the point of connection of the PV System to the grid. The PV System to be installed must comply with the system design and installation standards of IEEE for on-grid PV plants.

3.7 The PV panels, inverters, PV panel stands (supporting structures for PV modules), data recording and displaying devices and other systems and equipment to be used in the plant shall be in compliance with at least one of IEC, VDE, EN, DIN standards.

3.8 The power measurement and remote monitoring of each panel group shall be performed individually, and generation records shall be kept.

3.9 The technical documentation listed below shall be submitted to the Contracting Authority within 10 days following approval by the Contracting Authority of detailed workplan describing the periods for planning, manufacturing, delivery, installation and commissioning, and the Contracting Authority may require other documentation during performance of the work. In case the Contracting Authority requires modifications in the designs to be submitted by the Contractor, the Contractor will be obliged to submit the revised documentation to the Contracting Authority within latest 5 (five) days at no additional cost to the Contracting Authority;

Technical catalogues pertaining to the equipment to be used in the system,

- Guarantee/warranty and standard certificates (as per Article 3.14 of Section 5.a.) for the equipment to be used in the system,

Certificates of authorization for sales, service or installation of PV panels and inverters to be used in the system issued by their manufacturers or distributors,

- Detailed scheme and descriptions of remote monitoring, measurement and data storage systems,

3.10 The technical specifications for the PV panels and other equipment should be available on the original prospectuses, flyers and website of the manufacturer for double checking and confirmation. The equipment shall be suitable for uninterrupted operation for 24 hours a day and 365 days a year.

3.11 The Contractor shall perform the grid connection in accordance with the Regulation on Unlicensed Electricity Generation in Electricity Market and the Procedures and Principles for Grid Connection published thereunder.

3.12 The Contractor shall assign the following staff during installation of the PV plant:

Electrical and Electronics Engineer/Electrical Engineer/Electronics Engineer/ Mechanical Engineer or equivalent, having a work experience of at least 2 years in the field of PV installations

3.13 All items and power cables to be used in the installation shall be in compliance with TSE, IEC standards and ISO 9000. In case of items for which there is no TSE standard, TSEK certificate shall be required. The priority of standards for any issues not mentioned herein shall be as TSE, IEC and ISO.

3.14 A two-year guarantee shall be provided for the goods in PV plant as a whole system including all equipment in the system following acceptance by TEDAŞ, and the plant shall be taken over in operating condition. The Defects Liability Period will be 12 months as per Article 47 of General Conditions of Contract for Civil Works.

3.15 The Contractor shall be directly responsible for achieving of grid connection and achievement of 80% ($\pm 2\%$) of electricity generation, and in case of non-achievement of the required amount of electricity generation, the Contractor shall provide necessary corrections / improvements within a maximum of 30 days, at no cost during the guarantee period.

3.16 Ownership of the PV Systems shall be transferred to DG for Forestry (OGM). The Contractor shall provide training for the selected households that the system will be transferred to on operation and maintenance of the PV plant before Substantial Acceptance.

3.17 The Contractor shall deliver the manual required for smooth operation of the PV plant upon completion of the installation work.

3.18 Any and all primary and auxiliary equipment as well as works not mentioned in these technical specifications and annexes thereto but required for the technique of the work and functional operation of the system and to ensure a sound and problem free operation shall be considered for the benefit of the Contracting Authority and performed within the scope of work at no additional cost to the Contracting Authority.

3.19 The project information sign-board, the wired fences for the area to control penetration, warning signs, “danger of death” plates and operating instructions to be provided on the panels, metallic constructions and main components shall be properly prepared and installed by the Contractor.

3.20 The Contractor is responsible for issuing an insurance (15% of the total estimated price of the Contract) for all liabilities for damage to life including electricity shocks (for any unauthorized penetration, fires that would be caused by the system, etc.), lives and occupational health of its staff (including social security) and for the amount of electricity that should be secured in line with General Conditions of Contract for Civil Works Item 21, 22 and 23.

3.21 The Contractor shall be responsible for the tests, inspections and acceptance procedures to be carried out by the Acceptance Committee (substantial acceptance by the Contracting Authority will be done after the system is installed, operates and approved by the local electricity distribution company) to connect the PV plant to the grid and start energy exchange. Electrical and Electronics Engineer/Electrical Engineer/Electronics Engineer/Mechanical Engineer or equivalent representing the Contractor and “Engineer” representing the Contracting Authority will attend these procedures pursuant to the Regulation on Acceptance of Electrical Installations. The substantial acceptance of transformers and cells shall be carried out by the Contracting Authority under the responsibility of the Contractor. Any deficiencies and/or wrong practices to be identified at the time of substantial or final acceptance/completion shall be eliminated by the Contractor fully in accordance with the project at no cost to the Contracting Authority, within maximum 30 days.

3.22 The invoice to be prepared by the Contractor will be processed following the preparation of the substantial acceptance which shall be approved by UNDP as per Article 44 of Bid Data Sheet.

3.23 The final acceptance/completion will be done after the end of defects liability period, in other words 12 months after the substantial acceptance, if technical requirements of this ITB are satisfactorily completed by the Contractor.

3.24 All material wastes and residuals shall be regularly cleaned from the site during installation work, and the Contractor shall provide associated staff for this purpose.

3.25 The Contractor is obliged to take necessary measures for the safety of the employees at the site and ensure that all staff have social security and insurance for occupational health, as per local regulations. The Contractor shall be responsible for any accidents that might occur. All descriptive and occupational safety related plates shall be provided at necessary locations in a visible manner. The Contractor shall take all cleaning, fire safety and occupational safety measures at the site during transport, installation, welding and cutting works. The apparatus like scaffolds, ladders and handrails shall be made available where required for safe operation the equipment.

3.26 All components to be used in the system shall be brand new and state-of-the-art models. The design, materials and workmanship shall not be below the quality and standards established by advanced engineering and manufacturing practices.

3.27 The equipment and materials shall be carefully carried, properly stored and protected to avoid damages before and during installation in line with the manufacturer's recommendations and approval of the Contracting Authority (the Contractor shall be responsible for any and all damages during transport, storage and before and after installation up to Substantial Acceptance by the Contracting Authority). Damaged or defective parts and components shall be replaced by new ones. The Contractor shall be responsible for leaving the site suitable for operating condition upon completion of construction works.

3.28 The Contractor shall be responsible for any and all damages which may occur to the plant and environment during installation and the Contractor is obliged to indemnify any sort of damage which may occur.

3.29 The contractor shall be responsible for providing all utilities including electricity, water, gas, fuel, etc and consumables that may be required during installation of the PV Plant at its own cost.

4. TECHNICAL REQUIREMENTS

A. SCOPE

These specifications cover the general technical specifications, conditions of supply, erection & installation and all installation of systems associated with photovoltaic panels as well as receiving invitation to grid connection agreement and authorizations, additional equipment, synchronization of the system with the network, commissioning and operation of the system, technical support services following the installation, requirements for training; and execution, on a turn-key-delivery basis, of the building, construction and revision works necessary for the completion of the work as a whole; the installation, assembly, commissioning, Substantial Acceptance as indicated in the designs approved by TEDAS or Electricity Distribution Company; and other relevant matters of the "Grid Connected PV System" (henceforth "GCPVS (SEBGES)") with photovoltaic (henceforth "PV") module capacity to be installed on rooftops of designated houses with indicated AC installed powers.

B. GENERAL PRINCIPLES

B1. TECHNICAL DOCUMENTS TO SUBMIT TO THE ADMINISTRATION

The following technical documents shall be submitted to the Administration along with the work schedule before starting the manufacturing; and the Administration shall have the right to request any other documents as deemed necessary during the execution of the work. Where the Administration requests changes to the design drawings submitted by the Contractor, the Contractor shall be obliged to submit the necessary documentation within at most 10 days to the Administration with no charge.

- i. Technical catalogues of the equipment to be used in the system,
- ii. Warranty and standard certificates for the equipment to be used in the system,
- iii. Detailed work schedule indicating the times for planning, production, delivery, assembly and commissioning.

The Contractor shall start the construction work after the documents above are approved by the Administration, and strictly comply with the information during the construction. Where it is necessary to make changes, such changes may only be made by the written approval of the Administration.

B2. COMPLIANCE WITH STANDARDS

The products shall comply with the criteria laid down in the relevant Turkish standards and/or applicable European Union standards; and the proof of such compliance shall be submitted to the Administration. All materials shall be supplied in compliance with the specifications indicated in the specifications and annexes and appropriate ones of Turkish standards. Materials for which there is no Turkish standard shall comply with at least one international standards.

Relevant standards:

TS STANDARD NO	IEC, EN, HD, ISO STANDAD NO	TITLE OF STANDARD
TS HD 60364	IEC 60364 (all parts)	Low-voltage electrical installations
	IEC 60364-6	Low-voltage electrical installations – Part 6: Verification
	IEC 60364-7-712	Low-voltage electrical installations – Part 7-712: Requirements for special installations or locations - Solar photovoltaic (PV) power supply systems
TS IEC 60755	IEC 60755	General safety requirements for residual current operated protective devices
TS EN 61557	IEC 61557 (all parts)	Electrical safety in low voltage distribution systems up to 1000 V a.c. and 1500 V d.c. - Equipment for testing, measuring or monitoring of protective measures
TS EN 61730	IEC 61730 (all parts)	Photovoltaic (PV) module safety qualification
TS EN 50438	IEC 50438	Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks
TSE K 191		Requirements for generating plants with phase current higher than 16 A to be connected with public low-voltage distribution networks
TSE K 192		Requirements for generating plants with phase current higher than 16 A to be connected with public medium-voltage distribution networks
TSE EN 62446	IEC 62446	Grid connected Photovoltaic (PV) systems – Minimum requirements for documentation, commissioning tests and inspection
TSE EN 5021	IEC 50521	Connectors for photovoltaic systems - Safety requirements and tests
TSE EN 62305	IEC 62305	Protection against lightning
TS CLC/TS 50539-12		Low-voltage surge protective devices - Surge protective devices for specific application including d.c. - Part 12: Selection and application principles - SPDs connected to photovoltaic installations.
	IEC 62548	Photovoltaic (PV) arrays - Design requirements
	IEC 62109-1	Safety of power converters for use in photovoltaic power systems – Part 1: General requirements
	IEC 62109-2	Safety of power converters for use in photovoltaic power systems - Part 2: Particular requirements for inverters
	IEC 62116	Utility-interconnected photovoltaic inverters - Test procedure of islanding prevention measures

	IEC 61727	Photovoltaic (PV) systems - Characteristics of the utility interface
--	-----------	--

B3. COMPLIANCE WITH LEGISLATION

The Contractor shall execute the work in compliance with all pertaining local laws, bylaws and regulations relating to the construction, testing and operation of the plant including particularly those relating to preventing environmental pollution and protecting public health. On matters not regulated in any manner, the Contractor shall work or act in accordance with the applicable procedures and rules. The Contractor shall examine the compliance of matters indicated in design drawings and technical specifications with laws, bylaws, regulations, mandatory standards or local requirements, procedures and rules. If there is anything that does not comply, the Contractor shall alert the Administration in writing. If at the end of the work, there arises a noncompliance for which the Contractor has failed to alert, no payment shall be made to the Contractor to remedy such matter.

The relevant legislation (including but not limited to):

1. EMRA Decision of 28.12.2017
2. Communiqué of 15.05.2017 on Implementation of Regulation on Unlicensed Electricity Generation in the Electricity Market
3. Regulation of 15.05.2017 on Unlicensed Electricity Generation in the Electricity Market
4. Regulation of 25.01.2019 on Design of Electrical Facilities
5. Decision of 30.04.2018
6. Type Design Project for Rooftop and Front Installed PV Plant of 10kW or less published in 2018 and Annexes

If necessary, UNDP may appoint firm(s)/organization(s)/person(s) to monitor the compliance of health and safety measures, installation, testing and commissioning of the PV systems during the execution of works.

B4. RECEIVING INVITATION TO GRID CONNECTION LETTERS

The Contractor shall be obliged to receive Invitation to Grid Connection Letters from the designated households. It shall procure from the household owners the application documents as required by the Electricity Distribution Company.

B5. DESIGNS

As designs, design drawings, principle diagrams, technical specifications and manufacturing specifications are complementary to one another, all devices and equipment indicated here shall be supplied and the systems shall be completed in accordance with the art. No changes may be made to the design drawings without written approval of the Administration; and the type details shall be adhered to in implementation.

B6. SITE VISIT

The Contractor shall have the responsibility to visit and study the site and environs and obtain all potentially necessary information. Upon visiting the site of work and environs, the Contractor shall be deemed to have been informed, in terms of cost and time, on the layout and nature of the site, climatic conditions, quantity and type of works and materials needed to execute the work, and matters of access to the site and build site works. Accordingly, the Contractor shall be deemed to have

obtained all information relating to the cost, risks that may affect its profits, contingencies and other similar matters.

B7. DESIGN APPROVAL

The Contractor shall be obliged to supply the authorization and documents required for the approval of designs and design drawings by TEDAS. It shall be obliged to have TEDAS approve the design drawings, following the notification and approval by the Administration of the materials to be used in the project, considering the Administration's interests in priority. During the design approval process, the Contractor shall not demand any additional payment including fees from the Administration.

B8. PRODUCTS TO BE USED

All devices used in the system shall be state-of-the-art, unused and new (produced within at most in 1 year period); each product shall have an original label affixed that contains the brand, model, date of manufacture etc. information. The devices shall be capable of operating around-the-clock all year; and their connection plugs and sockets shall comply with national standards.

B9. DELIVERY OF DEVICES/MANUFACTURED ITEMS

The price for each of the work items whose capacities, measures and counts are indicated in the design drawings shall include the supply of the work item at the work site; making the connections, as may be necessary, of pipes, ducts, cabling, electrical wiring, automatic control and automation etc. and integration into the existing system; potentially necessary assembly materials (fittings, red lead and/or oil paint, insulation, suspension and anchorage materials, seismic equipment, clamps, base construction, suspending, welding etc.), testing, workmanship, ground excavation, transport, vertical and horizontal handling, tools and instruments, contractor's profits and general costs. It shall also include the costs of all potentially necessary testing or commissioning of testing, preparation or commissioning of reports and designs and approvals etc. In other words, the work items shall be executed and delivered in operational condition in accordance with the relevant regulations, standards, designs, manufacturing specifications and specifications.

B10. TRANSPORT AND STORAGE

The equipment and materials shall be carefully transported, appropriately stored, and protected to prevent harm before and during assembly in accordance with the manufacturer's recommendations and Administration's approval. Harmed or out-of-order pieces shall be replaced.

B11. MANUFACTURER'S RECOMMENDATIONS

Where it is required that assembly works or the materials being assembled comply with the manufacturer's recommendations, such recommendations shall be submitted in print to the Administration prior to assembly. The assembly of materials shall not be allowed before the submission and approval of recommendations. Failure to submit the recommendations may lead to rejection of the materials. Where any part of the work needs to be executed outside the work site, the Contractor shall inform the Administration what works shall be executed when and where, and allow checking.

B12. OCCUPATIONAL SAFETY AND MEASURES

The Contractor shall take all measures for cleanliness, fire and occupational safety during transport, assembly, welding and cutting tasks. Such pieces as scaffolds, ladders and fences shall be made

available for safe operation and maintenance. UNDP may appoint firm(s)/organization(s)/person(s) to monitor the compliance of health and safety measures, in accordance to Turkish Laws and Legislations.

B13. BUILDING PROTECTION

Care shall be taken to prevent damage to buildings during assembly/disassembly works; and any damage shall be covered by the Contractor. In case of deviation from the static design, the building structural elements shall not be touched without written approval of the Administration. Defects inevitably inflicted on walls, floors etc. shall be rehabilitated by Contractor with no charge. Particularly, as the panels are to be integrated to the roofs where the facility is to be installed, the water insulations shall be made with extreme care, and no water insulation problem shall occur in the buildings. Any damage shall be remedied by the Contractor with materials and techniques as designated by the Administration. The Contractor shall not attempt any hole enlargement or drilling new holes on its own (i.e. without approval of the Administration); if it does so, it shall be liable for all potential damages.

B14. INSTRUCTION PLATES

Plates which include instructions for operating and stopping the devices, and other warnings, signs and information as prescribed by the relevant legislation shall be placed on or near the devices.

B15. PRODUCTS AND EQUIPMENT TO BE USED

All the capacities, types and characteristics of equipment pieces are generally provided in the design drawings or Technical Specifications and annexes. The capacities so furnished are minimum. Changes in characteristics shall be allowed only upon written approval of the Administration. All same-type items shall be from the same manufacturer. If assembly instructions are not in the specifications or plans, the manufacturer's instructions shall be followed.

B16. DOCUMENTS TO SUBMIT FOR APPROVAL

Shop drawings, manufacturer's data, documents relating to equipment and all materials, and the details for every system indicated in separate parts shall be submitted for approval; and the approval of the Administration shall be obtained before supply, manufacture or delivery to the work site. Documents partially submitted for approval shall not be admitted, and returned without examination. The documents submitted for approval shall include the manufacturer's name and commercial title, catalogue model or number, label data, dimensions, layout measures, capacity, design specifications and reference paragraphs, relevant Turkish standards, references to industrial and technical association publications, and all information demonstrating that each piece to be supplied by the Contractor complies with the contract.

iv. Manufacturer's data

The documents of each produce piece submitted for approval shall include the information, equipment drawings and diagrams, performance and characteristic curves relating to the manufacturer's catalogued products.

B17. WATER INSULATION/GAP CLOSURES AT ROOFTOP INSTALLATIONS

For roof-integrated PV plants, the roof tiles shall be removed where the panel carrying supports shall stand. The roof tiles shall remain intact where no carrying support stands. Care shall be taken to ensure water insulation; and water insulation tests must be conducted before commissioning. There shall be no leaks. If insulation is failing, necessary remedial work shall be undertaken, and tests re-

conducted until full tightness is ensured. Holes, slots etc. apertures opened temporarily in the outer walls, roofs as necessitated by the work shall be re-closed in the best manner, and fully water-tight. Where necessary measures are taken against such contingencies as rain showers or floods etc., this matter may be left without requirements, still with the responsibility on the Contractor at sections where work is done. At the end of work however, the apertures for which the Contractor is responsible shall be made permanently water-tight. Temporary apertures on roofs, walls and floors for the construction and assembly of pipes or ducts shall be closed, following the completion of the work, with fire-resistant materials if there is fire partitioning, or otherwise, with materials appropriate for the structure.

B18. TESTS FOR PREPARATION FOR SUBSTANTIAL ACCEPTANCE

All devices, materials and workforce shall be supplied by the Contractor as necessary for the tests prior to connection to the grid. The Contractor shall first notify in writing the Administration that the plant is ready for tests; then the Administration shall designate the date of test and who shall be present. Tests shall be conducted in the presence of technical staff authorized by the Administration; and the results be submitted as a report to the Administration. All defects identified in the tests shall be immediately repaired or parts replaced, and the test shall be repeated until the inspection team grants acceptance. If any damage occurs during the test, it shall be immediately repaired; damaged piece or device shall be replaced by a new one; and it shall be made such that the inspection team approves it. Function tests shall indicate the approximate performance of the system as a whole. Where any material or equipment fails such tests, they shall be replaced and the test repeated to achieve the required performance. Following the device tests, the entire system shall be subjected to operating tests to see the system in operation. Once the tests are successful, the procedures for commissioning and Substantial Acceptance shall commence.

If necessary, UNDP may appoint firm(s)/organization(s)/person(s) to monitor testing and commissioning of the PV systems.

B19. TRAINING

The Contractor shall introduce the PV System and provide information on the operation, maintenance and repair to a user designated by the Administration. No money under whatsoever name shall be paid to the Contractor for this.

B20. SHUTTING DOWN OR STOPPING THE SYSTEMS IN OPERATION

The Contractor shall supply uninterrupted electricity to the buildings in use as it is, and take necessary measures for this. Where, during the execution of the work, the system needs to be stopped for partial installation of a system or connecting another operating system, such action shall be executed at a time window designated by the Administration provided that the Administration be informed in advance and the duration of stopped indicated.

B21. CLEANING AND SETTINGS

All devices shall be cleaned before hand over to the Administration. If painted, coated or finished surfaces are damaged, they shall be restored and all equipment shall be in condition for acceptance. The systems shall be delivered to the Administration in a condition with all settings made and capable of performing all functions as indicated in the specifications.

B22. MAINTENANCE AND CLEANING OF SYSTEMS AND DEVICES PRIOR TO ACCEPTANCE

The Contractor shall be obliged to maintain all installed materials and devices until acceptance. All

materials and devices shall be preserved at the assembled locations with protective maintenance performed until the completion of transport, storage, assembly and work. Following the completion of the assembly of all systems, the Contractor shall operate the system for a duration sufficient to execute all tests, settings, balancing to ensure that system operating conditions are fully achieved as indicated in the specifications and design drawings; and if necessary in the meantime, it shall work with the assembly teams or manufacturer's representatives or both to achieve the desired outcome for the plant.

C. DESCRIPTION OF THE WORK

C1. The Contractor shall implement a GCPVS having varying powers (mentioned in BoQ) of photovoltaic systems in accordance with the approved design drawings. The solar power produced shall be connected according to the approved design drawing of the PV plant transformer. The system shall operate ON-GRID with both the grid and GCPVS simultaneously in operation.

C2. On the areas where PV panels are located, the roof tiles shall be removed where the panel carrying supports shall stand; water insulation shall be provided and panel connections made. The Contractor shall be responsible for ensuring necessary water insulation, taking and implementing measures, and may not demand additional payment.

C3. The Contractor shall, in the context of this work, be responsible for the system as a whole including the grounding of the system of the installed power at the **foundation as indicated in the approved design project, implementation of the** steel construction, installing panels and commissioning the system, at no additional charge.

C4. The electrical power generated by GCPVS shall first be used to meet the needs of the household, and the power needs not supplied by GCPVS shall be supplied from the existing grid. The electrical power generated by GCPVS but not consumed in the buildings shall be fed to the distribution grid; and the exchange between the grid and the building shall be recorded by a two-way power meter, **consist of automatic remote reading system in accordance with the Local Electric Utility Company/ TEDAŞ requirements**, to be installed in the context of this work.

C5. The Contractor shall execute the panel installation, assembly, commissioning and Substantial Acceptance according to the approved design drawings of the PV plant. Any work such as excavation, construction, revision, remedying, demolition, punching etc. that may arise during this work item shall be executed by the Contractor with no additional charge.

C6. The Contractor shall be directly responsible for failure to make the grid connection due to faulty design and installation and generate the envisaged quantity of electrical power, and provide all necessary improvement/remedies within 20 calendar days at no charge.

C7. The Contractor shall execute the cabling, connection, material supply and workmanship between the grid and the area where the PV plant shall be installed. Any work such as excavation, construction, revision, remedying, demolition, punching etc. that may arise during this work item as well as necessary repair work shall be executed by the Contractor with no additional charge. The Contractor

shall be deemed to have visited the work site and been informed of the potentially necessary renovation.

C8. The Contractor shall execute the grounding, material supply and workmanship for the PV plant. In this context, the existing grounding systems of the buildings shall be examined, necessary measurements and reports made, and such works as excavation, construction, revision, remedying etc. shall be executed by the Contractor with no additional charge. The Contractor shall be deemed to have been informed of the existing grounding during the site visit.

C9. The Contractor shall make the grid connection in accordance with the Regulation on Unlicensed Electricity Generation in the Electricity Market, Communiqué on Implementation of Re Regulation on Unlicensed Electricity Generation in the Electricity Market, other regulations and annexes.

C10. Materials to be used in the installation, control and power cables shall comply with TSE, IEC standards and ISO 9000 series, and have CE certification. For materials for which no TSE standards exist, TSEK certification shall be required. For matters not indicated in the specifications, TSE, IEC and ISO norms shall apply in the priority order.

C11. GCPVS as a whole and all equipment pieces in the system shall be under warranty for the specified durations; and the plant shall be delivered in operating condition.

C12. The manufacturing quality certificates for the connection components to be supplied for the plant shall be checked by the Administration prior to the start of manufacturing, and then received in delivery.

C13. The duration of work is 120 (one hundred and twenty) calendar days from the date of site delivery.

C14. The Contractor shall provide GCPVS training to the users designated by the Administration following the Substantial Acceptance.

C15. The Contractor shall deliver the necessary documentation for sound operation of GCPVS to the Administration following the work completion.

D. TECHNICAL SPECIFICATIONS

D1. GCPVS general requirements

D1.1 All equipment to be used in the system shall be brand new and unused and affixed with the brand, model, date of manufacture.

D1.2 The PV panels shall be installed on rooftop surfaces indicated in the layout plan in the design drawings which the Contractor shall procure approval (it shall procure approval after obtaining the approval of the Administration).

D1.3 The areas where inverters can be installed shall be included in the buildings and designated by the Administration. The inverters shall be installed considering the necessary technical calculations by the Contractor, and selecting appropriate technical volumes and after obtaining the approval of the Contractor.

D1.4 The electrical power generated by GCPVS shall first be used to meet the loads in the building, and the electrical power needed for the loads and not supplied by the PV panels shall be supplied from the existing grid. The electrical power generated by GCPVS but not consumed in the buildings shall be fed to the distribution grid. The exchange between the grid and the building shall be recorded by a two-way power meter to be installed within the system.

D1.5 The PV System design shall be prepared and approved in a way that the panel layout and sun angles of the PV System shall allow maximum power generation during the year.

D1.6 GCPVS shall be connected and integrated to the grid in accordance with the approved design drawings. The system shall operate ON-GRID with both the grid and GCPVS simultaneously in operation.

D2. PV panels

D2.1 GCPVS shall be designed such that all the PV panels in the system shall have the capacity to generate 270 (one hundred and fifty) W \pm 5% instant power under the radiation of 1000 (thousand) W/m², air mass (AM) of 1.5, cell temperature of 25°C at standard testing conditions.

D2.2 The electric power to be generated by the on-grid PV plant shall be fed to the power distribution grid as per the approved design drawings (In line with the Invitation to Grid Connection Letter) by TEDAS and local electrical distribution company.

D2.3 The PV panels shall be of the same type and model in themselves respectively for the compatibility the period between the date of manufacture of the PV panels and the date of installation of the PV plant shall not be longer than 12 months. Panels of different type and power shall not be used in the same system.

D2.4 The PV panels shall be in the number, power and structure as specified in the Project. The efficiency of the PV panels shall be the same as specified in the Project (at least 95%).

D2.5 The frames of PV panels shall be pressed and punched. The drain holes and assembly holes must be provided on the frame. Bolt-mounted frames on the PV panels are not acceptable. The frame of the PV panels shall be made of corrosion resistant material and it must be stainless (anodised aluminium is preferable). The frame shall be designed so that assembly can be performed without any drilling.

D2.6 The glass/plastic material covering the PV panels shall not reflect the sunlight. The glass shall be tempered glass in accordance with EN 12150 and transparent by at least 92%. The thickness of the glass shall be at least 3.2 mm. The strength of the glass shall be at least 90 N/mm² when calculated in accordance with EN 12150.

D2.7 The PV panels shall be under warranty for 2 years, which means that any failure or breakdown shall be repaired by the Contractor at no additional cost and under a warranty for at least 10 years where the Contractor shall continue to provide spare parts and technical support/workmanship at a cost. The Contractor shall provide the statement of the panel manufacturer indicating the guarantee/warranty period,

which is notary public approved for local manufacturers or consulate approval for international manufacturers.

D2.8 Apart from all insurances detailed in the General Conditions of Contract for Civil Works, the linear energy shall be guaranteed for at least 25 years through Comprehensive Machinery Insurance (CMI). The Contractor is responsible for issuing this insurance throughout the contract duration and for 2 years after handing over the PV Plant. Then, the local government, non-governmental organization or persons to whom the plant is transferred shall be responsible for issuing this insurance. The linear energy guarantee shall ensure at least 90% of the original panel power after 10 years and at least 80% of the original panel power after 25 years.

D2.9 The PV panels and connectors shall be resistant to a wind velocity of 130 kmh.

D2.10 The protection class of the connection boxes of the PV panels shall be IP 67.

D2.11 The PV panels shall have the certificate of compliance with IEC 61215, IEC 61730-1 and IEC 61730-2.

D2.12 The PV panels shall withstand a wind load of at least 2400 Pa and a snow load of at least 5400 Pa (IEC 61215).

D2.13 The direct current output cables of the PV panels and the (+) and (-) poles of the connectors shall be distinguishable.

D2.14 The cells used in the PV panels shall be of first quality Ethylene Vinyl Acetate (EVA) with both sides laminated.

D2.15 The PV panels shall operate smoothly under the following conditions:

- Temperature range of -40°C / +80 °C,
- Elevation range of 0 - 1300 m,
- Relative humidity range of 0% - 85%.

These shall be guaranteed by the manufacturer in writing through brochures, test reports, etc.

The Contractor shall submit the following information on the PV modules offered to the Administration (Standard testing conditions: radiation of 1000 W/m², module temperature of 25°C and spectrum of AM=1.5).

- The document containing the brand and model of the panel and all technical and physical characteristics of the product,
- Product certificate (test report),
- Guarantee and warranty certificates for the modules offered to be issued by the manufacturer.

D2.16 Each PV panel shall be affixed with a product plate on which at least the following information is provided. In order to maintain visibility rules of UNDP, the company shall first receive approvals from UNDP with regards to the visibility materials to be placed at the site.

- Manufacturer's name
- PV Cell Type
- Serial No
- Nominal Power Pmax, Voc, Isc
- Date of Manufacture
- Country of Origin

D2.17 The Contractor shall provide the Administration with the catalogue of the panels offered, a certificate of authority issued by the main manufacturer or its distributor in Turkey for sales, installation and services and certificate of guarantee/warranty of the panels.

D3. Inverters

D3.1 The maximum efficiency shall be at least 98% according to applicable European standards.

D3.2 There shall be an integrated DC separator on the DC and AC sides of the inverter, a grounding leak monitor and a grid monitor, DC reverse polarity protection, AC short-circuit protection, residual current monitor sensitive to all poles.

D3.3 Inverters shall comply with IEC61727, IEC62109, VDE-AR-N-4105, IEC61000-3 and VDE 0126-1-1 standards, and have CE certification.

D3.4 Each inverter shall have web link allowing the viewing of data over the internet.

D3.5 THD (Total Harmonic Distortion) shall be less than 3%.

D3.6 The protection class of the inverters shall be at least IP65.

D3.7 The operating temperature range of the inverters shall be between -25 and +60°C.

D3.8 The grid frequency range shall be maximum 45-53 Hz.

D3.9 The grid voltage range (phase – neutral) shall be 190-270V.

D3.10 The relative humidity under operating conditions shall be up to 95%.

D3.11 The inverters shall be originated from manufacturers/countries not included in the Sanction List of the United Nations.

D3.12 The product warranty duration shall be 2 years and the warranty duration shall be for 10 years.

D3.13 The protection class shall be Class I to IEC 62103, Class III to IEC 60664 High Voltage Category or Class I to IEC 62103, Class III to IEC 60664 high voltage category, and comprise at least 3 or 4 of the quality certificates to EN 50178 and EN 62109 equivalent to the above-mentioned protection standards, and each MPPT shall be protected by a surge arrester.

D3.14 The following documents for the inverters offered shall be submitted:

- A catalogue indicating the technical characteristics, dimensions, weight and installation details, etc.,
- Type test results and competence certificates for the inverters offered issued by accredited institutions comprising relevant testing capacity and competence,
- The installation, assembly, operating, troubleshooting and maintenance guides shall be delivered in Turkish.

D3.15 The Contractor shall submit to the Administration the catalogue of the inverters offered, and a certificate of authorization for sales, installation and service and guarantee/warranty certificate in Turkish issued by the main manufacturer or Turkish distributor of the inverters.

D4. Supporting structure for panels

D4.1 The Contractor shall install the supporting structure, which shall have the PV panels placed and fixed, on the locations marked on the layout plan in the static design project.

D4.2 The construction and assembly system shall be hot-dip galvanised to resist corrosion. The construction, assembly system and manufacturer shall have the qualifications indicated in the calculations in the static design.

D4.3 All connections shall be water-tight and impact-resistant.

D4.4 All galvanisation and paint damaged during installation shall be properly repaired.

D4.5 Gaps shall be provided between the PV panels to avoid resistance against wind.

D4.6 The PV panels shall be mounted on the construction profiles using appropriate connection apparatus (clamps). The holes on the PV panels shall not be used for bolt mounting. The clamps to be used for mounting the PV panels on the construction profiles shall be made of aluminium and necessary measures shall be taken to prevent theft.

D4.7 The aluminium items to be used in the supporting structure shall be in compliance with EN AW 6063 T5 and TS EN 12010 (2010) and the steel items shall be galvanised. Galvanising shall be according to TS 914 EN ISO 1461.

D5. Cables and cabling

D5.1 The Contractor shall be responsible for cabling between PV panels-inverters, inverters-grid, supply and appropriate installation of cables.

D5.2 The cables to be used for PV panels shall be specially produced solar cables for use in PV plants.

D5.3 The PV power cables shall be resistant to high temperature and heat, UV resistant, double isolated, halogen free, lead free (preferably), nominal cable section in compliance with IEC 60228 and IEC 60287 standards.

D5.4 The solar cables to be used in the system shall be manufactured for a rated voltage of 1800 V.

D5.5 The solar cables shall be suitable for use at operating temperature of +90°C.

D5.6 The voltage drop on the cables between the PV panels and inverters shall be maximum 1.5% at maximum current.

D5.7 The AC cables shall be TSE certified and produced in compliance with TS IEC 60502.

D5.8 The maximum operating temperature for the AC cables shall be at least 70°C.

D5.9 The cables between inverters and the grid shall be dimensioned such that a voltage drop of maximum 1.5% is allowed under full load of GCPVS.

D5.10 The Contractor shall be responsible for collecting information on the existence of underground utilities at the installation site such as underground cables, installations, pipelines; and the Contractor shall be deemed informed. In some cases, manual excavation shall be necessary.

D5.11 All cables shall be corded in cable racks, trays and metal construction using cable ties at every 30 cm or fixed appropriately.

D5.12 All cables used shall be affixed with indelible labels at both ends.

D5.13 MC4 type male and female connectors shall be used for the PV panel to solar cable and solar cable to inverter connections. The connectors, couplers and sockets shall be capable of operating at temperature range of -40°C to 90°C, have IP 67 protection class, be suitable for high currents, and comply with standards.

D6. Protection, switching materials, relays, panels and meters

D6.1 Protection, switching materials, relays, panels and meters shall be selected and used in accordance with the design drawings in the annex and relevant regulations; and all necessary regulations shall be taken into account during implementation.

D7. Grounding

D7.1 All electrical and electronic equipment to be installed for the PV plant as well as the cabins, all

carrying metal components, construction and metal components all auxiliary metal installation items shall be properly grounded. Grounding shall be made on both DC side and AC side in accordance with the design drawings.

D7.2 A grounding system shall be formed within the PV installation site as required by the relevant regulation; the grounding conductor shall be copper or galvanised sheet; and the elements and metal components of the PV plant shall be connected to this grounding line.

D7.3 The grounding system shall be built by using products complying with IEC 50164 standard.

D7.4 The Contractor shall execute the grounding, material supply and workmanship for the PV plant. In this context, such works as excavation, excavation remedial work, supply and assembly of additional auxiliary materials shall be realised by the Contractor with no additional charge.

D8. Other matters

D8.1 Any primary and auxiliary equipment and compulsory works which are not mentioned in the Technical Specifications but required for the functionality and installation of a smooth facility shall be deemed matters in favour of the Administration and executed in the context of this work. No charge shall be claimed for these from the Administration.

D8.2 Panels, metal construction etc. major components shall be prepared and delivered in assembled form with all warning, danger of death signs, user instructions and caution plates affixed on.

D8.3 All components to be used in the system shall be new and state-of-the-art models; their design, materials and workmanship shall not be lower than the quality and standards indicated in advanced engineering and manufacturing practices.

D8.4 Apart from the work and groups indicated in the technical specifications, the supply, assembly, transport, general cost and profits of any auxiliary materials which are not mentioned in the technical specifications and contract annexes but required within the work shall be within the price; and the said works shall be on the Contractor.

D8.5 During the execution of the work, all material waste in the building shall be regularly removed by the Contractor.

D8.6 The Contractor shall take fully safety measures for the employees in accordance with the occupational safety and health (OSH) legislation in effect. Employees shall have received training on work-at-height. All personal protective equipment for this purpose shall be provided by the Contractor.

D8.7 The Contractor shall be liable for all losses and damages inflicted on the facility and environment during the execution of work; and if the damage is not remedied, the amount which shall be determined shall be recovered from the Contractor.

E. ACCEPTANCE PROCEDURES

E1. Substantial Acceptance

E1.1 The procedures for Substantial Acceptance of the tested GCPVS as required by the Regulation on Unlicensed Electricity Generation in the Electricity Market with the relevant institution shall be organized by the Contractor on behalf of the Administration. The Contractor shall accompany the acceptance commission on behalf of the Administration during the Substantial Acceptance, and ensure that acceptance procedures be completed smoothly.

E1.1 The Substantial Acceptance shall involve the checking of system functionality and specifications defined in the technical specifications.

E1.1 Where it is identified during the Substantial Acceptance that the Contractor fails to meet the clauses of the technical specifications, the Substantial Acceptance shall not be granted.

E1.1 Where the proposed product is not ready as a whole with all accessories, testing devices, measuring instruments; the Substantial Acceptance shall not be granted.

E2. Final Completion

E2.1 The procedures for Final completion as required by the Regulation on Unlicensed Electricity Generation in the Electricity Market with the relevant institution shall be conducted following the remedial, within the allowed official time, of defects and deficiencies identified in the Substantial Acceptance, and fulfilment of all matters required during the warranty period.

E2.2 Where, out of the control of Administration and Contractor during the Final completion phase, there occur delays arising from the authorised institutions which shall conduct the acceptance, such a case shall be recorded mutually, and Clause 6.2.1 may be revised accordingly.

5. DEFECTS LIABILITY PERIOD, GUARANTEE, TECHNICAL SUPPORT AND MAINTENANCE

5.1. Defects liability period, as per Article 47 of General Conditions of Contract for Civil Works, will be 12 months after the substantial acceptance by local electricity distribution company.

5.2. Guarantee will be provided by the Contractor to fix failures or malfunctions of the system stemming from the deficiencies in goods for 2 years at no cost. Warranty period is on the other hand, is for 10 years for which the Contractor provides technical service, workmanship, spare parts, etc. at the cost of service/goods.

5.3. The Contractor shall ensure that all equipment and tools (including workmanship quality) to be used in the system and the system that he shall set up, shall be free of errors, new and of the highest quality and that their guarantee durations are 2 years as per the local regulations. If the materials used (including any and all parts) fail during the guarantee period (24 months) after substantial acceptance due to design, workmanship or material quality, the Contractor shall be responsible for supplying and installing the same material. Starting from the PV Plant Substantial Acceptance date, the warranty periods of the components to be used in the system shall be as follows:

- The proposed PV panels shall be under warranty for at least ten (10) years.
- PV panel substructure; 10 (ten) years.
- Invertors; 10 (ten) years.
- Other parts/sections; 10 (ten) years.

5.4. The guarantee period shall begin on the date of Substantial Acceptance for the PV Plant by UNDP.

5.5. Defects and failures that occur during the guarantee period shall be remedied by the Contractor replacing/repairing defective hardware or parts free of charge.

5.6. All expenses stemming from materials, workmanship and transportation costs for parts incurred by malfunctions that occur during the warranty period shall be covered by the Contractor.

5.7. Following the substantial acceptance of PV Plant, for two years the Contractor must act within 48 hours following notification by UNDP if any malfunctions occur.

5.8. If the inverter or any other equipment malfunctions, it may be replaced with a spare to ensure that the malfunction is remedied in the specified amount of time. After the defective equipment is repaired, it shall replace the spare equipment. Defective equipment shall be repaired and replaced within 1 month at the latest notification by UNDP.

5.9. The contractor shall have sufficient aftersales services capacity in accordance with applicable legislation and provide periodic maintenance to the PV Plant every 3 (three) months free of charge during the guarantee period to ensure that no malfunctions occur.

5.10. The Contractor shall give a detailed description of the periodic maintenance schedule and maintenance work to be performed during the guarantee period before substantial acceptance.

6. TRAINING AND DOCUMENTATION

- 6.1. The Contractor shall provide maximum 10 (ten) personnel from the Implementing Partner/Household selected by the Contracting Authority with 1 (one) day of training, minimum 4 (four), maximum 8 (eight) hours. Training shall take place in each of the provinces that the bidder submitted a bid. Training shall take place in the household or in a venue to be allocated in the village and/or near the village and the training shall be in Turkish. Contractor shall receive declarations from the trainees that they will not be taking action in cases that TEDAŞ/local electricity distribution should be notified such as electricity leakage.
- 6.2. The personnel who shall be giving the training should be either a member of the Electrical Engineering, Electronics Engineering, Electrical-Electronics Engineering or Mechanical Engineering departments of universities in Turkey or abroad, who can demonstrate works completed in PV, either in configuration or R&D. The CV of this trainer shall be presented with the bid submission (it could be the same person as the staff assigned during the installation).
- 6.3. The training program shall be presented to the approval of the Contracting Authority before the training takes place, along with information on the personnel who shall lead the training.
- 6.4. The training shall ensure that authorized operators are able to continuously carry out the following activities:
- Regular facility inspection / oversight and maintenance activities
 - Use of the data recording and remote monitoring system
 - Manual Activation / Deactivation
- 6.5. The trainings shall be given with the support of documents prepared in Turkish and shall be aimed at giving knowledge and skills on system members to relevant technical personnel.
- 6.6. The PV Plant shall be provided with the following documents shall be provided on CD and in paper/blueprint:
- Design diagram of the network and PV Plant
 - Troubleshooting guide
 - Complete equipment list,
 - Detailed specifications and manuals for each equipment
 - Test procedure and report
 - Mechanical and electrical design plans, as – built projects
 - Operation, maintenance and test catalog
 - All necessary electrical documents and pictures

7. CONSTRUCTION WORKS NOT IN COMPLIANCE WITH THE APPLICABLE PROJECTS

7.1. Construction works not in compliance with the applicable projects or its specifications shall be re-made by the Contractor in compliance with the project and its specifications, if the inspection committee deems it necessary. The Contractor shall re-make at no cost to the Contracting Authority.

8. OCCUPATIONAL HEALTH AND SAFETY MEASURES

8.1. The Contractor shall comply with the requisitions of the General Conditions for Contract for Civil Works.

8.2. Before the work commences, the Contractor shall hold the necessary meetings and ensure coordination with third parties and institutions/organizations (Institutions for phone lines, Traffic Directorate, etc.) as per

local legislation to ensure that necessary precautions are taken for the safety of workers and the quality of the work, such as procuring necessary traffic signs depending on the amount of traffic.

8.3. The Contractor shall be liable to give its own personnel the necessary training for the realization of this work for social security, insurance or Personal Protection Equipment. Otherwise, accountability, the legal and criminal responsibility for all accidents that occur as a result of negligence, employing illegal or unlicensed workers, shall be on the Contractor.

8.4. The Contractor shall provide all health precautions necessary to protect the health of workers in accordance with the provisions of the occupational health and safety regulations.

8.5. The Contractor shall be wholly responsible for observing local Social Security and Human Resources legislation, hiring workers or paying for their labor rights pertaining to rights of workers and employers, hiring workers, etc. The Contracting Authority holds no responsibility in this regard.

8.6. The Contractor has to notify UNDP on staff changes; before any changes are made.

8.7. If specific knowledge or skills are necessary to complete certain tasks, the Contractor shall be responsible for hiring personnel competent for such tasks (asphalt cutting, use of a compactor, EFM welding, PPRC welding etc.)

8.8. The contractor shall be the direct employer of the workers he recruits for the works he has undertaken. As such, in order to prevent occupational accidents and occupational diseases, it is necessary to take all required Occupational Health and Safety precautions stated in Occupational Health and Safety Law No. 6331, Labor Law No. 4857, Social Security Insurance Law, related Directives and Regulations and other local regulations, and to make sure that the rules are observed at the worksite, to provide all kinds of materials, tools and supplies, to keep them at the workplace, to ensure that they are used by the workers and to check whether the precautions taken are abided by.

8.9. The contractor shall be obliged to follow up on the relevant laws and regulations on Occupational Health and Safety and to fulfil all legal obligations. Otherwise, the legal and criminal responsibility for all accidents that occur as a result of negligence, employing or unlicensed illegal workers shall be on the Contractor.

8.10. The Contractor shall procure all types of insurances defined in General Conditions of Contract for Civil Works and insurances specifically identified in Section 5.a.

8.11. If necessary, UNDP may appoint firm(s)/organization(s)/person(s) to monitor the compliance of health and safety measures to the Turkish Laws and Legislations.

Section 5b: Other Related Requirements

Further to the Schedule of Requirements in the preceding Table, Bidders are requested to take note of the following additional requirements, conditions, and related services pertaining to the fulfillment of the requirements:

Delivery Term	The equipment shall be delivered on “Turnkey” basis, after installation, commissioning. For international deliveries, the delivery term is “DAP”; whereby the contractor shall follow exactly the same process for installation and commissioning. Please kindly refer to the Payment Condition Table in Bid Data Sheet Item 25.		
Exact Address of Delivery/Installation Location	<u>Province</u>	<u>Sub-Province</u>	<u>Village</u>
	Adana	Feke	Paşalı
	Çorum	Osmançık	Gecek
	Ankara	Kızılcahamam	Uğurlu
	Artvin	Yusufeli	Çevreli
	Bilecik	Gölpazarı	Kavak
	Çanakkale	Yenice	Sazak
	Denizli	Pamukkale	Güzelpınar
	Elazığ	Merkez	Bağlarca
	Elazığ	Merkez	Sarıgül
	Erzurum	Tortum	Şenyurt
	Burdur	Merkez	Büğdüz
	İzmir	Kiraz	Çayağzı
	Manisa	Sarıgöl	Alemşahlı
	Manisa	Sarıgöl	Kızılcukur
	Manisa	Sarıgöl	Karacaali
	Kastamonu	Tosya	Çaykapı
	Yozgat	Akdağmadeni	Yukarıçulhalı
	Yozgat	Çekerek	Bayındırhüyük
	Karaman	Merkez	Gökçe
	Kahramanmaraş	Onikişubat	Sarıçukur
	Şanlıurfa	Bozova	Arıkök
	Trabzon	Maçka	Ardıçyayla
Inspection upon “turnkey” delivery	An inspection committee from UNDP will do an inspection for the substantial and final acceptance/completion.		
Installation Requirements	As per Section 5a, Schedule of Requirements and Technical Specifications/Technical Requirements/Bill of Quantities		
Testing Requirements	As per Section 5a, Schedule of Requirements and Technical Specifications/Technical Requirements/Bill of Quantities		
Scope of Training on Operation and Maintenance	As per Section 5a, Schedule of Requirements and Technical Specifications/Technical Requirements/Bill of Quantities		

Commissioning	As per Section 5a, Schedule of Requirements and Technical Specifications/Technical Requirements/Bill of Quantities
Warranty Period	The guarantee period is for 2 Years after substantial acceptance by UNDP when the Contractor will provide services/repair/hardware/spare parts for goods in case of failure or malfunctions at no extra cost. The Contractor will provide a warranty for 10 years while technical service, workmanship and spare parts will be available through paying the price for services and goods to the Contractor. The PV will be transferred to local government or non-government institutions after substantial acceptance. Contractor will be also in contact with this institution during the guarantee and warranty period.
Local Service Support	Must be available
Technical Support Requirements	Must be available
After-sale services Requirements	<input checked="" type="checkbox"/> Warranty on Parts and Labor for minimum period of 10 years, as explained and 2 years for guarantee period at no extra cost <input checked="" type="checkbox"/> Technical Support <input checked="" type="checkbox"/> Provision of Service Unit when pulled out for maintenance /repair <input type="checkbox"/> Others <i>[pls. specify]</i>
Conditions for Release of Payment	Please refer to Item 25 of Bid Data Sheet
All documentations, including catalogues, instructions and operating manuals, shall be in this language	English/Turkish
Preconditions for Acceptance of Invoices by UNDP:	<ul style="list-style-type: none"> • Complete delivery of all items (when the installation, commissioning, electricity production, transfer to grid and successful delivery of training are all made.) • Positive Inspection and Substantial Acceptance by UNDP at destination,
Inspection and Acceptance	<p>The inspection and substantial acceptance shall be conducted by the committee established by UNDP upon turnkey delivery of the all on-grid Rooftop PV Systems. The guarantee period will be initiated upon substantial acceptance by UNDP.</p> <p>On-grid Rooftop PV System to be installed is also subject to an additional inspection and acceptance in conjunction with the local electricity distribution company.</p>

Section 6: Returnable Bidding Forms / Checklist

This form serves as a checklist for preparation of your Bid. Please complete the Returnable Bidding Forms in accordance with the instructions in the forms and return them as part of your Bid submission. No alteration to format of forms shall be permitted and no substitution shall be accepted.

Before submitting your Bid, please ensure compliance with the Bid Submission instructions of the BDS 22.

Technical Bid:

Have you duly completed all the Returnable Bidding Forms?	
▪ Form A: Bid Submission Form	<input type="checkbox"/>
▪ Form B: Bidder Information Form	<input type="checkbox"/>
▪ Form C: Joint Venture/Consortium/ Association Information Form	N/A
▪ Form D: Qualification Form	<input type="checkbox"/>
▪ Form E: Format of Technical Bid/Bill of Quantities	<input type="checkbox"/>
▪ Form G: Form of Bid Security	
Have you provided the required documents to establish compliance with the evaluation criteria in Section 4?	<input type="checkbox"/>

Price Schedule:

▪ Form F: Price Schedule Form	<input type="checkbox"/>
-------------------------------	--------------------------

Form A: Bid Submission Form

Name of Bidder:	[Insert Name of Bidder]	Date:	Select date
ITB reference:	[Insert ITB Reference Number]		

We, the undersigned, offer to supply the goods and related services required for [Insert Title of goods and services] in accordance with your Invitation to Bid No. [Insert ITB Reference Number] and our Bid. We hereby submit our Bid, which includes this Technical Bid and Price Schedule.

Our attached Price Schedule is for the sum of [Insert amount in words and figures and indicate currency].

We hereby declare that our firm, its affiliates or subsidiaries or employees, including any JV/Consortium /Association members or subcontractors or suppliers for any part of the contract:

- a) is not under procurement prohibition by the United Nations, including but not limited to prohibitions derived from the Compendium of United Nations Security Council Sanctions Lists;
- b) have not been suspended, debarred, sanctioned or otherwise identified as ineligible by any UN Organization or the World Bank Group or any other international Organization;
- c) have no conflict of interest in accordance with Instruction to Bidders Clause 4;
- d) do not employ, or anticipate employing, any person(s) who is, or has been a UN staff member within the last year, if said UN staff member has or had prior professional dealings with our firm in his/her capacity as UN staff member within the last three years of service with the UN (in accordance with UN post-employment restrictions published in ST/SGB/2006/15);
- e) have not declared bankruptcy, are not involved in bankruptcy or receivership proceedings, and there is no judgment or pending legal action against them that could impair their operations in the foreseeable future;
- f) undertake not to engage in proscribed practices, including but not limited to corruption, fraud, coercion, collusion, obstruction, or any other unethical practice, with the UN or any other party, and to conduct business in a manner that averts any financial, operational, reputational or other undue risk to the UN and we embrace the principles of the United Nations Supplier Code of Conduct and adhere to the principles of the United Nations Global Compact.

We declare that all the information and statements made in this Bid are true and we accept that any misinterpretation or misrepresentation contained in this Bid may lead to our disqualification and/or sanctioning by the UNDP.

We offer to supply the goods and related services in conformity with the Bidding documents, including the UNDP General Conditions of Contract and in accordance with the Schedule of Requirements and Technical Specifications.

Our Bid shall be valid and remain binding upon us for the period specified in the Bid Data Sheet.

We understand and recognize that you are not bound to accept any Bid you receive.

I, the undersigned, certify that I am duly authorized by [Insert Name of Bidder] to sign this Bid and bind it should UNDP accept this Bid.

Name: _____

Title: _____

Date: _____

Signature: _____

[Stamp with official stamp of the Bidder]

Form B: Bidder Information Form

Legal name of Bidder	[Complete]
Legal address	[Complete]
Year of registration	[Complete]
Bidder's Authorized Representative Information	Name and Title: [Complete] Telephone numbers: [Complete] Email: [Complete]
Are you a UNGM registered vendor?	<input type="checkbox"/> Yes <input type="checkbox"/> No If yes, [insert UGNM vendor number]
Are you a UNDP vendor?	<input type="checkbox"/> Yes <input type="checkbox"/> No If yes, [insert UNDP vendor number]
Countries of operation	[Complete]
No. of full-time employees	[Complete]
Quality Assurance Certification (e.g. ISO 9000 or Equivalent) <i>(If yes, provide a Copy of the valid Certificate):</i>	[Complete]
Does your Company hold any accreditation such as ISO 14001 or ISO 14064 or equivalent related to the environment? <i>(If yes, provide a Copy of the valid Certificate):</i>	[Complete]
Does your Company have a written Statement of its Environmental Policy? <i>(If yes, provide a Copy)</i>	[Complete]
Does your organization demonstrates significant commitment to sustainability through some other means, for example internal company policy documents on women empowerment, renewable energies or membership of trade institutions promoting such issues	[Complete]
Is your company a member of the UN Global Compact	[Complete]
Contact person that UNDP may contact for requests for	Name and Title: [Complete]

clarifications during Bid evaluation	Telephone numbers: [Complete] Email: [Complete]
Please attach the following documents:	<ul style="list-style-type: none"> ▪ Company Profile, which should <u>not</u> exceed fifteen (15) pages, including printed brochures and product catalogues relevant to the goods and/or services being procured ▪ Certificate of Incorporation/ Business Registration* ▪ Tax Registration/Certificate issued by the Internal Revenue Authority ▪ Trade name registration papers, if applicable ▪ Quality Certificate (e.g., ISO, etc.) and/or other similar certificates, accreditations, awards and citations received by the Bidder, if any ▪ Environmental Compliance Certificates, Accreditations, Markings/Labels, and other evidences of the Bidder's practices which contributes to the ecological sustainability and reduction of adverse environmental impact (e.g., use of non-toxic substances, recycled raw materials, energy-efficient equipment, reduced carbon emission, etc.), either in its business practices or in the goods it manufactures ▪ Patent Registration Certificates, if any of technologies submitted in the Bid is patented by the Bidder ▪ Local Government permit to locate and operate in assignment location, if applicable ▪ Official Letter of Appointment as local representative, if Bidder is submitting a Bid on behalf of an entity located outside the country <p><i>* In Turkey, this corresponds to the Trade Registry Gazette that demonstrates the year of establishment of the business, articles of association, shareholders etc. if the business has updated/revised its articles of association and/or the shareholders, the trade registry gazette(s) that demonstrate(s) the most updated information on these matters should be provided as well).</i></p> <ul style="list-style-type: none"> ▪

Form C: Joint Venture/Consortium/Association Information Form

This form is not applicable

Name of Bidder:	[Insert Name of Bidder]	Date:	Select date
ITB reference:	[Insert ITB Reference Number]		

To be completed and returned with your Bid if the Bid is submitted as a Joint Venture/Consortium/Association.

No	Name of Partner and contact information <i>(address, telephone numbers, fax numbers, e-mail address)</i>	Proposed proportion of responsibilities (in %) and type of goods and/or services to be performed
1	[Complete]	[Complete]
2	[Complete]	[Complete]
3	[Complete]	[Complete]

Name of leading partner (with authority to bind the JV, Consortium, Association during the ITB process and, in the event a Contract is awarded, during contract execution)	[Complete]
--	------------

We have attached a copy of the below referenced document signed by every partner, which details the likely legal structure of and the confirmation of joint and severable liability of the members of the said joint venture:

☐ Letter of intent to form a joint venture **OR** ☐ JV/Consortium/Association agreement

We hereby confirm that if the contract is awarded, all parties of the Joint Venture/Consortium/Association shall be jointly and severally liable to UNDP for the fulfillment of the provisions of the Contract.

Name of partner: _____ Name of partner: _____

Signature: _____ Signature: _____

Date: _____ Date: _____

Name of partner: _____ Name of partner: _____

Signature: _____ Signature: _____

Date: _____ Date: _____

Form D: Eligibility and Qualification Form

Name of Bidder:	[Insert Name of Bidder]	Date:	Select date
ITB reference:	[Insert ITB Reference Number]		

If JV/Consortium/Association, to be completed by each partner.

History of Non- Performing Contracts

<input type="checkbox"/> Non-performing contracts did not occur during the last 3 years (reference period to be taken into account: from 10 March 2017 to 10 March 2020).			
<input type="checkbox"/> Contract(s) not performed in the last 3 years (reference period to be taken into account: from 10 March 2017 to 10 March 2020).			
Year	Non- performed portion of contract	Contract Identification	Total Contract Amount (current value in US\$)
		Name of Client: Address of Client: Reason(s) for non-performance:	

Litigation History (including pending litigation)

<input type="checkbox"/> No litigation history for the last 3 years (reference period to be taken into account: from 10 March 2017 to 10 March 2020).			
<input type="checkbox"/> Litigation History as indicated below			
Year of dispute	Amount in dispute (in US\$)	Contract Identification	Total Contract Amount (current value in US\$)
		Name of Client: Address of Client: Matter in dispute: Party who initiated the dispute: Status of dispute: Party awarded if resolved:	

Previous Relevant Experience

Please list only previous assignments successfully completed for provision and installation of on-grid PV system (roof-top or land-based) in the last 5 years (reference period to be taken into account: from 10 March 2015 to 10 March 2020).

List only those assignments for which the Bidder was legally contracted by the Client as a company or was one of the Consortium/JV partners. Assignments completed by the Bidder's individual experts working privately or

through other firms cannot be claimed as the relevant experience of the Bidder, or that of the Bidder's partners or sub-consultants, but can be claimed by the Experts themselves in their CVs. The Bidder should be prepared to substantiate the claimed experience by presenting copies of relevant documents and references if so requested by UNDP.

As proof document, the bidders shall submit original letters or their notarized versions, indicating 'Satisfactory Performance/Substantial or Final Acceptance issued by **Electricity Utility Company**' (the Letters shall indicate the initiation and end date for the previous experience, its budget information, installed power, location of the system explicitly).

Project name & Country of Assignment	Client & Reference Contact Details	Contract Value (in USD equivalent*)	Period of activity and status	Types of activities undertaken

*Bidders shall convert the currency quoted in the "Certificate of Satisfactory Performance/Substantial or Final Acceptance" into USD, in accordance with the prevailing UN operational rate of exchange on the contract date stated in "Certificate of Completion". UN operational exchange rates are available at the following website: <https://treasury.un.org/operationalrates/OperationalRates.php#E>

Bidders may also attach their own Project Data Sheets with more details for assignments above.

☐ Bidders shall attach Statements of Satisfactory Performance/Substantial or Final Acceptance Certificates from the Clients.

Financial Standing

Annual Turnover for the last 3 years (in USD equivalent²)	Year	USD
	Year	USD
	Year	USD
Latest Credit Rating (if any), indicate the source		

Financial information (in US\$ equivalent)	Historic information for the last 3 years		
	Year 1	Year 2	Year 3
	<i>Information from Balance Sheet</i>		
Total Assets (TA)			
Total Liabilities (TL)			
Current Assets (CA)			
Current Liabilities (CL)			
	<i>Information from Income Statement</i>		
Total / Gross Revenue (TR)			

² Bidders shall convert the currency into USD by using the UN operational exchange rate which was effective for December of each corresponding year. UN operational exchange rates are available at the following website: <https://treasury.un.org/operationalrates/OperationalRates.php>

Profits Before Taxes (PBT)			
Net Profit			
Current Ratio			

☐ Attached are copies of the audited financial statements (balance sheets, including all related notes, and income statements) for the years required above complying with the following condition:

- a) Must reflect the financial situation of the Bidder or party to a JV, and not sister or parent companies;
 - b) Historic financial statements must be audited by a certified public accountant;
 - c) Historic financial statements must correspond to accounting periods already completed and audited.
- No statements for partial periods shall be accepted.

Form E: Format of Technical Bid

Name of Bidder:	[Insert Name of Bidder]	Date:	Select date
ITB reference:	[Insert ITB Reference Number]		

The Bidder's Bid should be organized to follow this format of the Technical Bid. Where the bidder is presented with a requirement or asked to use a specific approach, the bidder must not only state its acceptance, but also describe how it intends to comply with the requirements. Where a descriptive response is requested, failure to provide the same will be viewed as non-responsive.

SECTION 1: Bidder's qualification, capacity and expertise

- 1.1 General organizational capability which is likely to affect implementation: management structure, financial stability and project financing capacity, project management controls, extent to which any work would be subcontracted (if so, provide details).
- 1.2 Relevance of specialized knowledge and experience on similar engagements done in the region/country.
- 1.3 Quality assurance procedures and risk mitigation measures.
- 1.4 Organization's commitment to sustainability.

SECTION 2: Scope of Supply, Technical Specifications, and Related Services

This section should demonstrate the Bidder's responsiveness to the specification by identifying the specific components proposed, addressing the requirements, as specified, point by point; providing a detailed description of the essential performance characteristics proposed; and demonstrating how the proposed bid meets or exceeds the requirements/specifications. All important aspects should be addressed in sufficient detail.

- 2.1 A detailed description of how the Bidder will deliver the required goods and services, keeping in mind the appropriateness to local conditions and project environment. Details how the different service elements shall be organized, controlled and delivered.
- 2.2 Explain whether any work would be subcontracted, to whom, how much percentage of the requirements, the rationale for such, and the roles of the proposed sub-contractors and how everyone will function as a team.
- 2.3 Implementation plan including a Gantt Chart or Project Schedule indicating the detailed sequence of activities that will be undertaken and their corresponding timing.

Technical Compliance Table					
Goods and services to be Supplied and Technical Specifications	Your response				
	Compliance with technical specifications		Specifications Quoted by the Bidder	Quality Certificate/Export Licenses, etc. <i>(indicate all that apply and attach)</i>	Comments
	Yes, we comply (Yes/No)	No, we cannot comply <i>(indicate discrepancies)</i>			
Panel, minimum 270 Wp (for a radiation of 1000 W/m ²) under standard operating conditions, each being of the same type and rated power and certified to IEC 61215, IEC 61730-1 and IEC 61730-2, having instant power output tolerance of 0/+5 W, resistant to wind velocity of at least 130 km/h, wind load of at least 2400 Pa and a snow load of at least 5400 Pa (IEC 61215), and protection class of IP 67					
Supporting Structure, made of corrosion resistant material (hot-dip, galvanized, etc.), designed for an operational life of at least 25 years, resistant to wind with a velocity of 130 km/h and snow load of at least 5400 Pa as a whole including the PV panels installed on them.					
Inverter, having a maximum efficiency of at least 98%, THD less than 3%, protection class of at least IP 65,					

operating temperature range between -25 and +60°C and relative humidity up to 95%, and equipped with an integrated DC separator on the DC and AC sides of the inverter, a grounding leak monitor and a grid monitor, DC reverse polarity protection, AC short-circuit protection, residual current monitor sensitive to all poles.					
Cables					
Workmanship for installation of on-grid Rooftop PV System					
2-year Comprehensive Machinery Insurance (CMI) after substantial acceptance					
Minimum amount of liability insurance (15% of the total amount of the Contract) - Clause 23 of UNDP General Conditions of Contract for Civil Works					

*As per Section 5a – Schedule of Technical Requirements and Specifications.

** Quantities are estimated based on preliminary design drawings. Payment shall be done according to approved drawings.

Other Related services and requirements (based on the information provided in Section 5b)	Compliance with requirements		Details or comments on the related requirements
	Yes, we comply	No, we cannot comply (indicate discrepancies)	
Guarantee			
Warranty			
Local Service Support			
Staff assigned for the installation of the roof-top plant			
Training for households and provision of User's Manual			

SECTION 3: Management Structure and Key Personnel

- 3.1 Describe the overall management approach toward planning and implementing the project. Include an organization chart for the management of the project describing the relationship of key positions and designations. Provide a spreadsheet to show the activities of each personnel and the time allocated for his/her involvement.
- 3.2 Provide CVs for key personnel that will be provided to support the implementation of this project using the format below. CVs should demonstrate qualifications in areas relevant to the scope of goods and/or services.

Format for CV of Proposed Key Personnel

Name of Personnel	[Insert]
Position for this assignment	[Insert]
Nationality	[Insert]
Language proficiency	[Insert]
Education/ Qualifications	<i>[Summarize college/university and other specialized education of personnel member, giving names of schools, dates attended, and degrees/qualifications obtained.]</i> [Insert]
Professional certifications	<i>[Provide details of professional certifications relevant to the scope of goods and/or services]</i> <ul style="list-style-type: none">▪ Name of institution: [Insert]▪ Date of certification: [Insert]
Employment Record/ Experience	<i>[List all positions held by personnel (starting with present position, list in reverse order), giving dates, names of employing organization, title of position held and location of employment. For experience in last five years, detail the type of activities performed, degree of responsibilities, location of assignments and any other information or professional experience considered pertinent for this assignment.]</i> [Insert]
References	<i>[Provide names, addresses, phone and email contact information for two (2) references]</i> Reference 1: [Insert] Reference 2: [Insert]

I, the undersigned, certify that to the best of my knowledge and belief, the data provided above correctly describes my qualifications, my experiences, and other relevant information about myself.

Signature of Personnel

Date (Day/Month/Year)

FORM F: Price Schedule Form

Name of Bidder:	[Insert Name of Bidder]	Date:	Select date
ITB reference:	[Insert ITB Reference Number]		

The Bidder is required to prepare the Price Schedule following the below format. The Price Schedule must include a detailed cost breakdown of all goods and related services to be provided. Separate figures must be provided for each functional grouping or category, if any.

Total Financial Bid, Turkey Unit Prices and Turkey Total Prices shall include the all requirements specified under Section 5 ("Section 5a: Schedule of Requirements and Technical Specifications/Bill of Quantities" and "Section 5b: Other Related Requirements")

The Contractor shall not be entitled to receive any price difference and/or additional amount from UNDP for whatsoever reason, including but not limited to increase in the costs of the Contractor or any missing goods/services in its Price Schedule to be submitted in response to this ITB.

Price Schedule

No	Item	Unit	Quantity*	Turnkey unit Price (USD/set)	Turnkey Total Price (USD)
A. PV System					
A.1	On-grid Rooftop PV System having installed capacity of 1,20 kW AC	Set	200		
A.2	On-grid Rooftop PV System having installed capacity of 2,00 kW AC	Set	12		
A.3	On-grid Rooftop PV System having installed capacity of 2,80 kW AC	Set	11		
A.4	On-grid Rooftop PV System having installed capacity of 3,20kW AC	Set	2		
TOTAL FINANCIAL BID (USD)**					

***These quantities are determined by GDF. These quantities may be subject to change. UNDP shall issue payments over the realized quantities during the course of the contract, without changing the unit price whatsoever. The successful bidder shall not be entitled to receive any amount over and above this figure for reasons including but not limited to solid conditions; length of cabling; location of the villages; etc. For this reason; the bidders shall make a thorough analysis of possible additional costs that may come out while preparing their bids.**

**** Value Added Tax (VAT) shall not be included in the Bid, as UNDP is exempt from VAT.**

Name of Bidder: _____

Authorised signature: _____

Name of authorised signatory: _____

Functional Title: _____

FORM G: Form of Bid Security

**Bid Security must be issued using the official letterhead of the Issuing Bank.
Except for indicated fields, no changes may be made on this template.**

To: UNDP
[Insert contact information as provided in Data Sheet]

WHEREAS [Name and address of Bidder] (hereinafter called "the Bidder") has submitted a Bid to UNDP dated [Click here to enter a date](#) to execute goods and/or services [Insert Title of Goods and/or Services] (hereinafter called "the Bid"):

AND WHEREAS it has been stipulated by you that the Bidder shall furnish you with a Bank Guarantee by a recognized bank for the sum specified therein as security if the Bidder:

- a) Fails to sign the Contract after UNDP has awarded it;
- b) Withdraws its Bid after the date of the opening of the Bids;
- c) Fails to comply with UNDP's variation of requirement, as per ITB instructions; or
- d) Fails to furnish Performance Security, insurances, or other documents that UNDP may require as a condition to rendering the contract effective.

AND WHEREAS we have agreed to give the Bidder such Bank Guarantee:

NOW THEREFORE we hereby affirm that we are the Guarantor and responsible to you, on behalf of the Bidder, up to a total of *[amount of guarantee] [in words and numbers]*, such sum being payable in the types and proportions of currencies in which the Price Bid is payable, and we undertake to pay you, upon your first written demand and without cavil or argument, any sum or sums within the limits of *[amount of guarantee as aforesaid]* without your needing to prove or to show grounds or reasons for your demand for the sum specified therein.

This guarantee shall be valid up to 30 days after the final date of validity of bids.

SIGNATURE AND SEAL OF THE GUARANTOR BANK

Signature: _____

Name: _____

Title: _____

Date: _____

Name of Bank _____

Address _____

[Stamp with official stamp of the Bank]

[insert: address and email address]