

## Bid Bulletin 01

### IRQ-RFQ-039-20

#### Rehabilitation of Electrical Network in Al-Sakrah District – Anah, Anbar Governorate - Iraq. Coordinate 34.2279744N, 42.1452283E

Questions	Answers
Did the work include to rehabilitate the main feeder from the substation towards Al-Sakrah district?	the work not includes to rehabilitate the main feeder while includes install feeder to connect the substation with the existed feeder line that feeds the agricultural projects and rehabilitation of the internal network.
Did the work includes to remove the old and damaged poles?	the work includes to remove all the damaged poles, conductors, insulators ... etc. and deliver it to the end user warehouse as mentioned in BoQ.