

**Bid Bulletin 02**  
**IRQ-ITB-032/20**

**Rehabilitation of Three Strategic Warehouses for Department of  
Agriculture in Hawija-Kirkuk Governorate**

Questions	Answers
1. Is it possible to provide us with any interior architectural drawings	There is no architectural drawing as the building is warehouse with no interior partitions.
2. Are we responsible for main distribution panelboard	Main distribution panelboard has been added to the BoQ. Please refer to updated BoQ. Item # 1, 3, 7, 9 and 13. Also, one new item has been created which is # 15.
3. What is the IP protection of the lighting fixtures & outlet and distribution panelboard	The IP protection for lighting fixtures is IP65, for outlets is IP23 and for panelboards is IP65.
4. With the reference to Electrical Work item no 1: Power cable (4x35 mm <sup>2</sup> ), where is the control pump board of the project? For what purpose it is using	There is no control pump board. the cable is to connect the main electrical source to the building (From the Electricity grid to MDB of the warehouse)
5. Is it possible to provide us with the project layout plan	There is no layout exist for the project, but the bidder can get detail about the layout through the site visit.