

UNDP CYP RFQ EID 025 2020 – Fencing of 3 Churches

Clarifications No.: 1 dated 27 February 2020

	Questions	Answers
1	<p>50X50X5MM METAL MESHES SPECIFIED FOR FENCES.</p> <p>Only galvanized mesh with 50x50 and sizes 1.00x2.00 mt, 1.20x3.00 mt, 1.50x3.00 mt</p> <p>Metal meshes 50x150 and sizes-1.80x6.00 mt. available in the market</p> <p>Please advise whether metal mesh with sheets 50x150 OR 50x50 Galvanized sheets can be used</p>	<p>50x50x5 metal mesh will be used, not galvanized.</p>
2	<p>GATES: Galvanized mesh with 1.00x2.00 mt 50X50 AVAILABLE.</p> <p>Please advice whether galvanize sheets can be used.</p>	<p>As per the drawings and specification. Galvanized material not accepted.</p>