

QUESTIONS AND ANSWERS

Item No:	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Did the area of the land is enough for the new school building?	The bidders were informed that the new school site will be increased by 5 meters from each side in order to fit the new building and according to the drawings .
2	What's the works included for the existed extension building ?	The bidders were informed that work includes all the civil works required as removing the exterior walls plastering and re-plaster it and rendering , and painting the interior walls with plastic paintings , removing damaged walkways and yard and recasting of it , rehabilitation of the doors and windows ...etc .
3	Where is the high tension power electrical poles ?	The bidders were informed about the location from where the electricity of the school will provided and informed about removing the damages poles .
4	Where will be installed the water pump of the RO unit ?	The bidders were informed that the water pump will be installed beside the river and the CPVC pipe will be laying down and trenched to be connected with the RO unit to provide the school with water .

Certification of Minutes as a true record of the proceedings of the meeting/site visit:

Prepared by: -

Signature:

Name: Alaa Naji Abd Al-Jaleel

Position: Site Engineer of Anah and Rawa

Date: 3 Mar. 2020