

Amendment No. 1

TO REQUEST FOR QUOTATION FOR LOW-VALUE GOODS

Date: <b>April 17, 2020</b>
Regarding: <b>RFQ/024/20 – Request for Quotation for Supply and installation of reverse osmosis system with a discharge capacity of 6m3/hour</b>

This Amendment is submitted to **RFQ/024/20** announced on **April 11, 2020**, for the "Supply and installation of reverse osmosis system with a discharge capacity of 6m3/hour"

Changes are as follows:

1. Required water quality of **Item # 1** upon discharging is to be read as stipulated in **ANNEX 4** below, which is an integral part of this Amendment No. 1.

All Amendments to the **RFQ/024/20** are an integral part of it, and all participants must comply with the requirements stipulated by such additions. Any deviation from the claims made by amendments to this RFQ may result in consideration of the proposal as not meeting the requirements and withdrawing from further evaluation.

All other terms and conditions of the **RFQ/024/20** remain unchanged.

**ANNEX 4**

Name of Indicator	UOM	Required Quality
Mineralization	mg/l	1000 - 1500
Total alkalinity	mg-eqv/l	Less than 7.0
Calcium	mg/l	Less than 350
Sulfates (in sulfur)	mg/l	100
Chlorides	mg/l	150