

Bid Bulletin 02
IRQ-ITB-121/20
Rehabilitation of Al-Hussain Electrical Substation in Ramadi-Anbar
Governorate-Iraq

To: All potential bidders,


The purpose of this addendum is to inform all the bidders that:

- 1- The deadline of bid submission has extended from **03 May 2020 till 10 May 2020 @14:00 ILT**.

Question(s)	Answer(s)
We would like to request a clarification regarding subjected newly announced tender. As its stated in BoQ only Siemens and Schneider products will be accepted according to the explanation of end user	<p>Kindly note that the request is made by the Government Authorities to rehabilitate an existing substation with Siemens and Schneider components/equipment, after consultation with end-user, the cited brands requested due to the following reasons:</p> <ul style="list-style-type: none">✓ This project is for the rehabilitation of existed substation for old models which contains "Siemens" and "Schneider" equipment;✓ The end-user has standardized these brands within the target project area;✓ Availability of spare parts for the mentioned brands in the end-user stores;✓ End-user staff are trained on these brands and they are familiar with the substation. <p>Based on the above, bidders are kindly advised to submit their quote(s) as per compliance sheet and BOQ advertised.</p>

All other terms and conditions in the ITB remained unchanged.

Thank you in advance for your interest in UNDP procurement opportunities.



Ijaz Hussain
Head of Procurement
Service Center, UNDP