

Bid Bulletin 03

Site Visit Question and Answers

ITB-118/20

**Rehabilitation of Jubail Sewage and Storm water Networks- Zone B -
Al Khadraa' District - Falluja**

No.	QUESTIONS	Answers
1	Please advise about the arrangement for connection point between the Stormwater Network (pipes) and Stormwater lift station (pipes).	<p>As shows on the drawings and BOQ, the selected bidder is requested to execute the project up to the connection point/manhole(s) under supervision of UNDP Focal Engineer, as well as, in coordination with end-user.</p> <p>UNDP Focal Engineer and end-user will coordinate between both projects/sites selected bidders to ensure that the levels of execution as required in plans to connect both sites as required.</p>
2	Please advise about the direction of sewage pipes	It'll be towards the F1 sub-station, which existing now.
3	Please advise the responsibility of damages for the other services in project area like (electric, water pipes and others)	It'll be under responsibility of the execution contractor to repair any damages in services inside the project area