RFQ-197/20 - Full Rehabilitation of 11 KV Electrical Feeder for Alwuabed Water Project in Habbaniyah, Ramadi, Anbar, Iraq

QUESTIONS AND ANSWERS

During the site visit

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	From where the feeder will be start? Is it	The feeder will be connected with the existing
	from the mobile substation?	street lighting feeder "Emergency electrical line"
		that already feeding it from the mobile
		substation