

## **QUESTIONS AND ANSWERS REPORT No. 2**

**To:** Bidders

**From:** UNDP Syria Co

**Subject:** Rehabilitation of pumping stations and drinking water well in Al Qamishli Countryside

**Reference:** **UNDP-SYR-ITB-32-20**

**Date:** 31-5-2020

UNDP Syria Procurement Unit has received questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Questions and Answers		
1	Q. A.	<p>In the first item (Providing and installing a 50m<sup>3</sup>/h horizontal pumping set, 100m lifting shut off, in oum Alkhair Albarkieh and Yathreb (Tal Hamis); there is a discrepancy in the pump rotation speed between the Arabic and the English version, English version says (From 1450 to 1500 rpm) while the Arabic version says (سرعة الدوران من 2850 وحتى 3000 د/د) please confirm which is correct one.</p> <p><b>The rotation speed is between 2850 to 3000 rpm.</b></p>
2	Q. A.	<p>In the price list: item no. 15 and item no. 17 should be in the same quantity, kindly confirm the correct qty.</p> <p><b>The quantity of transformers 100KV (item No 15 in the price list) is 4 and the quantity of 100KV's control panel ( item No 17 in the price list) is 5 , the additional one is to replace 100KV control panel which is out of service.</b></p>
3	Q. A.	<p>In the price list: item no. 24, the requested unit is not clear in (Cubic) since the Digging is in a 60 cm width, 120 cm deep, while the length is unknown, kindly clarify.</p> <p><b>about item No 24 ( 60cm,120cm,145m) and item No 21 (60cm, 120cm,2500m).</b></p>