

**ITB-217/20**  
**Supply of Kitchen & Laundry Equipment for Al Batool Building in Al Shifaa Hospital Complex-West Mosul**  
**Bid Bulletin 2**  
**Questions and Answers**

Question	Answer
<p>please advise about the following dimensions:</p> <ol style="list-style-type: none"> <li>1. Soaking sinks.</li> <li>2. Cold rooms as per the requirement.</li> </ol>	<p>The required dimensions are:</p> <ul style="list-style-type: none"> <li>• The dimension of the soaking sink is 0.5cm x 0.5cm.</li> <li>• The dimension of the walk-in garbage cold room is 3.4m x 2.7m.</li> <li>• The dimension of the walk-in meat cold room is 2m x 3.5m</li> </ul>
<p>The technician and labours who will be working for the installation of the equipment's as per the tender will UNDP will provide food and accommodations for them or it will be contractor responsibility.</p>	<p>The price shall be based on supply and installation. The landed price, including transportation, insurance and the total cost of ownership (including spare parts, consumption, installation, commissioning, training, special packaging, etc., where applicable).</p> <p>UNDP will not provide any kind of food nor accommodation; it is solely the responsibility of the bidder</p>
<p>Please advise if the CAD drawings for this project are available. We have the PDFs but to obtain accurate dimensions we request you provide the CAD drawings.</p>	<p>Please refer to the attached CAD drawings. Kindly advised that the attached CAD Drawing's remained the reference for the quoted prices. Any modification or change of the drawings will not be considered even if it included bidder's bid or during implementation. The CAD file uploaded will remained the reference for the execution.</p>