

## Questions and answers

### Tender 522-2020-UNDP-UKR-RFP-RPP

**«Purchasing of stand-by generator 50 kW and services regarding it's installation, connection, commissioning and start up, and works and services of generator's maintenance»**

**«Постачання постачання резервного генератору потужністю 50 кВт та послуг з узгодження його встановлення, підключення, пусконаладжувальних робіт, а також робіт та послуг з його обслуговування»**

<b>QUESTION 1. Which Engine Governor is required?</b>	<b>ANSWER 1.</b> In terms of reference mentioned required power for the Generator for UNDP Office in Ukraine.  <u>Type of engine governor is depending from engine manufacturer and/or Proposal of the Bidder.</u>  However, UNDP expects that proposed Engine will have support / option of usage of electronic governor for the engine. And, Bidder may on his own intention include electronic governor as option to the Proposal.
<b>QUESTION 2. Which engine cooling is required?</b>	<b>ANSWER 2.</b> Correct type of engine cooling – liquid (antifreeze).
<b>QUESTION 3. Which type of remote control and monitoring is required?</b>	<b>ANSWER 3.</b> It's needed to obtain remotely such information, as status, errors, fuel level and other (if possible).
<b>QUESTION 4. What is meant by Leakage control and protection?</b>	<b>ANSWER 4.</b> It's meant that in case of any leakage / level decrease of the technical liquids there will be error displayed / notification provided by the generator.
<b>QUESTION 5. How much cable is needed, if mentioned 100 meters will be enough?</b>	<b>ANSWER 5.</b> Distance form generator to connection point is about 150 meters. Except cable, in terms of reference mentioned "Kit for connection", which should include all necessary items for connection (including additional cables).
<b>QUESTION 6. How to be price on installation and commissioning (including project) to be indicated?</b>	<b>ANSWER 6.</b> If there is no possibility for calculation of costs before application, then price of such works to be indicated as tentative (but it should be mentioned).  During evaluation, UNDP will assess these costs as where changes possible (after application by Bidders).
<b>QUESTION 7. May be plan or a drawing for price calculation of the generator set installation and commissioning?</b>	<b>ANSWER 7.</b> In tender document mentioned all the data, like cable length, necessity of Automatic Transfer Switch, and another items.