



Questions And Answers Report

<u>To:</u>	Bidders
<u>From:</u>	UNDP Syria
<u>Subject:</u>	For the supply of pumping station spares and equipment's
<u>Reference:</u>	UNDP-SYR-ITB-052-20 -
<u>Date:</u>	26-07-2020

UNDP Syria Procurement Unit received question regarding the subject ITB. This question is documented below with respective answers.

Question 1:

It was mentioned in Lot 1, Item 30

Oil pressure switch and in the technical specifications column 2 the specifications for the control transformer are mentioned

Please provide us with the technical specifications for the item 30, which is the oil pressure switch

لقد ذكر في البند رقم 30 من LOT1 حول القاطع الخاص بضغط الزيت حيث أن الحقل الخاص بالوصفات الفنية يشير إلى مواصفات التحكم بالمحولة.

الرجاء ارسال المواصفات الفنية الخاصة بالبند 30 من LOT1.

Answer 1:

Item:30.oil level switch not pressure switch

Type 1002w contact AC 125V 4A, DC 125V 0.4A .

Serial No. 70453.

Mounted on oil pressure unit which has SN,RF:10297-03 EBARA.

It uses for turning the pump off and on .

إن البند 30 هو لجهاز قياس مستوى الزيت وليس لضغط الزيت و يوضع على وحدة ضغط الزيت ذات الرقم التسلسلي
03-10297 ماركة EBARA.

إن البند 30 ذو المواصفات التالية والرقم التسلسلي التالي:

Type 1002w contact AC 125V 4A, DC 125V 0.4A .

Serial No. 70453

Regards,

All other terms and condition remain unchanged.