United Nations Development Programme

Regional Bureau for Arab States

Regional Hub in Amman, Jordan



رنامـــج الأمــم المتــحدة الإنمــائي
لمكـتب الإقليمـــي للـــدول العربــية
المـركز الإقايمـــي في عمــان، الأردن

To: All Bidders

Subject: (RFQ) NO. RBAS-RFQ-016/2020 SUPPLY AND INSTALL CCTV SYSTEM AT UNDP REGIONAL HUB PREMISES

Dear Sirs,

Please find enclose **Addendum No. 01** for the subject RFP, which includes the following:

1. UNDP responses on Bidders' queries and clarifications (Q&A)

Please acknowledge receipt of this Addendum.

Thank you and best regards.

Acknowledged receipt:
Signature:
Name:
Company:

United Nations Development Programme

Regional Bureau for Arab States

Regional Hub in Amman, Jordan



برنامـــج الأمـم المتـحدة الإنمـائي المكتب الإقليمــي للـدول العربـية المركز الإقليمــي في عمـان، الأردن

SN	Query	UNDP Reply & Clarifications
1	Can we offer a partially comply cameras with compliance percentage of 95%. For example the IR range 30m instead of 40m, Given that this will reduce prices significantly? Or we have to stick with the specs in the tender documents to have 100% compliance? if yes can we offer 2 options of cameras?	Please note that there was a mistake in the technical specifications as the IR distance for the Indoor Camera shall read minimum 40 m. (this mean 40m and above is accepted) All other technical specifications shall remain unchanged.
		Please also note that optional offers are not allowed, each company is allowed submit only one option.