

Bidders Questions and Answers

No	Question	Answer
1	<p>Further to our below answered Q.1 Where will the Iron door of the basement and the iron sliding gate doors in which item of BOQ will be priced in?</p> <p>Will a double leaf door be counted as 2 doors?</p> <p>Please Clarify?</p>	<p>There are 2 doors to be priced in the mechanical breakdown Item 4 and sub-item 9.</p> <p>Please give references to the questions so that we can easily identify and reply.</p> <p>A double leaf door is one door.</p>
2	<p>Where will the Iron door of the basement and the iron sliding gate doors in which item of BOQ will be priced in? Giving reference to our above question:</p> <p>1. Iron Door Basement</p> <p>Mechanical Room K4 240X285 M07 Elevation drwg / Along the axes 1/AB Plans drwg MO2</p> <p>Where will the Iron door of the basement in which item of BOQ will be priced in?</p>	<p>In BoQ item E.2 Exterior Doors</p>
3	<p>2. Sliding Iron Door M01 SITE PLAN 1 NUMBER GK 770X120 IRON SLIDING IRON DOOR (SOUTH CAR ENTRANCE) 1 NUMBER GK 770X120 IRON SLIDING IRON DOOR (EAST CAR ENTRANCE)</p> <p>Meanwhile Detail DRWG M07 giving the gate height as 90 cm whereas M01 height is given as 120 cm</p> <p>Where will the iron sliding gate doors in which item of BOQ will be priced in?</p> <p>Please Clarify?</p>	<p>The height of the iron doors will be 1.10m as the same height with new perimeter walls. In M07, at North facade, it is 1.10m too.</p> <p>This item should be priced in BoQ item B11 which is added to (BoQ Revision 01) and uploaded in E-tendering system</p>

4	<p>We would like to ask if there will be a point system in place to differentiate between the contractors who fulfilled the initial requirements as opposed to the amended requirements (Addendum 01), absence of such a system in our opinion, would lead to unfair competition. Such a system would also ensure fair competition in case of any further amendments.</p>	<p>In accordance with UNDP Procurement rules and regulations, the ITB Evaluation Criteria Section 4. Clearly stated that the technical bids shall be evaluated on a pass/fail basis for compliance or non-compliance with the technical specifications identified in the bid document.</p> <p>Therefore, in UNDP context, pointing system in case of Works ITB is not applicable and cannot be used.</p>
---	---	--