



QUESTIONS AND ANSWERS REPORT

To: Bidders

From: UNDP Syria

Subject: Providing and installing solar street lights in Al-Hasaka Governorate LOT.2

Reference: UNDP-SYR-RFQ-073-20

Date: 20.Oct.2020

UNDP Syria Procurement Unit has received questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Questions and Answers		
1	Q. A.	<p>سؤال: يرجى تحديد هل مطلوب تقديم حساس حركة ضمن جهاز الإنارة المطلوب ؟</p> <p>الجواب: نعم ، مطلوب حساس حركة يعمل بنظام الأمواج الميكروية (microwave) متوافق مع منظم الجهد الكهربائي وعلى الأقل ثلاث مراحل وضمن كل مرحلة هناك إمكانية للضبط الزمني من / 0 - 15 / ساعة وإمكانية ضبط استطاعة الخرج من (0 – 100) % .</p>
2	Q. A.	<p>سؤال: ما هي المسافة بين أعمدة الإنارة عند التركيب ؟</p> <p>الجواب: استنادا إلى دفتر الموصفات والشروط الفنية البند رقم / 1 / المسافة من / 30 - 25 / م .</p>
3	Q. A.	<p>سؤال: ورد في دفتر الشروط الفنية البند رقم / 7 / تقديم وتركيب عمود إنارة معدني مزدوج بطول / 9 / م ، يرجى تبين هل العمود المطلوب يحمل جهاز إنارة واحد أم جهازي إنارة ؟</p> <p>الجواب: العمود المطلوب هو عمود إنارة معدني مفرد بطول / 9 / م ويحمل جهاز إنارة واحد .</p>
1	note	<p>ملاحظة : أبدت شركة سليم ملاحظة بعدم مشاركة نتائج وإجراءات فض العروض وعدم إعلام الشركات بنتائج فض العروض وأسباب رفض العروض في المناقصات السابقة ويقترحون إعلام الشركات بما سبق في المناقصات القادمة .</p>

All other terms and conditions remain unchanged