

Site Visit Report

ITB-362-20- Rehabilitation of the Main Electrical Feeder from Anah Electrical Substation to Al-Sakrah District

QUESTIONS AND ANSWERS

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	What's the type of the work in the line ?	The bidder's representatives were informed that the work includes supply and install 14 m poles with all its accessories , 210 mm ² conductor , installing S-MC tower
2	Where are the locations of the damaged line that will be rehabilitated?	-The bidder's representatives were taken to the locations of the damaged line and were given brief about it.