

CLARIFICATIONS dated November 20, 2020

Clarifications to Queries received from prospective Bidders

RFQ-206-IND-2020

Supply, Installation and Commissioning of battery backed Solar PV system for powering of Smart Livelihood Centre

| No | Query | Response | | | | | | | | | | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-----|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---|-----|---|----------------|---|-----------------------|---|--|
| 1 | Reference to Page No.10 of RFQ, under column "Bill of Quantity", Please define the "Hybrid Inverter". We would like to know if it is expected that the Hybrid Inverter will export extra electricity to the Grid. Also, whether the Inverter should be Single Phase or 3 Phase. | It is expected that the hybrid inverter will feed in additional power to the grid during non-operation period of productive load. The inverter should be 3 phase so that it could supply both single phase and three phase loads. | | | | | | | | | | | |
| 2 | Reference to page no.12, clause no.6, should we quote for Grid Tie related components, local liaison expenses at this stage or that would be reimbursed. | The bidder should quote the cost for grid tie up and local expenses at the bidding stage. No additional cost will be reimbursed at the later stage. | | | | | | | | | | | |
| 3 | Kindly clarify the quantity of "computer hardware system" to be supplied for smart livelihood centers. | <table border="1"> <thead> <tr> <th data-bbox="878 1167 1417 1224">Item</th> <th data-bbox="1417 1167 1505 1224">Qty</th> </tr> </thead> <tbody> <tr> <td data-bbox="878 1224 1417 1507">Pre-loaded desktop PC with keyboard, mouse, wireless connecting interface and external sound system, intel i3 processor latest/10 gen, 1TB storage, 8 GB RAM. The system should have preloaded original windows, and Microsoft office and other software and drivers as is required for the purpose of rendering of training</td> <td data-bbox="1417 1224 1505 1507">1</td> </tr> <tr> <td data-bbox="878 1507 1417 1560">UPS</td> <td data-bbox="1417 1507 1505 1560">1</td> </tr> <tr> <td data-bbox="878 1560 1417 1612">43" LED screen</td> <td data-bbox="1417 1560 1505 1612">1</td> </tr> <tr> <td data-bbox="878 1612 1417 1675">A4 size laser Printer</td> <td data-bbox="1417 1612 1505 1675">1</td> </tr> </tbody> </table> | Item | Qty | Pre-loaded desktop PC with keyboard, mouse, wireless connecting interface and external sound system, intel i3 processor latest/10 gen, 1TB storage, 8 GB RAM. The system should have preloaded original windows, and Microsoft office and other software and drivers as is required for the purpose of rendering of training | 1 | UPS | 1 | 43" LED screen | 1 | A4 size laser Printer | 1 | |
| Item | Qty | | | | | | | | | | | | |
| Pre-loaded desktop PC with keyboard, mouse, wireless connecting interface and external sound system, intel i3 processor latest/10 gen, 1TB storage, 8 GB RAM. The system should have preloaded original windows, and Microsoft office and other software and drivers as is required for the purpose of rendering of training | 1 | | | | | | | | | | | | |
| UPS | 1 | | | | | | | | | | | | |
| 43" LED screen | 1 | | | | | | | | | | | | |
| A4 size laser Printer | 1 | | | | | | | | | | | | |
| 4 | <p>Technical Offer:</p> <p>In technical terms it is impossible to mention only one make of item like module/battery/inverter due to Covid-19.</p> | Maximum of two make will be allowed, however both the make should be MNRE approved and should comply to the standard specified in the RFQ. | | | | | | | | | | | |

| No | Query | Response |
|-----------|-------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|
| | We will mention more than one make for individual items, is it acceptable ? | |
| 5 | In technical offer whether we mention the quantity for 5kwp pv system or 20Kwp pv system (i.e. 5Kwp \times 4nso=20Kwp | Please mention the quantity of the 20KWp PV system. |

United Nations Development Programme, 55 Lodi Estate, New Delhi - 110 003.