



9 December 2020

Addendum 1

To: All potential bidders

Subject: IRQ-ITB-395/20 - COVID-19 Response- Isolation Rooms in Diwaniya, Iraq

With reference to the Invitation to Bid ITB-395/20 dated 2 December 2020 on COVID-19 Response- Isolation Rooms in Diwaniya, Iraq.

We hereby notify the following amendment of the above referred ITB as follows:

- BOQ – Mechanical work item #6: airflow capacity of the Exhaust Fan is changed to 4250 cfm that matches the compliance sheet.

Please find attached the revised updated BOQ for submission of bid. The bid submitted on the previous version will not be accepted.

Please be guided accordingly.

Thank you.

End of Addendum n. 1

Sincerely,

A handwritten signature in blue ink, which appears to read 'Piero Franceschetti', is positioned above the printed name.

Piero Emanuele Franceschetti
Head of Service Center,
UNDP Iraq