

QUESTIONS AND ANSWERS

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	A question about choosing the final site for the project cause there is no references points within the site-plan drawing.	It was answered that the site is definitively defined in the back garden of the Prosthetics Center and adjacent to the blood bank, as confirmed that by Dr. Sabah, the director of the hospital, and Mr. Abed al-Amir Abed al-Hussein, the representative of the head of the engineering department at the hospital.
2	The question was asked about entry ports and accessibility to the site.	We clarified that there are three ways to access the site, two of which are paved and the third is unpaved, which can be used after coordination with the hospital administration.
3	A question was asked about the existence of a biological sewage line close to the site.	We clarified, according to the engineering staff of the hospital, that there is a sewage line opposite the project, which is connected to a biological treatment plant.
4	The question was asked about the possibility of obtaining a national electricity line + generator from the hospital administration during implementation.	We clarified, according to the engineering staff of the hospital, that there is a problem with the hospital in electrical loads, so the contractor will be equipped with a national power line and for the purpose of lighting only.