



Site Visit Report

ITB-194-21 Rehabilitation of High Tension transmission lines 11 KVA in Suleiman Bek - Salahdien Governorate

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Should all materials used in the project be delivered to the stores of electricity in Tikrit for testing?	Yes, all electrical materials except construction materials are test in governmental construction lab.
2	Do we have anything to do with old poles and wires?	No this is end user's business