

Notice to Bidders/Tenderers
Tender Notice 2

Bidders are kindly requested to note the following changes to the bill of quantity.

Originally	Revised or should read as
Grundfos Submersible SP46-5 of 7.5kW 3x400VAC 50Hz, 6" pump 3" outlet discharging at least 36 m3/hr at TDH 50m.	Submersible of 7.5kW 3x400VAC 50Hz, 6" pump 3" outlet discharging at least 36 m3/hr at TDH 50m.
Bill No. 2.3, Solar Pumps – 2.3.2 - Control Panel 7,5kW with electrical protections (VACON VERSION) with inbuilt dry protection mechanism.	Bill No. 2.3, Solar Pumps – 2.3.2 - Control Panel 7,5kW with electrical protections with inbuilt dry protection mechanism.

Revised bill of quantity uploaded.