

Bidders Clarifications 01 – dated 20 September 2021

RFQ No.: UNDP CYP RFQ 235 2021

Construction of Street Shading in Nicosia

Bidders Questions and Answers

| No | Question | Answer |
|----|--|---|
| 1 | ANNEX 3: TECHNICAL AND FINANCIAL OFFER – WORKS states that Quantity for poles is 220 and Number of foundations for poles 200 Nos. To be same? | Quantity for the poles and the foundations will be 200 |
| 2 | Request for Quotation - Civil works for illuminations - 2.54 (1 inch) mm pvc pipes will be installed between each pole and connected to the pipe from the foundations" - This is not clear how electricity is to be connected? More detail is needed please? Is there only one pipe under each pole as shown on drawings etc.? | As shown on the drawings this is only the civil works component; electrical components and connections will be handled under the provisional sum item. |
| 3 | Connecting elements - Gijon Screws (Annex 3) only 1000 No's is estimated. We estimated 12 Nos/pole x 220 poles = 2640 No's.. Please clarify? | These are estimates and works done will be based on the unit rates. |
| 4 | Could you please confirm if there is any security bond required for this RFQ. | Security bond is not required for this RFQ. |
| 5 | Are you going to modify the existing BOQ for the corrected number of poles? You said in your previous clarification mail poles to be estimated as 200 Nos.. | The existing BoQ and number of poles maybe revised subject to advice from our designers. We will inform all bidders - if any changes made as appropriate. |