

**Minutes of the Site Visit
for ItB_18_2021
Construction of a CICOV-Hospitalization Center for Covid-19 Patients
in the Mavalane Hospital, Maputo City**

as of 25 November 2021, 10:00,
Venue: Hospital Geral de Mavalane (HGM)

Agenda:

- I. Site reconnaissance
- II. On-site Project briefing

I. Site reconnaissance

9 representatives of 6 bidders were present to the site, along with MISAU, DSCM and HGM representatives and UNDP members.

After introduction of attendants, the MISAU member opened the session highlighting the importance of the delivery time, due to the emergency nature of the works.

The representative of the DPS/HGM mentioned the availability and willingness of the hospital staff to collaborate with the awarded contractor for the successful completion of the works.

UNDP members revisited the ITB, the SoW and project details, including the preliminary location plan. A reference was made to the overall project, but it was emphasized that the scope under tender is strictly limited to the works specified in the SoW and BoQ, namely surgical block, the morgue, the medical support staff services and the required civil works.

Questions and Answers

- 1. Bidder questioned about the inclusion of the infirmary block and it was clarified that they are not part of this scope.
- 2. Bidder questioned about the contents of this scope and it was clarified that it is comprised by the surgical block, the morgue, the medical support staff services and the required civil works.
- 3. Bidder questioned about the location of the nearest power transformer (PT) to connect the electricity to the contractor yard, and the hospital staff indicated the PT near the Eastern entrance and the genset / generator. A nearest connection – new electrical board / box – is also available, but the final connection point will be agreed upon during the works execution.

4. Following the above the bidders queried about the water supply for the contractor yard and the elevated water tank was pointed as the main option. It was stressed by the hospital staff that for both water and electricity, there is the option to connect to the public water and electricity supplier to provide a temporary direct connection to the contractor's yard.
5. Bidder queried about the deadline for the submission of the proposal – 6th of December – as being too tight to contact their modular units' suppliers and submit a more accurate bid. It was, again, emphasized by both UNDP and MISAU that the scope is related to emergency needs and that the bidders will also be evaluated based on their delivery timeframe.

Without further questions, the session was completed, and the participants dismissed.

Prepared by UNDP

Eurico da Conceição



Sergio de Barros

