

**ADDENDUM 01****Date: 19th November 2021**

To: All Potential Bidders
From: UNDP IRAQ

Subject: CHANGE OF DOCUMENT TO BE SUBMITTED (BOQ) - ITB-413-21 Extension Pipe and Distribution Networks for (Sfirat, Minizla, Jamalia, Sliman Al Ghrab, Burglia, Arisha)-Hawija District-Kirkuk Governorate GPS 35.381788, 43.772415; 35.414852, 43.723864; 35.396003, 43.758371; 35.363332, 43.750837

Reference is made to the UNDP published procurement notice for the **ITB-413-21 Extension Pipe and Distribution Networks for (Sfirat, Minizla, Jamalia, Sliman Al Ghrab, Burglia, Arisha)-Hawija District-Kirkuk Governorate GPS 35.381788, 43.772415; 35.414852, 43.723864; 35.396003, 43.758371; 35.363332, 43.750837** on UNDP and UNGM websites respectively.

All potential interested bidders are hereby notified that:

This Addendum is issued with the purpose to amend ITB-413-21 dated 11 November 2021 as follows.

1. Due to an update on **Annex 1 BOQ** price schedule to ITB-413-21. Some items descriptions were Changed. The interested bidders are requested to use the updated version of BOQs. The old version will not be accepted.
2. The new updated BOQ has been uploaded to the online Atlas e-tendering system.
3. Bidders to download and consider the new BOQ and submit your offer accordingly. The old BOQ will not be accepted.

Following clarifications were sought by Email and during the site visit. Please see the responses below:

Questions	Answers
In the BoQ you mentioned that one of the required PE pipes diameter is 300 mm (DN300) i guess that you mean 315 mm because 300mm dia. isn't exist in polyethylene pipes instead it there is 315mm.	Item description has been revised. Please find attached the revised BoQ.
You mentioned in the BoQ that (using electro fusion welding to connect PE pipe 300mm with the main existing network, to connect 225mm with 300mm pipe, to connect 160mm with 225mm pipe and so on, my question is such method (electro fusion) is it used for just connecting between two different pipe in diameter or it should use to all pipes connection process i.e. could we used another pipe connection method (butt welding) for connecting pipes in same diameter for example connecting 2000 m 300 mm pipe together by butt welding?	The required connection method is electro fusion welding.
You mentioned in the BoQ and in the compliance sheet that the PE pipes are (RC) pipe, which is expensive PE pipe, could we offer and submit for PE pipes without (RC) specification?	The required pipe is PE RC type.
could we offer for Polyethylene pipe same required specifications but not (RC)	No, RC is not acceptable, only Polyethylene Pipes

The interested bidders are kindly requested to adhere to the above guidance and submit their bids before the deadline accordingly.

This Addendum 01 forms an integral part of the **ITB-413-21**.

All other Terms and Conditions in this ITB will remain in full force and unchanged.

Thank you in advance for your interest in UNDP procurement opportunities.

Yours sincerely,

Shadi Hussein
Head of Procurement