

Pre-Bid Meeting Minutes

Questions and answers (1st round)

Date of the Meeting: 30 November 2021

REQUEST FOR PROPOSAL: ITB/PNG/006-2021 - Procurement of Roof Materials

	Questions	Answers
1	Can you please provide the exact location for delivery?	Proposed Sir Yuwi School site adjacent to Tari airport, Hela Province.
2	Please confirm your arrangements to unload the roofing materials from vehicles in Tari. Do you have a forklift on-site, and what tonnage is it rated at?	Unloading Equipment: Forklift with 2.5 tone capacity available on site to unload materials.
3	Corrugated Roofing Steel Sheet The Corrugated profile is called out as "Custom Orb". Are you going to provide the profile or are you flexible on the profile? Is there a specific color you would like?	CustomOrb is a trademarked corrugated profile. Only bids with CustomOrb profile will be considered. Zinc-colored.
4	5V Crimp Steel Sheet Is there a specific rib height you would like? Is there a specific color you would like?	Rib Height: 1/2"; Rib Spacing: 12" from centre; Gauge: 29" Zinc-colored.
5	For good dimension, whether the tolerance is acceptable?	Up to 20mm tolerance from the prescribed width is acceptable.
6	Are there any flexibilities in the delivery timelines?	We request to deliver goods as indicates in ITB.
7	Should we share certificates for the goods supplied?	Yes, we request to share them as part of the bid.