

United Nations Development Programme UNDP- Yemen	BID BULLETIN 1:
	ITB Ref: ITB-YEM-0037-2022
	Event ID number: 0000012209
	PRE-BID MEETING MINUTES Page 1 of 2
Date: 05 May 2022	

- Bid Ref/Subject:** ITB-YEM-0037-2022 -New Building in UNDP Compound Sana'a, Yemen,
- Meeting date &time:** 27 April 2022, 02:00 Pm Sana'a time
- Meeting Location:** UNDP CO- Sana'a, Yemen

Site Visit Questions & Answers

Q1	Where is the location of the temporary gate?
Response Q1	The temporary gate is already indicated in the drawings advertised
Q2	Where can we store our materials?
Response Q2	The contractor should store the material in any place at his own cost during the construction period
Q3	Are the building permissions under the contractor responsibilities?
Response Q3	Yes
Q4	What are the working hours?
Response Q4	For the noisy works such as demolition will be after working hours in the office (After 4:00PM local time) for other works it can be done from 8 am till midnight.
Q5	The elevator capacity is 450kg and the well dimensions can be fit with 630kg?
Response Q5	The elevator capacity has been updated in the amended BOQ to be 630kg
Q6	What is the measurement method?
Response Q6	As per the BOQ, the measurement method is indicated for each item.
Q7	Where is the location of fire extinguishers?
Response Q7	It will be added to the revised drawings
Q8	What is the length of 70mm² earthing cable?
Response	The estimated length is about 30m

United Nations Development Programme UNDP- Yemen	BID BULLETIN 1: ITB Ref: ITB-YEM-0037-2022 Event ID number: 0000012209
	PRE-BID MEETING MINUTES Page 2 of 2
	Date: 05 May 2022

Annexes	Annex I – Revised BOQ. Annex II – Revised Drawings.
	<p style="color: red;">Bidders failed to provide their offers in accordance with the updated BOQs and drawing will be rejected at the preliminary evaluation stage.</p>