No	DATE	REVISION
0	ISSUED FOR REVIEW PURPOSE ONLY	
1		
2		
3		

NOTES
- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.
- DO NOT SCALE DRAWINGS.
- VERIFY ALL DIMENSIONS ON SITE BEFORE COMMENCEMENT OF WORK.
- ALL DRAWINGS SHALL BE READ IN CONJUNCTION WITH SPECIFICATIONS AND SCHEDULES.
- ALL WORK SHALL BE CARRIED OUT IN ACCORDANCE WITH LOCAL LAWS AND UNDP SPECIFICATIONS.
- ANY DISCREPANCIES SHALL BE REPORTED TO UNDP ENGINEERS.



NOTE:
1. GRAVEL SIZE IS 85 TO 100 PERCENT LAGER THAN WELL SCREEN APERTURE.
2. GRAVEL PACK WILL EXTEND A MINI. A 3M ABOVE THE TOP OF THE SCREEN.
3. THE UPPER 3 METERS OF WELL BORE WILL BE SEALED WITH CEMENT GROUT . GROUT SHALL BE PLACED IN ONE CONTINUOUS MASS AND BE IMPERMEABLE.
4. THE SPACE AROUND THE WELL SCREEN WILL BE FILLED WITH CRUSH STONE OR GRAVEL PACK SIZE OF Ø10MM - Ø 40MM.

ISSUED FOR TENDER

BENEFICIARY: Ministry of Public Health, Islamic Republic of Afghanistan

IMPLEMENTOR: UNITED NATIONS DEVELOPMENT PROGRAM

PROJECT: BORE HOLE FOR KUNDUZ RRL

DRAWING TITLE: BORE HOLE DETAILS

DESIGNED:	UNDP	PROJECT NO:		DRAWING NO.	REV.
DRAWN:	UNDP	SHEET SIZE:	A3	WS01	0
CHECKED:	UNDP	SCALE:	1:40		
APPROVED:	UNDP	DATE:	20.06.2022		