



No	DATE	REVISION
0		ISSUED FOR REVIEW PURPOSE ONLY
1		
2		
3		

NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.
- DO NOT SCALE DRAWINGS.
- VERIFY ALL DIMENSIONS ON SITE BEFORE COMMENCEMENT OF WORK.
- ALL DRAWINGS SHALL BE READ IN CONJUNCTION WITH SPECIFICATIONS AND SCHEDULES.
- ALL WORK SHALL BE CARRIED OUT IN ACCORDANCE WITH LOCAL LAWS AND UNDP SPECIFICATIONS.
- ANY DISCREPANCIES SHALL BE REPORTED TO UNDP ENGINEERS.

- NOTE:
1. GRAVEL SIZE IS 85 TO 100 PERCENT LAGER THAN WELL SCREEN APERTURE.
 2. GRAVEL PACK WILL EXTEND A MINI. A 3M ABOVE THE TOP OF THE SCREEN.
 3. THE UPPER 3 METERS OF WELL BORE WILL BE SEALED WITH CEMENT GROUT . GROUT SHALL BE PLACED IN ONE CONTINUOUS MASS AND BE IMPERMEABLE.
 4. THE SPACE AROUND THE WELL SCREEN WILL BE FILLED WITH CRUSH STONE OR GRAVEL PACK SIZE OF Ø10MM - Ø 40MM.

ISSUED FOR TENDER

BENEFICIARY				
 Ministry of Public Health Islamic Republic of Afghanistan				
IMPLEMENTOR				
 UNITED NATIONS DEVELOPMENT PROGRAM				
PROJECT: BORE HOLE FOR NANGARHAR RRL				
DRAWING TITLE: BORE HOLE DETAILS				
DESIGNED:	UNDP	PROJECT NO:	DRAWING NO. WS01	REV. 0
DRAWN:	UNDP	SHEET SIZE: A3		
CHECKED:	UNDP	SCALE: 1:40		
APPROVED:	UNDP	DATE: 20.06.2022		