

## Minutes of Pre-bid meeting Clarification and responses

United Nations Development Programme (UNDP)		
Subject: UNDP/AFG/2022/ITB/ 0000013391		
Tittle: SUPPLY, INSTALLATIONS, TESTING AND COMMISSIONING OF SOLAR ELECTRICAL AND HOT		
WATER SYSTEM IN 60 FAMILY HEALTH HOUSES IN AFGHANISTAN		
Venue	Virtual via Zoom Call	
Date of Conference: 23/08/2022	Time: 10:00 a.m.	
Pre bid conference was opened with following	Introduction of UNDP team	
agenda:	2. Briefing on scope of RFP (Administrative	
	and Technical)	
	3. Questions and answers	

The following queries were raised by the participating representatives from the prospective bidders, and the following respective responses are provided:

## **CONDEX TECHNOLOGY**

No.	Queries	Responses	
1	Initially there was a detailed explanation about the use of the required forms and importance to provide all the information. Also, there was an explanation about		
	I	e submitted as part of the bid. All this information	
	is already explained in the ITB Document.		
2	How many water wells are there for this	There are 60 water wells, one in each facility	
	project?	that will be utilized for the provision of hot water systems.	
3	How many meters deep is each water	The depth of water well varies. It is in the range	
	wells?	of 20-45 meters.	
4	How many meters is the water?	Approx. 18-42 meters.	
5	Is it necessary to dig a well?	The water well is dug to provide to the water	
		demand of the health facilities.	
6	Is there any municipal electricity	No.	
	network? Does a generator already exist		
	for water wheels?		
7	Is the water heater an active system or a passive system?	A passive system, meaning no electricity is required for the water heaters.	
8	Is there a cold water tank?	Yes	
9	The BOQ is not mentioned in tender	The quantities in the BOQ are cumulative	
	documents if you provide us the Total	quantities required for all facilities. Please kindly	
	required capacity of each side and BOQ.	refer to Annex	
10	The location of 60 family health houses	Please refer to the list provided as Annex	
	is not specified in the document.		

	Is the lightings system of the medical centers building also part of the scope of this project?	Yes, please kindly refer to the BOQ and the scope of work of the requirement.
11	if there is no sun and the weather is cloudy what will be the source of water heater to operate?	Please refer to the answer of Question no. 6. The water heater has in-built storage tanks.
12	Is it possible to have the contacts of technical department of medical centers to be able to get further technical information?	This information will be provided to the selected bidder. In case you require additional information, please kindly submit it as requirement of clarification and we will provide the required clarification.