


Addendum No.1**Title:** Procurement of Generator for CPHL and 6 Regional Reference Labs**RFQ Reference:** RFQ-007-22

United Nations Development Programmed (UNDP)		
RFQ Reference	Original	Addendum
ANNEX 1: SCHEDULE OF REQUIREMENTS	<p>Supply and Installation of 50 KVA Power Generators (3Phase)</p> <p>Minimum Rating 50 kVA / 50 kW</p> <p>Maximum Rating 55 kVA / 55 kW</p> <p>Emissions/Fuel Strategy EU Stage IIIA emissions compliant.</p> <p>50 Hz Prime 50 kVA / 50 kW</p> <p>50 Hz Standby 55 kVA / 55 kW</p> <p>60 Hz Prime - / -</p> <p>Frequency 50 Hz</p> <p>Speed 1500 RPM</p> <p>Voltage 220-240 Volts</p> <p>50 Hz Prime Rating Standard reference conditions 25C (77F) Air Inlet Temp, 100m (328 ft) A.S.L. 30% relative humidity.</p> <p>Fuel consumption data at full load with diesel fuel with a specific gravity of 0.85 and conforming to BS2869: 1998, Class A2.</p> <p>Note: the transportation and installation cost should be included in the bid price.</p>	<p>Supply and Installation of 45 KVA Power Generators (3Phase)</p> <p>Minimum Rating 45 kVA</p> <p>Maximum Rating 50/56.3 kVA</p> <p>Emissions/Fuel Strategy EU Stage IIIA emissions compliant.</p> <p>50 Hz Prime 45 kVA</p> <p>50 Hz Standby 50 kVA</p> <p>60 Hz Prime - / -</p> <p>Frequency 50/60 Hz</p> <p>Speed 1500 RPM</p> <p>Voltage 220-240 Volts</p> <p>50 Hz Prime Rating Standard reference conditions 25C (77F) Air Inlet Temp, 100m (328 ft) A.S.L. 30% relative humidity.</p> <p>Fuel consumption data at full load with diesel fuel with a specific gravity of 0.85 and conforming to BS2869: 1998, Class A2.</p> <p>Note: the transportation and installation cost should be included in the bid price.</p>
ANNEX 3: TECHNICAL AND FINANCIAL OFFER - GOODS	<p>Supply and Installation of 50 KVA Power Generators (3Phase)</p> <p>Minimum Rating 50 kVA / 50 kW</p> <p>Maximum Rating 55 kVA / 55 kW</p> <p>Emissions/Fuel Strategy EU Stage IIIA emissions compliant.</p> <p>50 Hz Prime 50 kVA / 50 kW</p> <p>50 Hz Standby 55 kVA / 55 kW</p> <p>60 Hz Prime - / -</p> <p>Frequency 50 Hz</p> <p>Speed 1500 RPM</p> <p>Voltage 220-240 Volts</p> <p>50 Hz Prime Rating Standard reference conditions 25C (77F) Air Inlet Temp, 100m (328 ft) A.S.L. 30% relative humidity.</p> <p>Fuel consumption data at full load with diesel fuel with a specific gravity of 0.85 and conforming to BS2869: 1998, Class A2.</p> <p>Note: the transportation and installation cost should be included in the bid price.</p>	<p>Supply and Installation of 45 KVA Power Generators (3Phase)</p> <p>Minimum Rating 45 kVA</p> <p>Maximum Rating 50/56.3 kVA</p> <p>Emissions/Fuel Strategy EU Stage IIIA emissions compliant.</p> <p>50 Hz Prime 45 kVA</p> <p>50 Hz Standby 50 kVA</p> <p>60 Hz Prime - / -</p> <p>Frequency 50/60 Hz</p> <p>Speed 1500 RPM</p> <p>Voltage 220-240 Volts</p> <p>50 Hz Prime Rating Standard reference conditions 25C (77F) Air Inlet Temp, 100m (328 ft) A.S.L. 30% relative humidity.</p> <p>Fuel consumption data at full load with diesel fuel with a specific gravity of 0.85 and conforming to BS2869: 1998, Class A2.</p> <p>Note: the transportation and installation cost should be included in the bid price.</p>

Yours sincerely

DocuSigned by:

27-Sep-2022



C37FA973C99B45F...

Head of Procurement
UNDP Afghanistan

DS
SMA