

Date: Thursday, September 29, 2022
Reference: **MyITB2022-005 The Proposed Design, Construction and Completion of the I.D Renovation Works for The Expansion of United Nation Malaysia Office at Level 9, Menara PjH, Lot 2C2, Precinct 2, Putrajaya**
Subject: Clarification Letter 1

Dear Sir/ Madam,

Please be informed that, further to inquiries from prospective Offerors, we are sending both the clarification request received and the respective UNDP response to all Offerors and posting on relevant procurement websites in accordance with our standard practices.

Clarification Note:		
No:	Question	Answers / Corrections
1	We would like to request the As Built / base-built MEP drawings i.e., AC system, Fire Protection, Electrical, Plumbing, BSS etc.	The drawings are attached at Atlas E-tendering, UNDP Procurement Notice & UNGM.
2	Please provide us the technical specifications for existing building PA system, Building Security System & Fire alarm system for integration and coordination.	This information will be share with the awarded contractor upon request.
3	We would like to request a list on numbers / quantity of the equipment racks and load for UPS.	One (1) unit of 1.5 KVa UPS with two (2) units CISCO 48 port switch connected to the UPS
4	Please advise of security works are under us?	The security works is not included in this tender.
5	Please provide CAD file of all drawings.	The CAD drawing is attached at Atlas E-tendering.
6	Revision on the Terms of Reference (Optional requirement) Note: Please provide quote based on the optional items	<ul style="list-style-type: none"> • 3 x CAT 6 cables for CCTV • 1 x CAT 6 cable for Door Access • 2 x CAT 6 cable from Level 10 IT room to Level 9 • 56 x CAT 6 (RJ45) workstations • Entrance door as Firestop wall • Workstations:- <ul style="list-style-type: none"> ○ 4 power plugs, ○ 1 USB ○ 1 Cat 6 (RJ45) • For pantry, please quote:- <ul style="list-style-type: none"> ○ Table top for dining ○ Cabinet design to store 200L Refrigerator, microwave, water

		<ul style="list-style-type: none">inlet for tabletop water dispenser and sink<ul style="list-style-type: none">○ Grease trap for sink• Row of Full height cabinet located next to the Utility room
--	--	---

All other terms and conditions remain the same.

Thank you and best regards,

Procurement Malaysia
UNDP