

### Addendum # 1

**Tender Description:** For the supply and installations of aluminum partitions and curtain for office renovation

**Tender Reference:** ETH4154

Dear Mr. /Ms.: Bidders:

This Addendum # 1 is issued to amend the tender as follows.

S.No	Bidders Question			UNDP Response
	BOQ No	Description	Queries	
1	1	Fabricate and fix aluminium door, covered with 10mm thick plywood, fix approved quality lock.		
		D1	What will be the thickness of the door? Whether it's a glazed door or flush door? What is the frame material & it's section details? Please provide Door hardware details.	D1, D3 are designated for archive and store . We cannot specify lock brand. Indicate what you have quoted for. Aluminium section is usual 50mm Wide. Specify wall thickness. Evaluation is on quality not price.
		D3	Please provide Door hardware details. Also clarify what type of door is this, because in drawing nothing is shown.	
2	2	Full height (Floor to concrete ceiling height Partition) (Soundproof) (refer to attached drawing)		

		WD1	<p>The Drawing says double solid panel. Please clarify what type of panel is this?</p> <p>Also provide the thickness and section details of aluminium frame for this partition.</p>	<p>WD1:WD2; WD3 are soundproof elements. Although we have given an indication of the thickness it is the responsibility of the contractors to supply and install soundproof partition. In other words, it is “turn key”. We expect certification of assurance</p>
		WD2	<p>The Drawing says double solid panel. Please clarify what type of panel is this?</p> <p>Also provide the thickness and section details of aluminium frame for this partition.</p>	
		WD3	<p>In the drawing, for WD3, nothing is mentioned. Please clarify what type of panel is this?</p> <p>Also provide the thickness and section details of aluminium frame for this partition.</p>	
		WD5	<p>Please provide the section details of aluminium stiffener (RHS) as shown in drawing.</p>	<p>WD5 is a long element. To have a straight surface you will have to brace. Fixing on the ground alone will not be sufficient. You can use aluminium RHS size (might be around 60*60*2) fixed to the ceiling. Exact size can be determined when you prepare shop drawings.</p>

3	3	Full height (Floor to concrete ceiling Partition) (Non Soundproof)	Please clarify whether these non-sound proof partitions are glazed partition or solid partition. Also provide its panel details. What are the profile section details.	
4	4	Curtain	Please provide the make and Shade of the curtain.	Curtain: I think the description and movie is sufficient. We can not recommend brand (make)

Each Bidder shall consider this information given in this Addendum to prepare their bids.

**Best Regards,**  
**Procurement Team**  
 UNDP Ethiopia CO